

No. 21-_____

**IN THE UNITED STATES COURT OF APPEALS
FOR THE NINTH CIRCUIT**

CITY AND COUNTY OF SAN FRANCISCO,

Petitioner,

v.

U.S. ENVIRONMENTAL PROTECTION AGENCY,

Respondent.

PETITION FOR REVIEW

Of Counsel:

John Roddy (CA Bar No. 96848)

Estie Kus (CA Bar No. 239523)

Deputy City Attorneys

Office of City Attorney Dennis Herrera

City and County of San Francisco

1 Carlton B. Goodlett Pl.

Telephone No.: (415) 554-3986

John.S.Roddy@sfcityatty.org

Estie.Kus@sfcityatty.org

Richard S. Davis (application pending)

Andrew C. Silton

BEVERIDGE & DIAMOND, P.C.

1900 N Street NW, Suite 100

Washington, DC 20036

Telephone No.: (202) 789-6000

rdavis@bdlaw.com

asilton@bdlaw.com

*Attorneys for Petitioner City and County
of San Francisco*

February 9, 2021

PETITION FOR REVIEW

The City and County of San Francisco hereby petitions the United States Court of Appeals for the Ninth Circuit pursuant to Federal Rule of Appellate Procedure 15(a) and Section 509(b)(1) of the Clean Water Act, 33 U.S.C. § 1369(b)(1), to review the U.S. Environmental Protection Agency's (EPA) final agency action regarding National Pollutant Discharge Elimination System Permit No. CA0037681 (the Permit, attached as Exhibit 1), which authorizes discharges from and imposes requirements on certain facilities owned and operated by San Francisco.¹ EPA Region 9 (the Region) approved the Permit on December 10, 2019. In order to exhaust its administrative remedies, San Francisco filed a petition for review with the Environmental Appeals Board (the Board) on January 13, 2020, and a supplement to that petition on June 30, 2020. The Board denied San Francisco's requests for review in a December 1, 2020 order. *In re City & Cnty. of S.F.*, 18 E.A.D. 322 (EAB 2020) (attached as Exhibit 2). On December 22, 2020, The Region issued its Notice of Final Permit Decision (attached as Exhibit 3), which became a final agency action on January 5, 2021. *See* 40 C.F.R. § 23.2.

¹ The San Francisco Bay Regional Water Quality Control Board has assigned the Permit Order No. R2-2019-0028.

February 9, 2021

Respectfully submitted,

Of Counsel:

John Roddy (CA Bar No. 96848)

Estie Kus (CA Bar No. 239523)

Deputy City Attorneys

Office of City Attorney Dennis Herrera

City and County of San Francisco

1 Carlton B. Goodlett Pl.

Telephone No.: (415) 554-3986

John.S.Roddy@sfcityatty.org

Estie.Kus@sfcityatty.org

s/ Andrew C. Silton

Richard S. Davis (application pending)

Andrew C. Silton

BEVERIDGE & DIAMOND, P.C.

1900 N Street NW, Suite 100

Washington, DC 20036

Telephone No.: (202) 789-6000

rdavis@bdlaw.com

asilton@bdlaw.com

*Attorneys for Petitioner City and County
of San Francisco*

Exhibit 1

**U.S. ENVIRONMENTAL PROTECTION AGENCY
REGION IX**

75 Hawthorne Street, San Francisco, California 94105
(415) 947-8707 • Fax (415) 947-3549
<http://www.epa.gov/region9/>

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION**

1515 Clay Street, Suite 1400, Oakland, CA 94612
(510) 622-2300 • Fax (510) 622-2460
<http://www.waterboards.ca.gov/sanfranciscobay>

**ORDER No. R2-2019-0028
NPDES No. CA0037681**

**WASTE DISCHARGE REQUIREMENTS AND
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT
FOR CITY AND COUNTY OF SAN FRANCISCO
OCEANSIDE WATER POLLUTION CONTROL PLANT, WASTEWATER
COLLECTION SYSTEM, AND WESTSIDE RECYCLED WATER PROJECT**

The following Discharger is authorized to discharge from the locations listed in Table 2 in accordance with the waste discharge requirements (WDRs) and federal National Pollutant Discharge Elimination System (NPDES) permit requirements set forth in this Order:

Table 1. Discharger Information

Discharger	City and County of San Francisco
Facility Name	Oceanside Water Pollution Control Plant, Wastewater Collection System, and Westside Recycled Water Project
Facility Address	3500 Great Highway San Francisco, CA 94132 San Francisco County
CIWQS Place Number	256498

Table 2. Discharge Locations

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
001	Treated effluent, including the following: <ul style="list-style-type: none"> • Secondary-treated effluent from Oceanside Water Pollution Control Plant (dry weather); • Primary- and secondary-treated effluent from Oceanside Water Pollution Control Plant (wet weather); • Equivalent-to-primary-treated effluent from Westside Transport/Storage Structure (wet weather); and • Reverse osmosis concentrate from Westside Recycled Water Project, when operational (dry and wet weather). 	37.70500	-122.57750	Pacific Ocean, Offshore
CSD-001	Equivalent-to-primary-treated effluent (wet weather)	37.71528	-122.50444	Pacific Ocean (Fort Funston, Ocean Beach)

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
CSD-002	Equivalent-to-primary-treated effluent (wet weather)	37.73778	-122.50806	Pacific Ocean (Vicente St., Ocean Beach)
CSD-003	Equivalent-to-primary-treated effluent (wet weather)	37.76389	-122.51167	Pacific Ocean (Lincoln Way, Ocean Beach)
CSD-004	Equivalent-to-primary-treated effluent (wet weather)	37.78472	-122.51028	Pacific Ocean (Mile Rock)
CSD-005	Equivalent-to-primary-treated effluent (wet weather)	37.78778	-122.49167	Pacific Ocean (China Beach)
CSD-006	Equivalent-to-primary-treated effluent (wet weather)	37.78944	-122.48778	Pacific Ocean (Baker Beach)
CSD-007	Equivalent-to-primary-treated effluent (wet weather)	37.78944	-122.48694	Pacific Ocean (Baker Beach)

Table 3. Administrative Information

The U.S. Environmental Protection Agency, Region IX, issued this Order on:	
The San Francisco Bay Regional Water Quality Control Board adopted this Order on:	September 11, 2019
This Order shall become effective on:	November 1, 2019
This Order shall expire on:	October 31, 2024
The Discharger shall file a Report of Waste Discharge as an application for reissuance of WDRs in accordance with California Code of Regulations, title 23, and an application for reissuance of a National Pollutant Discharge Elimination System (NPDES) permit no later than:	February 1, 2024
This discharge is classified as follows:	Major

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

NPDES No. CA0037681

Administrative Information for U.S. Environmental Protection Agency, Region IX

This permit was issued on:	December 10, 2019
This permit shall become effective on:	February 1, 2019
Permit reapplication due no later than:	February 1, 2024
This permit shall expire at midnight on:	October 31, 2024

In accordance with 40 CFR 122.21(d), the permittee shall submit a new application for a permit at least 180 days before the expiration date of this permit, unless permission for a date no later than the permit expiration date has been granted by the Director.

Signed this 10th day of December, 2019, for the Regional Administrator.



Tomás Torres, Director
Water Division

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

The signatures below certify that this Order with all attachments is a full, true, and correct copy of the Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on the date indicated above, and an NPDES permit issued by the U.S. Environmental Protection Agency, Region IX, on the date above.

 7/12/2019

Michael Montgomery, Executive Officer
San Francisco Bay Regional Water Board

Tomás Torres, Water Division Director
U.S. Environmental Protection Agency

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Contents

I.	Facility Information	5
II.	Findings.....	5
III.	Discharge Prohibitions.....	6
IV.	Effluent Limitations and Discharge Specifications	7
	A. Technology-Based Effluent Limitations	7
	B. Water Quality-Based Effluent Limitations	8
V.	Receiving Water Limitations	9
VI.	Provisions.....	9
	A. Standard Provisions.....	9
	B. Monitoring and Reporting.....	9
	C. Special Provisions	10
	1. Reopener Provisions	10
	2. Effluent Characterization Study and Report.....	10
	3. Pollutant Minimization Program	11
	4. Special Provisions for Publicly-Owned Treatment Works (POTWs).....	13
	5. Combined Sewer System.....	15
	6. Westside Recycled Water Project Operations Notification.....	23
	7. Flame Retardant Special Study	23
	8. Efficacy of Combined Sewer System Controls Special Study.....	23

Tables

Table 1.	Discharger Information.....	1
Table 2.	Discharge Locations	1
Table 3.	Administrative Information	2
Table 4.	Effluent Limitations - Oceanside Water Pollution Control Plant.....	7
Table 5.	Effluent Limitations - Westside Recycled Water Project.....	8
Table 6.	Effluent Limitations - Discharge Point No. 001	8
Table 7.	Tasks to Update Long-Term Control Plan (LTCP)	21

Attachments

Attachment A –	Definitions	A-1
Attachment B –	Facility and Receiving Water Maps	B-1
Attachment C –	Process Flow Schematics.....	C-1
Attachment D –	Federal Standard Provisions.....	D-1
Attachment E –	Monitoring and Reporting Program (MRP).....	E-1
Attachment F –	Fact Sheet.....	F-1
Attachment G –	Regional Standard Provisions and Monitoring and Reporting Requirements	G-1
Attachment H –	Pretreatment Requirements	H-1

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

I. FACILITY INFORMATION

Information describing the Oceanside Water Pollution Control Plant, Wastewater Collection System, and Westside Recycled Water Project (collectively, the Facility) is summarized in Table 1 and in Fact Sheet (Attachment F) sections I and II.

II. FINDINGS

The California Regional Water Quality Control Board, San Francisco Bay Region (Regional Water Board), and the U.S. Environmental Protection Agency (U.S. EPA) find:

- A. Legal Authorities.** This Order serves as WDRs pursuant to California Water Code article 4, chapter 4, division 7 (commencing with § 13260). This Order is also issued pursuant to federal Clean Water Act (CWA) section 402 and implementing regulations adopted by U.S. EPA and Water Code chapter 5.5, division 7 (commencing with § 13370). It shall serve as a National Pollutant Discharge Elimination System (NPDES) permit authorizing the Discharger to discharge into waters of the United States as listed in Table 2 subject to the WDRs and NPDES permit requirements in this Order.
- B. Background and Rationale for Requirements.** The Regional Water Board and U.S. EPA developed the requirements in this Order based on information the Discharger submitted as part of its application, information obtained through monitoring and reporting programs, and other available information. The Fact Sheet contains background information and rationale for the requirements in this Order and is hereby incorporated into and constitutes findings for this Order. Attachments A through E, G, and H are also incorporated into this Order.
- C. Notification of Interested Parties.** The Regional Water Board and U.S. EPA notified the Discharger and interested agencies and persons of their intent to jointly issue WDRs and NPDES permit requirements, and provided an opportunity to submit written comments and recommendations. The Fact Sheet provides details regarding the notification.
- D. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard all comments pertaining to the discharge. The Fact Sheet provides details regarding the public hearing. The Regional Water Board and U.S. EPA considered all comments pertaining to the discharge.

THEREFORE, IT IS HEREBY ORDERED that Order No. R2-2009-0062 (previous order) is rescinded upon the effective date of this Order, except for enforcement purposes, and in order to meet the provisions of Water Code division 7 (commencing with § 13000) and regulations adopted thereunder and the provisions of the CWA and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order. The Regional Water Board intends that joint issuance of this Order with U.S. EPA will serve as its certification under CWA section 401 that discharges pursuant to this Order comply with 33 U.S.C. sections 1311, 1312, 1313, 1316, and 1317. This action in no way prevents the Regional Water Board or U.S. EPA from taking enforcement action for past violations of the previous order.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

III. DISCHARGE PROHIBITIONS

- A. Discharge of treated wastewater at a location or in a manner different than described in this Order is prohibited.
- B. Bypass of untreated or partially-treated wastewater to waters of the United States is prohibited, except as provided for in Attachment D section I.G. Combined sewer discharges during wet weather (as defined in Attachment A) authorized by this Order are not subject to this prohibition.

Blended wastewater is biologically-treated wastewater blended with wastewater diverted around biological treatment units at the Oceanside Water Pollution Control Plant. These anticipated discharges are approved under the bypass conditions when (1) the Discharger's instantaneous wet weather influent flow exceeds the capacity of the biological treatment units of 43 MGD, (2) all wet weather flows passing the headworks of the plant receive at least primary treatment, and (3) the discharge complies with the applicable effluent and receiving water limitations contained in this Order. Furthermore, the Discharger shall operate its Facility as designed and in accordance with the Operation and Maintenance Manual for the Facility. This means it shall optimize storage and use of equalization units and shall fully utilize the biological treatment units. The Discharger shall report incidents of blended effluent discharges in monthly self-monitoring reports and shall conduct monitoring of this discharge as specified in the attached Monitoring and Reporting Program (MRP) (Attachment E).

- C. Discharge at Discharge Point No. 001 is prohibited when the discharge does not receive a minimum initial dilution of at least 148:1 (parts seawater per part wastewater), as modeled assuming no currents. Compliance shall be achieved by proper operation and maintenance of the discharge outfall to ensure that it (or its replacement, in whole or part) is in good working order and is consistent with, or can achieve better mixing than, 148:1. The Discharger shall describe measures taken to ensure compliance in its Report of Waste Discharge and application for permit reissuance.
- D. Discharge to a water of the United States from any location other than Discharge Point No. 001 is prohibited, except from Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007 during wet weather (as defined in Attachment A) in accordance with the requirements in this Order.
- E. Average dry weather Oceanside Water Pollution Control Plant influent flow in excess of 43 MGD is prohibited. Average dry weather influent flow shall be determined from three consecutive dry weather months each year, with compliance measured at Monitoring Location INF-001A as described in the MRP.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Technology-Based Effluent Limitations

1. Oceanside Water Pollution Control Plant

During dry weather, the Discharger shall comply with the following effluent limitations for discharges from the Oceanside Water Pollution Control Plant, with compliance measured at Monitoring Location EFF-001A as described in the MRP, as follows:

Table 4. Effluent Limitations - Oceanside Water Pollution Control Plant

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Carbonaceous Biochemical Oxygen Demand, 5-day @ 20°C (CBOD ₅)	mg/L	25	40	---	---	---
Total Suspended Solids (TSS)	mg/L	30	45	---	---	---
CBOD ₅ Removal ^[1]	%	85 (minimum)	---	---	---	---
TSS Removal ^[1]	%	85 (minimum)	---	---	---	---
pH ^[2]	s.u.	---	---	---	6.0	9.0

Abbreviations:

mg/L = milligrams per liter
s.u. = standard units
% = percent

Footnotes:

- ^[1] The arithmetic mean of CBOD₅ and TSS, by concentration, of effluent samples collected at Monitoring Location EFF-001A as described in the MRP shall not exceed 15 percent of the arithmetic mean of the CBOD₅ and TSS, by concentration, of influent samples collected at Monitoring Location INF-001A as described in the MRP, at approximately the same times during the same periods.
- ^[2] If the Discharger monitors pH continuously, pursuant to 40 C.F.R. § 401.17 the Discharger shall be in compliance with this pH limitation provided that both of the following conditions are satisfied: (i) the total time during which the pH is outside the required range shall not exceed 7 hours and 26 minutes in any calendar month; and (ii) no individual excursion from the required pH range shall exceed 60 minutes.

During wet weather, the Discharger shall comply with the narrative technology-based effluent limitations contained in Provision VI.C.5.a (Nine Minimum Controls).

2. Westside Recycled Water Project

When recycled water is being produced, the Discharger shall comply with the following effluent limitations for discharges from the Westside Recycled Water Project, with compliance measured at Monitoring Location EFF-001R as described in the MRP, as follows:

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Table 5. Effluent Limitations - Westside Recycled Water Project

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
TSS	mg/L	60	---	---	---	---
pH ⁽¹⁾	s.u.	---	---	---	6.0	9.0
Oil and Grease	mg/L	25	40	---	---	75
Settleable Solids	mL/L	1.0	1.5	---	---	3.0
Turbidity	NTU	75	100	---	---	225

Abbreviations:

mg/L = milligrams per liter
mL/L = milliliters per liter
NTU = nephelometric turbidity units
s.u. = standard units

Footnote:

- ⁽¹⁾ If the Discharger monitors pH continuously, pursuant to 40 C.F.R. § 401.17 the Discharger shall be in compliance with this pH limitation provided that both of the following conditions are satisfied: (i) the total time during which the pH is outside the required range shall not exceed 7 hours and 26 minutes in any calendar month; and (ii) no individual excursion from the required pH range shall exceed 60 minutes.

B. Water Quality-Based Effluent Limitations

During dry weather, the Discharger shall comply with the following effluent limitation for discharges at Discharge Point No. 001, with compliance measured at Monitoring Location EFF-001C as described in the MRP, as follows:

Table 6. Effluent Limitations - Discharge Point No. 001

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Chronic Toxicity ⁽¹⁾	Pass or Fail	---	---	Pass	---	---

Footnote:

- ⁽¹⁾ MRP section V sets forth chronic toxicity monitoring requirements. The discharge is subject to determination of "Pass" or "Fail" from a single chronic toxicity test conducted at the in-stream waste concentration (IWC) defined in MRP section V.A.2 using the Test of Significant Toxicity (TST) statistical approach (Welch's t-test) in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, 2010), Appendix A, Figure A-1 and Table A-1, and Appendix B, Table B-1.

The TST null hypothesis shall be the following:

$$\text{Mean discharge IWC response} \leq 0.75 \times \text{Mean control response}$$

A test result that rejects this null hypothesis shall be reported as "Pass." A test result that does not reject this null hypothesis shall be reported as "Fail." The relative "Percent Effect" at the discharge IWC shall also be reported as:

$$[(\text{Mean control response} - \text{Mean discharge IWC response}) \div \text{Mean control response}] \times 100$$

During wet weather, the Discharger shall comply with the narrative water quality-based effluent limitations contained in Provision VI.C.5.c (Long-Term Control Plan) for the Discharge Points in Table 2.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

V. RECEIVING WATER LIMITATIONS

Discharge shall not cause or contribute to a violation of any applicable water quality standard (with the exception set forth in State Water Board Order No. WQ 79-16) for receiving waters adopted by the Regional Water Board, State Water Resources Control Board (State Water Board), or U.S. EPA as required by the CWA and regulations adopted thereunder. If more stringent water quality standards are promulgated or approved pursuant to CWA section 303, or amendments thereto, the Regional Water Board and U.S. EPA may revise or modify this Order in accordance with the more stringent standards.

VI. PROVISIONS

A. Standard Provisions

1. The Discharger shall comply with all “Standard Provisions” included in Attachment D. In Attachment D, references to “Regional Water Board” shall be interpreted as “Regional Water Board and U.S. EPA,” and references to “Regional Water Board Executive Officer” shall be interpreted as “Regional Water Board Executive Officer and U.S. EPA.”
2. The Discharger shall comply with all applicable provisions of the “Regional Standard Provisions, and Monitoring and Reporting Requirements” (Attachment G), except as follows:
 - a. **Attachment G section V.C.1.d.iv (Dioxin-TEQ).** The Discharger shall calculate and report dioxin-TEQs using the definition of TCDD Equivalents in Attachment A, which supersedes the definition in Attachment G.
 - b. **Attachment G section III.A.2 (Minimum Levels).** The Discharger shall comply with the minimum levels listed in Ocean Plan Appendix II in lieu of those listed in Attachment G Table B.
 - c. **Attachment G section III.A.3.b.v(b) (Approved Wet Weather Bypasses).** The Discharger shall comply with the monitoring requirements for wet weather secondary bypasses in MRP Table E-5 (Monitoring Location EFF-001B) in lieu of those listed in Attachment G section II.A.3.b.v(b).

In Attachment G, references to “Regional Water Board” shall be interpreted as “Regional Water Board and U.S. EPA,” and references to “Regional Water Board Executive Officer” shall be interpreted as “Regional Water Board Executive Officer and U.S. EPA.”

B. Monitoring and Reporting

The Discharger shall comply with the MRP, and future revisions thereto, and applicable sampling and reporting requirements in Attachments D and G.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

C. Special Provisions

1. Reopener Provisions

The Regional Water Board or U.S. EPA may modify or reopen this Order prior to its expiration date in any of the following circumstances, as allowed by law:

- a. If present or future investigations demonstrate that the discharges governed by this Order have or will have a reasonable potential to cause or contribute to, or will cease to have, adverse impacts on water quality or beneficial uses of the receiving waters.
- b. As new or revised water quality standards or total maximum daily loads (TMDLs) come into effect for surface waters of the State (whether statewide, regional, or site-specific). In such cases, effluent limitations in this Order may be modified as necessary to reflect updated water quality standards and wasteload allocations in TMDLs. Adoption of effluent limitations contained in this Order is not intended to restrict in any way future modifications based on legally adopted water quality objectives, TMDLs, or as otherwise permitted under federal regulations governing NPDES permit modifications.
- c. If translator, dilution, or other water quality studies provide a basis for determining that a permit condition should be modified.
- d. If State Water Board precedential decisions, new policies, new laws, or new regulations are adopted.
- e. If an administrative or judicial decision on a separate NPDES permit or WDRs addresses requirements similar to this discharge.
- f. If combined sewer system discharge controls fail to meet water quality standards or protect designated uses.
- g. Or as otherwise authorized by law.

The Discharger may request a permit modification based on any of the circumstances above. With any such request, the Discharger shall include antidegradation and anti-backsliding analyses.

2. Effluent Characterization Study and Report

- a. **Study Elements.** The Discharger shall characterize and evaluate the dry weather discharge from Discharge Point No. 001 to verify that the reasonable potential analysis conclusions of this Order remain valid and to inform the next permit reissuance. The Discharger shall monitor Ocean Plan Table 1 pollutants as described in the MRP and evaluate on an annual basis whether concentrations of any Ocean Plan Table 1 pollutants significantly increase over past performance. The Discharger shall investigate the cause of any such increases. The investigation may include, but need not be limited to, increasing the monitoring frequency, monitoring internal process streams, and monitoring of influent sources. The Discharger shall establish remedial measures addressing any increases resulting in reasonable potential to cause or contribute to an exceedance of

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

applicable water quality objectives (see Fact Sheet Tables F-9 and F-10 for the objectives). This requirement to establish remedial measures may be satisfied through identification of the constituent as a “pollutant of concern” in the Discharger’s Pollutant Minimization Program, described in Provision VI.C.3.

b. Reporting Requirements

- i. **Routine Reporting.** The Discharger shall, within 45 days of receipt of analytical results, report the identity of any Ocean Plan Table 1 pollutant detected at or above the applicable water quality objective to the Regional Water Board and U.S. EPA.
- ii. **Annual Reporting.** The Discharger shall summarize the annual data evaluation and source investigation in its annual self-monitoring report (see MRP § VIII.B).

3. Pollutant Minimization Program

- a. The Discharger shall continue to improve its Pollutant Minimization Program to promote minimization of pollutant loadings to the sewer system and therefore to the receiving waters.
- b. The Discharger shall submit an annual report no later than February 28 each year. Each annual report shall include at least the following information:
 - i. **Brief description of treatment plant.** The description shall include the service area and treatment plant processes.
 - ii. **Discussion of current pollutants of concern.** Periodically, the Discharger shall analyze its circumstances to determine which pollutants are currently a problem and which pollutants may be potential future problems. This discussion shall include the reasons for choosing the pollutants. At a minimum, the Discharger shall consider copper and zinc as pollutants of concern.
 - iii. **Identification of sources for pollutants of concern.** This discussion shall include how the Discharger intends to estimate and identify pollutant sources. The Discharger shall include sources or potential sources not directly within the ability or authority of the Discharger to control, such as pollutants in the potable water supply and air deposition.
 - iv. **Identification of tasks to reduce the sources of pollutants of concern.** This discussion shall identify and prioritize tasks to address the Discharger’s pollutants of concern. The Discharger may implement the tasks by itself or participate in group, regional, or national tasks that address its pollutants of concern. The Discharger is strongly encouraged to participate in group, regional, or national tasks that address its pollutants of concern whenever it is efficient and appropriate to do so. An implementation timeline shall be included for each task.
 - v. **Outreach to employees.** The Discharger shall inform employees about the pollutants of concern, potential sources, and how they might be able to help reduce the

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

discharge of these pollutants of concern into the Facility. The Discharger may provide a forum for employees to provide input.

- vi. **Continuation of Public Outreach Program.** The Discharger shall continue a pollution prevention public outreach program for its service area. Outreach may include participation in existing community events, such as county fairs; initiating new community events, such as displays and contests during Pollution Prevention Week; conducting school outreach programs; conducting plant tours; and providing public information in newspaper articles or advertisements, radio or television stories or spots, newsletters, utility bill inserts, or web sites. Information shall be specific to target audiences. The Discharger shall coordinate with other agencies as appropriate.
- vii. **Discussion of criteria used to measure Pollutant Minimization Program and task effectiveness.** The Discharger shall establish criteria to evaluate the effectiveness of its Pollutant Minimization Program. This discussion shall identify the specific criteria used to measure the effectiveness of each task in Provisions VI.C.3.b.iii, iv, v, and vi.
- viii. **Documentation of efforts and progress.** This discussion shall detail all of the Discharger's Pollutant Minimization Program activities during the reporting year.
- ix. **Evaluation of Pollutant Minimization Program and task effectiveness.** The Discharger shall use the criteria established in Provision VI.C.3.b.vii to evaluate the program and task effectiveness.
- x. **Identification of specific tasks and timelines for future efforts.** Based on the evaluation, the Discharger shall explain how it intends to continue or change its tasks to more effectively reduce the amount of pollutants flowing to the Facility, and subsequently in its effluent.
- c. The Discharger shall develop and conduct a Pollutant Minimization Program as further described below when there is evidence that a priority pollutant is present in the effluent above an effluent limitation (e.g., sample results reported as detected but not quantified [DNQ] when the effluent limitation is less than the method detection limit [MDL], sample results from analytical methods more sensitive than those methods required by this Order, presence of whole effluent toxicity, health advisories for fish consumption, or results of benthic or aquatic organism tissue sampling) and either:
 - i. A sample result is reported as DNQ and the effluent limitation is less than the Reporting Level (RL); or
 - ii. A sample result is reported as not detected (ND) and the effluent limitation is less than the MDL using definitions in Attachment A and reporting protocols described in the MRP.
- d. If triggered by the reasons set forth in Provision VI.C.3.c, the Discharger's Pollutant Minimization Program shall include, but not be limited to, the following actions and submittals:

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

- i. Annual review and semiannual monitoring of potential sources of the reportable pollutant, which may include fish tissue monitoring and other bio-uptake sampling, or alternative measures when source monitoring is unlikely to produce useful analytical data;
- ii. Quarterly monitoring for the reportable pollutant in treatment plant influent. The Regional Water Board Executive Officer and U.S. EPA may approve alternative measures when influent monitoring is unlikely to produce useful analytical data;
- iii. Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable pollutant in the effluent at or below the effluent limitation;
- iv. Implementation of appropriate cost-effective control measures for the reportable pollutant, consistent with the control strategy; and
- v. Inclusion of the following within the annual report required by Provision VI.C.3.b:
 - (a) All Pollutant Minimization Program monitoring results for the previous year;
 - (b) List of potential sources of the reportable pollutant;
 - (c) Summary of all actions undertaken pursuant to the control strategy; and
 - (d) Description of actions to be taken in the following year.

4. Special Provisions for Publicly-Owned Treatment Works (POTWs)

- a. **Sludge and Biosolids Management.** The Discharger shall manage its sludge and biosolids in accordance with federal regulations (40 C.F.R. parts 258 and 503) and Attachment H.
 - i. Sludge and biosolids treatment and storage shall not create a nuisance, such as objectionable odors or flies, or result in groundwater contamination.
 - ii. Sludge and biosolids treatment and storage facilities shall be adequate to divert surface runoff from adjacent areas, to protect site boundaries from erosion, and to prevent conditions that would cause drainage from stored materials. Adequate protection is defined as protection from at least a 100-year storm and the highest possible tidal state that may occur.
 - iii. This Order does not authorize permanent onsite sludge or biosolids storage or disposal. A Report of Waste Discharge shall be filed and the site brought into compliance with applicable regulations prior to commencement of any such activity.
- b. **Pretreatment Program.** The Discharger shall implement and enforce its approved pretreatment program in accordance with federal pretreatment regulations (40 C.F.R. part 403); pretreatment standards promulgated under CWA sections 307(b), 307(c), and 307(d); pretreatment requirements specified under 40 C.F.R. section 122.44(j); and the requirements in Attachment H, "Pretreatment Requirements." The Discharger's responsibilities include, but are not limited to, the following:

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

- i. Enforcement of the National Pretreatment Standards of 40 C.F.R. sections 403.5 and 403.6;
 - ii. Implementation of its pretreatment program in accordance with legal authorities, policies, procedures, and financial provisions described in the National Pretreatment Program (40 C.F.R. part 403);
 - iii. Submission of reports to the State Water Board, the Regional Water Board, and U.S. EPA as described in Attachment H; and
 - iv. Evaluation of the need to revise local limits as required under 40 C.F.R. sections 122.44(j)(2)(ii) and 403.5(c)(1) and, by November 1, 2020, submission of a report describing the changes to local limits with a plan and schedule for implementation, or the rationale for making no changes to local limits.
- c. **Anaerobically-Digestible Material.** If the Discharger receives hauled-in anaerobically-digestible material for injection into an anaerobic digester, the Discharger shall notify the Regional Water Board and develop and implement Standard Operating Procedures for this activity. The Standard Operating Procedures shall be developed prior to initiation of hauling. The Standard Operating Procedures shall address material handling, including unloading, screening, or other processing prior to anaerobic digestion; transportation; spill prevention; spill response; avoidance of the introduction of materials that could cause interference, pass through, or upset of the treatment processes; avoidance of prohibited material; vector control; odor control; operation and maintenance; and the disposition of any solid waste segregated from introduction to the digester. The Discharger shall train its staff on the Standard Operating Procedures and maintain records for a minimum of three years for each load received, describing the hauler, waste type, and quantity received. In addition, the Discharger shall maintain records for a minimum of three years for the disposition, location, and quantity of cumulative pre-digestion segregated solid waste hauled offsite.
- d. **Separate Sanitary Sewer Systems.** The Discharger shall properly operate and maintain its separate sanitary collection systems (see Attachments D and G, section I.D), report any noncompliance with respect to its separate sanitary collection systems (see Attachments D and G, sections V.E.1 and V.E.2), and mitigate any discharges in violation of this Order associated with its separate sanitary collection systems (see Attachments D and G, section I.C).

State Water Board Order No. 2006-0003-DWQ, Statewide General Waste Discharge Requirements for Sanitary Sewer Systems, as amended by State Water Board Order No. WQ 2013-0058-EXEC (statewide WDRs), contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. The statewide WDRs clearly and specifically stipulate requirements for operation and maintenance and for reporting and mitigating sanitary sewer overflows. Implementing the requirements for operation and maintenance and mitigation of sanitary sewer overflows set forth in the statewide WDRs (and any subsequent order updating those requirements) shall satisfy the corresponding federal NPDES requirements

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

specified in Attachments D and G of this Order for the separate sanitary collection systems. Following the reporting requirements set forth in the statewide WDRs (and any subsequent order updating these requirements) shall satisfy the NPDES reporting requirements for sanitary sewer overflows specified in Attachments D and G.

5. Combined Sewer System

- a. **Nine Minimum Controls.** The Discharger shall implement the following nine minimum controls:
 - i. **Control No. 1: Conduct Proper Operations and Maintenance Program.** The Discharger shall implement an operations and maintenance program that establishes operation, maintenance, and inspection procedures to ensure that the combined sewer system is operated and maintained in a manner that complies with the requirements of this Order. The program shall include the elements listed below:
 - (a) **Organizational Structure.** The Discharger shall maintain an up-to-date directory of operations and maintenance staff, and a designated primary contact person for the Facility. The Discharger shall notify the Regional Water Board and U.S. EPA within 90 days of designating a new primary contact person.
 - (b) **Budget.** The Discharger shall allocate sufficient funds and personnel for routine operations and maintenance, and to provide for possible emergencies.
 - (c) **Critical Facilities and Major System Components.** The Discharger shall maintain a written inventory of critical facilities and major system components (i.e., those facilities and system components that affect the performance of the combined sewer system). The inventory shall include force mains, pump stations, major treatment plant units, transport/storage structures, combined sewer discharge outfalls, Discharge Point No. 001 outfall, tide gates, overflow weirs, and baffles. The Discharger shall include the following information for each critical facility and major system component in the inventory:
 - (1) Physical description (e.g., capacity, dimensions, age) and location;
 - (2) Status (e.g., elements out of service or planned to be taken out of service); and
 - (3) Description of preventative maintenance planned and completed.

At a minimum, the Discharger shall review and update the inventory once every 12 months. The Discharger may combine the inventory and the Wastewater Facilities Status Report (see Attachment G section I.D.2) into one document.
 - (d) **Procedures for Routine Maintenance.** The Discharger shall document procedures for routine maintenance and timely repair of the critical facilities and major system components listed in the inventory required by Provision VI.C.5.a.i(c). Routine maintenance shall focus on preventative maintenance to avoid failures during critical times.
 - (e) **Non-Routine Maintenance and Emergency Situations.** The Discharger shall develop and implement an emergency response plan for each critical facility to

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

minimize the likelihood and adverse impacts of failure to the maximum extent practicable. The emergency response plan shall be consistent with the Contingency Plan required by Attachment G section I.C.1.

- (f) **Inspections.** The Discharger shall conduct an inspection program of the combined sewer system to provide reasonable assurance that unpermitted discharges, obstructions, and damage will be discovered. At a minimum, the Discharger shall do the following:
 - (1) Inspect each critical facility and major system component identified in accordance with Provision VI.C.5.a.i(c), above, at least once every 12 months to ensure they are in good working condition. The inspection shall include, but not be limited to, entering the regulator structure, if accessible; determining the extent of any structural defects or debris and grit buildup; removing any debris that may constrict flow, cause blockage, or result in a prohibited discharge; and adjusting tide gates to minimize combined sewer discharges and to prevent tidal inflow.
 - (2) Record all inspection results, including the date and time of the inspection, the inspection findings, and description of any corrective actions taken.
- (g) **Training.** The Discharger shall provide training to operations and maintenance staff regarding operation and maintenance duties and standard operation procedures. Training shall be consistent with the Discharger's Operation and Maintenance Manual required by Attachment G section I.D.1 (Operation and Maintenance Manual).
- (h) **Operation and Maintenance Program Review.** The Discharger shall review and modify its operations and maintenance program as necessary and in accordance with sections I.C (Duty to Mitigate) and I.D (Proper Operation and Maintenance) of Attachments D and G. At a minimum, the Discharger shall review and update the Operation and Maintenance Manual required by Attachment G section I.D.1 (Operation and Maintenance Manual) once per calendar year.

ii. Control No. 2: Maximize Use of Collection System for Storage

- (a) The Discharger shall maximize use of the combined sewer system for in-line storage to reduce the magnitude, frequency, and duration of combined sewer discharges. At a minimum, the Discharger shall implement the following controls:
 - (1) Prevent intrusion of receiving waters into the combined sewer system;
 - (2) Use all facilities, including any inoperative or unused treatment facilities, to store or treat wet weather flows to the maximum extent practicable; and
 - (3) Implement programs to remove and prevent flow obstructions in the combined sewer system, including but not limited to catch basin cleaning; gravity sewer cleaning; fats, oils and grease control; gravity sewer condition assessment;

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

gravity sewer rehabilitation and replacement; and disconnection of illegal connections.

(b) The Discharger shall notify and report sewer overflows from the combined sewer system by implementing the following within six months of the effective date of this Order:

- (1) The Discharger shall complete the CIWQS Online Collection System Questionnaire, as required by the CIWQS system, and enter information regarding all sewer overflows from the combined sewer system into the CIWQS Online SSO Database, including all required database fields. The Discharger's Legally Responsible Official, as required by the CIWQS system, shall certify all information submitted. The Discharger shall update and certify the Collection System Questionnaire at least every 12 months.
- (2) For sewer overflows from the combined sewer system with volumes 1,000 gallons or greater, the Discharger shall submit draft reports through the CIWQS Online SSO database within 3 business days of becoming aware of the sewer overflow from the combined sewer system and certify the reports within 15 calendar days of the end date of the sewer overflow from the combined sewer system.
- (3) For sewer overflows from the combined sewer system with volumes 50,000 gallons or greater that reach surface waters, the Discharger shall submit a technical report within 45 calendar days of the end date for such overflows that further explains the causes and circumstances, including the method and data used to calculate the volume, and lists response actions completed and planned.
- (4) For sewer overflows from the combined sewer system with volumes less than 1,000 gallons, the Discharger shall submit certified reports to the CIWQS Online SSO database within 30 calendar days of the end of the month during which such overflows occur.
- (5) For each month during which no sewer overflow from the combined sewer system occurs, the Discharger shall certify, within 30 calendar days of the end of the month during which no sewer overflow from the combined sewer system occurred, that no sewer overflow from the combined sewer system occurred.

Following the reporting requirements set forth above shall satisfy the reporting requirements for sewer overflows from the combined sewer system specified in Attachments D and G.

iii. **Control No. 3: Review and Modify Pretreatment Program.** The Discharger shall implement controls to minimize the impact of non-domestic discharges to its collection system. At three-year intervals, the Discharger shall re-evaluate whether additional modifications to its pretreatment program, such as requirements for

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

detention during wet weather, are feasible or practical. The Discharger shall document this re-evaluation in the annual report required by Provision VI.C.4.b and Attachment H.

- iv. **Control No. 4: Maximize Flow to Treatment Plant.** During wet weather, the Discharger shall maximize the volume of wastewater that receives treatment at the Oceanside Water Pollution Control Plant (i.e., secondary treatment for 43 MGD and primary treatment for an additional 22 MGD) and is discharged at Discharge Point No. 001.
- v. **Control No. 5: Prohibit Dry Weather Combined Sewer Overflows.** Dry weather discharges at Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007 are prohibited (see Discharge Prohibition III.D). During any dry weather discharge at Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, or CSD-007, the Discharger shall inspect the associated outfall structure each day until the unauthorized discharge stops. For each prohibited dry weather discharge, the Discharger shall submit the information required by Attachment G section V.C.1.a (e.g., duration, cause, corrective actions taken or planned).
- vi. **Control No. 6: Control Solid and Floatable Materials in Combined Sewer Discharges.** The Discharger shall implement measures to minimize the volume of solid and floatable materials in combined sewer discharges (e.g., equip Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007 with baffles, screens, racks, or other means to reduce the volume of solid and floatable materials). The Discharger shall also remove and properly dispose of solid and floatable materials captured in the combined sewer system.
- vii. **Control No. 7: Develop and Implement Pollution Prevention Program.** The Discharger shall implement a pollution prevention program focused on reducing the amount of pollutants that enter the combined sewer system. The Discharger shall develop and implement this program in accordance with Provision VI.C.3 (Pollutant Minimization Program). As part of this program, the Discharger shall implement a street sweeping program and clean catch basins at a frequency sufficient to minimize large accumulations of pollutants and debris.
- viii. **Control No. 8: Notify Public of Combined Sewer Discharges.** The Discharger shall inform the public of the location of combined sewer discharge outfalls (i.e., Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-005, CSD-006, and CSD-007), the actual occurrences of combined sewer discharges, the possible health and environmental impacts of combined sewer discharges, and the recreational or commercial activities (e.g., swimming, shellfish harvesting) curtailed as a result of combined sewer discharges. Notification shall include the following, at a minimum:
 - (a) The Discharger shall maintain permanent identification signs at the locations of Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-005, CSD-006, and CSD-007, and at public access points. The Discharger shall inspect, and replace as necessary, all permanent signs at least once per calendar year to ensure

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

that the signs are visible and readable. New or replacement signs shall be visible and legible from a distance of 50 feet onshore and offshore, and contain the following information, at a minimum:

- Discharge Point No. (discharge identification number).
- Telephone number to report dry weather discharges.
- Description of discharge, including the words “sewage” and “pathogens that can cause illness.”
- Warning, alert, caution, or other term to notify the public that caution is needed.

(b) The Discharger shall post warning signs, including “No Swimming” signs, at beach locations whenever a combined sewer discharge occurs to inform users that bacteria concentrations may be elevated. The Discharger shall post warning signs within four hours of the time the discharge commences unless the discharge begins after 4:00 p.m., in which case, the Discharger shall post warning signs by 8:00 a.m. the following day. Signs shall remain posted until analysis indicates that water quality meets bacteriological criteria for recreation.

(c) The Discharger shall post warning signs at public access points where shellfish may be harvested for human consumption whenever a combined sewer discharge occurs. The Discharger shall post warning signs within four hours of the time the discharge commences unless the discharge begins after 4:00 p.m., in which case, the Discharger shall post warning signs by 8:00 a.m. the following day. Signs shall be posted until the City and County Health Department indicates that posting is no longer required.

(d) The Discharger shall provide electronic notification of combined sewer discharges through a free-access website and telephone hotline. The electronic notification shall include information about the location and impacts of combined sewer discharges, and provide a telephone number for the public to report discharges.

ix. Control No. 9: Monitor to Characterize Combined Sewer Discharge Impacts and Efficacy of Controls. The Discharger shall monitor to determine the occurrence and apparent impacts of combined sewer discharges, and the efficacy of controls, as described in Provision VI.C.8 and the MRP.

b. Documentation of Nine Minimum Controls. The Discharger shall maintain records documenting implementation of the nine minimum controls described in Provision VI.C.5.a. By February 1 each year, the Discharger shall submit a report to the Regional Water Board and U.S. EPA covering the prior October 1 through September 30. The first such report shall be due February 1, 2021, and cover November 1, 2019, through September 30, 2020. The report shall summarize actions taken and planned to implement the nine minimum controls.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

- c. Long-Term Control Plan (LTCP).** The Discharger shall implement its Long-Term Control Plan (LTCP) and shall comply with the following provisions:
- i.** The Discharger shall optimize system operations to minimize combined sewer discharges and maximize pollutant removal during wet weather.
 - ii.** The Discharger shall use all facilities, including any inoperative or unused facilities, to store or treat wet weather flows to the maximum extent practicable.
 - iii.** The Discharger shall capture for treatment, or storage and subsequent treatment, 100 percent of the combined wastewater and stormwater flow collected in the combined sewer system during precipitation events. Captured flows shall receive the minimum treatment specified in Table 2.
 - iv.** The Discharger shall operate the facilities as set forth below and maintain records documenting implementation. If the Discharger demonstrates that changes to these operating parameters will result in additional storage or treatment, it shall implement such changes after receiving written concurrence from the Regional Water Board Executive Officer and U.S. EPA.
 - (a)** The Oceanside Water Pollution Control Plant shall have an instantaneous influent flow rate of at least 43 MGD prior to discharging primary-treated effluent from the plant to Discharge Point No. 001.
 - (b)** The Oceanside Water Pollution Control Plant shall have an instantaneous influent flow rate of at least 60 MGD prior to initiating discharge from the Westside Transport/Storage Structure to Discharge Point No. 001.
 - (c)** The flow at Discharge Point No. 001 shall be at least 165 MGD within 2 hours of a discharge from Discharge Point No. CSD-002 or CSD-003.
 - (d)** The Discharger shall ensure that two duty pumps at the Sea Cliff No. 1 Pump Station are operating at maximum capacity prior to discharging at Discharge Point No. CSD-005.
 - (e)** The Discharger shall ensure that the Sea Cliff No. 2 Pump Station is operating at maximum capacity and at least 1,100 gallons per minute prior to discharging at Discharge Point Nos. CSD-006 and CSD-007.
 - (f)** The Discharger shall comply with the following after rain and combined sewer discharges subside:
 - (1)** If the National Weather Service predicts at least a 30 percent chance of rain within the next 24 hours, the Discharger shall maximize storage capacity for predicted rain by pumping down the Westside Transport/Storage Structure to dry weather levels (i.e., ten feet or less in the East Box).
 - (2)** If the National Weather Service predicts less than a 30 percent chance of rain within the next 24 hours, the Discharger shall maximize secondary treatment

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

at the Oceanside Water Pollution Control Plant by ceasing the discharge of primary-treated plant effluent and Westside Transport/Storage Structure effluent to Discharge Point No. 001.

- d. **LTCP Update.** The Discharger shall update its LTCP by implementing the following tasks based on the *Combined Sewer Overflow (CSO) Control Policy* and shall submit the required reports to the Regional Water Board and U.S. EPA as specified in the table below. In doing so, the Discharger may use previously completed studies to the extent that they accurately provide the required information.

Table 7. Tasks to Update Long-Term Control Plan (LTCP)

Task	Compliance Date
<p>1. Post-Construction Characterization, Monitoring, and Modeling of Combined Sewer System</p> <p>The Discharger shall submit a System Characterization Report with a comprehensive characterization of the combined sewer system developed through records review, monitoring, modeling, and other means as appropriate to establish the existing conditions upon which the Consideration of Sensitive Areas Report (Task 3) will be based. At a minimum, the System Characterization Report shall include the following:</p> <ul style="list-style-type: none"> a. Thorough description of the entire combined sewer system, including how it responds during a modeled typical year and various precipitation events (including 3-hour duration, 5-year and 10-year return frequency storms). This description will consider the volume and frequency of combined sewer system discharges and sewer overflows from the combined sewer system, and the impacts of climate change and sea level rise; b. Description of each model used, including a discussion of model calibration and validation; c. Location, frequency, and characteristics of actual combined sewer discharges and sewer overflows from the combined sewer system, and their locations relative to sensitive areas, for at least the last 10 years; d. Description of any temporal or spatial trends of sewer overflows from the combined sewer system; e. Based on available information, evaluation of how combined sewer discharges affect receiving water quality. At a minimum, the Discharger shall compare wet weather average and maximum discharge characteristics and receiving water monitoring data with Ocean Plan Table 1 water quality objectives; and f. Evaluation of combined sewer discharge control efficacy (e.g., using TSS as a proxy for pollutant removal efficiency), including a description of any method used. 	<p>Within 48 months of this Order's effective date</p>
<p>2. Public Participation</p> <p>The Discharger shall submit a description of its completed and planned public participation efforts to actively involve the affected public in its decision-making process related to capital planning, including implementation of any additional long-term combined sewer system controls based on the results of the Consideration of Sensitive Areas Report. The affected public includes rate-payers (including rate-payers in separate sanitary sewer system service areas), industrial users, persons who use the receiving waters, and any other interested persons. The public participation efforts may include outreach through methods such as public meetings, direct mailers, billing inserts, press releases, postings of information on the Discharger's website, and development of advisory committees.</p>	<p>Within 48 months of this Order's effective date</p>

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Task	Compliance Date
<p>3. Consideration of Sensitive Areas</p> <p>Based on the findings of the System Characterization Report (Task 1), the Discharger shall submit a Consideration of Sensitive Areas Report that evaluates, prioritizes, and proposes control alternatives needed to eliminate, relocate, or reduce the magnitude or frequency of discharges to sensitive areas from Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-005, CSD-006, and CSD-007. The Consideration of Sensitive Areas Report shall include the following, at a minimum:</p> <ul style="list-style-type: none"> a. Provide updated water contact recreational use surveys, focusing particularly on recreational use following combined sewer discharges; b. Identify control alternatives for each combined sewer discharge structure and the combined sewer system as a whole, including but not limited to the following: <ul style="list-style-type: none"> i. Green infrastructure and low impact development; ii. Increased storage within the combined sewer system and at the Oceanside Water Pollution Control Plant; iii. Increased treatment capacity; iv. Operational changes; v. Increased pumping capacity at the Westside Pump Station; and vi. Use of high-rate treatment technologies and disinfection to minimize pollutant loads. c. Evaluate the practical and technical feasibility of the proposed alternatives; d. Using a model, simulate existing conditions and expected conditions after construction and operation of each proposed alternative, including how the alternative would be expected to affect water quality and combined sewer discharge volumes and frequencies at each combined sewer discharge outfall, and incorporating consideration of climate change and sea level rise; e. Evaluate the feasibility, costs, and benefits of the alternatives. Evaluate financial capabilities (e.g., using U.S. EPA's <i>Combined Sewer Overflows, Guidance for Financial Capability Assessment and Schedule Development</i> [EPA 832-B-97-004, February 1997] or other appropriate guidance); f. Consider costs relative to water quality and other public benefits, financial capabilities, other infrastructure needs, and integrated planning considerations, and prioritize and propose for implementation alternatives to eliminate, relocate, or reduce the magnitude or frequency of discharges from Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-005, CSD-006, and CSD-007 based on Tasks 3.a through 3.e, above; and g. Provide an implementation schedule that includes interim milestones. 	<p>Within 48 months of this Order's effective date</p>
<p>4. Operational Plan</p> <ul style="list-style-type: none"> a. The Discharger shall submit a Wet Weather Operations Report that proposes a set of operational parameters to be used as performance measures to ensure that wet weather operations maximize pollutant removal and minimize the frequency, volume, and duration of combined sewer discharges and sewer overflows from the combined sewer system. The performance measures may include all or a portion of those listed in Provision VI.C.5.c.iv and shall include measures to evaluate compliance. The Discharger shall provide the technical basis for proposing new performance measures or retaining the existing ones. b. Within 90 days of receiving written concurrence from the Regional Water Board Executive Officer and U.S. EPA, the Discharger shall update its Operation and Maintenance Manual, implement the proposed performance measures in lieu of those in Provision VI.C.5.c.iv, and demonstrate compliance. 	<p>Within 24 months of this Order's effective date</p> <p>Within 90 days of receiving written concurrence</p>

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Task	Compliance Date
5. Post-Construction Compliance Monitoring Program The MRP contains post-construction compliance monitoring requirements. The Discharger shall submit a Post-Construction Compliance Monitoring Plan proposing modifications, as appropriate, to the MRP for the next permit term to verify compliance with applicable water quality standards and protection of designated uses, as well as to ascertain the effectiveness of combined sewer system controls. At a minimum, the Post-Construction Compliance Monitoring Plan shall evaluate whether any reduction or increase in monitoring, or alternative monitoring, is appropriate.	With Report of Waste Discharge

6. Westside Recycled Water Project Operations Notification

The Discharger shall notify the Regional Water Board and U.S. EPA at least 30 days prior to commencing Westside Recycled Water Project operations. The notification shall include the following:

- a. Date that operations will commence;
- b. Description of the project as constructed, including a description and flow diagram of all treatment processes;
- c. Description and line diagram of how and where the concentrate from the reverse osmosis process is to be discharged to Discharge Point No. 001;
- d. Description of anticipated changes in the quality of effluent discharged to Discharge Point No. 001; and
- e. Verification that effluent discharged to Discharge Point No. 001 will comply with this Order's requirements.

If pollutant concentrations are expected to increase by more than considered in the reasonable potential analysis based on future effluent quality with the Westside Recycled Water Project (see Fact Sheet § IV.C.4.b), the notification shall also summarize anticipated maximum receiving water concentrations and compare them to the water quality objectives listed in Fact Sheet Tables F-9 and F-10.

7. Flame Retardant Special Study

The Discharger shall propose a special study to evaluate Oceanside Water Pollution Control Plant effluent flame retardant concentrations and flame retardant mass loadings to the Pacific Ocean from Discharge Point No. 001. The Discharger shall submit a special study work plan to the U.S. EPA Water Division Director within one year of the effective date of this Order and shall submit the special study final report with the application for permit reissuance.

8. Efficacy of Combined Sewer System Controls Special Study

By August 1, 2023, the Discharger shall submit a report to the Regional Water Board and U.S. EPA evaluating the quality of the combined sewer discharges and the efficacy of the combined sewer discharge controls during wet weather (i.e., control of solid and floatable

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

material in combined sewer discharges) at Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-005, CSD-006, and CSD-007. At a minimum, the Discharger shall monitor for TSS, copper, lead, and zinc. The Discharger shall also evaluate floatables removal.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

ATTACHMENT A – DEFINITIONS

Areas of Special Biological Significance (ASBS)

Areas designated by the State Water Resources Control Board as ocean areas requiring protection of species or biological communities to the extent that maintenance of natural water quality is assured. All Areas of Special Biological Significance are also classified as a subset of State Water Quality Protection Areas.

Average Monthly Effluent Limitation (AMEL)

Highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL)

Highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Bioaccumulative

Taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Chlordane

Sum of chlordane-alpha, chlordane-gamma, chlordene-alpha, chlordene-gamma, nonachlor-alpha, nonachlor-gamma, and oxychlordane.

Combined Sewer Discharge

Authorized combined sewer overflow during a wet weather day from an approved combined sewer discharge point. Table 2 of the Order lists approved combined sewer discharge points.

Combined Sewer Discharge Event

Discharge from one or more approved combined sewer discharge points during wet weather separated by at least six hours from any other combined sewer discharge event. Table 2 of the Order lists approved combined sewer discharge points.

Combined Sewer Overflow

The *Combined Sewer Overflow (CSO) Control Policy* defines a combined sewer overflow as the discharge from a combined sewer system at a point prior to the POTW's treatment plant.

Daily Discharge

Either: (1) total mass of the constituent discharged over a calendar day (12:00 a.m. through 11:59 p.m.) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit) for a constituent with limitations expressed in units of mass; or (2) unweighted arithmetic mean measurement of the constituent over a day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of a day.

For composite sampling, if a day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

DDT

Sum of 4,4'DDT, 2,4'DDT, 4,4'DDE, 2,4'DDE, 4,4'DDD, and 2,4'DDD.

Degrade

Degradation shall be determined by comparison of the waste field and reference site or sites for characteristic species diversity, population density, contamination, growth anomalies, debility, or supplanting of normal species by undesirable plant and animal species. Degradation occurs if there are significant differences in any of three major biotic groups, namely, demersal fish, benthic invertebrates, or attached algae. Other groups may be evaluated where benthic species are not affected, or are not the only ones affected.

Detected, but Not Quantified (DNQ)

Sample results that are less than the reported Minimum Level, but greater than or equal to the laboratory's method detection limit (MDL). Sample results reported as DNQ are estimated concentrations.

Dichlorobenzenes

Sum of 1,2-dichlorobenzene and 1,3-dichlorobenzene.

Dilution Credit

Amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation based on the allowance of a specified mixing zone. It is calculated from the dilution ratio, or determined by conducting a mixing zone study or modeling the discharge and receiving water.

Downstream Ocean Waters

Waters downstream with respect to ocean currents.

Dredged Material

Any material excavated or dredged from the navigable waters of the United States, including material otherwise referred to as "spoils."

Dry Weather

Any weather not defined as wet weather (determined on a day-by-day basis).

Effective Concentration (EC)

Point estimate of the toxicant concentration that would cause an adverse effect on a quantal, "all or nothing," response (such as death, immobilization, or serious incapacitation) in a given percent of the test organisms. If the effect is death or immobility, the term lethal concentration (LC) may be used. EC values may be calculated using point estimation techniques such as probit, logit, and Spearman-

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Karber. EC_{25} is the concentration of toxicant (in percent effluent) that causes a response in 25 percent of the test organisms.

Enclosed Bays

Indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. This definition includes, but is not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drakes Estero, San Francisco Bay, Morro Bay, Los Angeles Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay.

Endosulfan

Sum of endosulfan-alpha, endosulfan-beta, and endosulfan sulfate.

Estuaries and Coastal Lagoons

Waters at the mouths of streams that serve as mixing zones for fresh and ocean waters during a major portion of the year. Mouths of streams that are temporarily separated from the ocean by sandbars shall be considered as estuaries. Estuarine waters will generally be considered to extend from a bay or the open ocean to the upstream limit of tidal action but may be considered to extend seaward if significant mixing of fresh and salt water occurs in the open coastal waters. The waters described by this definition include, but are not limited to, the Sacramento-San Joaquin Delta as defined by California Water Code section 12220, Suisun Bay, Carquinez Strait downstream to Carquinez Bridge, and appropriate areas of the Smith, Klamath, Mad, Eel, Noyo, and Russian Rivers.

Halomethanes

Sum of bromoform, bromomethane (methyl bromide), and chloromethane (methyl chloride).

HCH

Sum of the alpha, beta, gamma (lindane), and delta isomers of hexachlorocyclohexane.

Initial Dilution

Process that results in the rapid and irreversible turbulent mixing of wastewater with ocean water around the point of discharge.

For a submerged buoyant discharge, characteristic of most municipal and industrial wastes that are released from the submarine outfalls, the momentum of the discharge and its initial buoyancy act together to produce turbulent mixing. Initial dilution in this case is completed when the diluting wastewater ceases to rise in the water column and first begins to spread horizontally.

For shallow water submerged discharges, surface discharges, and non-buoyant discharges, characteristic of cooling water wastes and some individual discharges, turbulent mixing results primarily from the momentum of discharge. Initial dilution, in these cases, is considered to be completed when the momentum induced velocity of the discharge ceases to produce significant mixing of the waste, or the diluting plume reaches a fixed distance from the discharge to be specified by the Regional Water Board, whichever results in the lower estimate for initial dilution.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Instantaneous Maximum Effluent Limitation

Highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation

Lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

In-Stream Waste Concentration (IWC)

The concentration of a toxicant in the receiving water after mixing.

Kelp Beds

For purposes of the Ocean Plan bacteriological standards, significant aggregations of marine algae of the genera *Macrocystis* and *Nereocystis*. Kelp beds include the total foliage canopy of *Macrocystis* and *Nereocystis* plants throughout the water column.

Mariculture

Culture of plants and animals in marine waters independent of any pollution source.

Material

- (a) In common usage: (1) the substance or substances of which a thing is made or composed, (2) substantial;
- (b) For Ocean Plan purposes relating to waste disposal, dredging, and the disposal of dredged material and fill: matter of any kind or description that is subject to regulation as waste or any material dredged from the navigable waters of the United States. See “dredged material.”

Maximum Daily Effluent Limitation (MDEL)

Highest allowable daily discharge of a pollutant.

Method Detection Limit (MDL)

Minimum concentration of a substance that can be reported with 99 percent confidence that the measured concentration is distinguishable from method blank results, as defined in 40 C.F.R. part 136, Appendix B.

Minimum Level (ML)

Concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Natural Light

Reduction of natural light may be determined by measurement of light transmissivity or total irradiance, or both, according to the monitoring needs of the Regional Water Board or U.S. EPA.

No Observed Effect Concentration (NOEC)

Highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specific time of observation. It is determined using hypothesis testing.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Not Detected (ND)

Sample results less than the laboratory's MDL.

PAHs (polynuclear aromatic hydrocarbons)

Sum of acenaphthylene, anthracene, 1,2-benzanthracene, 3,4-benzofluoranthene, benzo[k]fluoranthene, 1,12-benzoperylene, benzo[a]pyrene, chrysene, dibenzo[ah]anthracene, fluorene, indeno[1,2,3-cd]pyrene, phenanthrene, and pyrene.

PCBs (polychlorinated biphenyls)

Sum of chlorinated biphenyls whose analytical characteristics resemble those of Aroclor-1016, Aroclor-1221, Aroclor-1232, Aroclor-1242, Aroclor-1248, Aroclor-1254, and Aroclor-1260.

Pollutant Minimization Program (PMP)

Waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The PMP goal shall be to reduce potential sources through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board and U.S. EPA may consider cost effectiveness when establishing PMP requirements. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), fulfill the PMP requirements.

Reporting Level (RL)

Minimum Level (ML) and its associated analytical method chosen by the Discharger for reporting and compliance determination from the MLs included in this Order, including an additional factor if applicable as discussed herein (also known as the "Reported Minimum Level"). The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected either from Ocean Plan Appendix II in accordance with Ocean Plan chapter III.C.5.a or established in accordance with Ocean Plan chapter III.C.5.b. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Sewer Overflow from the Combined Sewer System

Release or diversion of untreated or partially-treated wastewater or combined wastewater and stormwater from the combined sewer collection system. Sewer overflows from the combined sewer system can occur in public rights of way or on private property. Sewer overflows from the combined sewer system do not include releases due to failures in privately-owned sewer laterals or authorized combined sewer discharges at Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, or CSD-007.

Shellfish

Organisms identified by the California Department of Public Health as shellfish for public health purposes (i.e., mussels, clams and oysters).

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Significant Difference

Statistically significant difference in the means of two distributions of sampling results at the 95 percent confidence level.

Six-Month Median Effluent Limitation

Highest allowable moving median of all daily discharges for any 180-day period.

State Water Quality Protection Areas (SWQPAs)

Non-terrestrial marine or estuarine areas designated to protect marine species or biological communities from an undesirable alteration in natural water quality. All "Areas of Special Biological Significance" (ASBS) previously designated by the State Water Board in Resolutions 74-28, 74-32, and 75-61 are now also classified as a subset of SWQPAs and require the special protections the Ocean Plan affords.

TCDD Equivalents

Sum of the concentrations of chlorinated dibenzodioxins (2,3,7,8-CDDs) and chlorinated dibenzofurans (2,3,7,8-CDFs) multiplied by their respective Toxicity Equivalency Factors (TEFs) and Bioaccumulation Equivalency Factors (BEFs), as defined in Table A-1. When calculating TCDD Equivalents, the Discharger shall set congener concentrations below the minimum levels to zero. This approach is based on 40 C.F.R. part 132, Appendix F, Procedure 4, Tables 1 and 2, and TEFs listed in the Ocean Plan. This TCDD equivalents definition supersedes the dioxin-TEQ definition in Attachment G section V.C.1.d.iv.

Table A-1. Minimum Levels, Toxicity Equivalency Factors, and Bioaccumulation Equivalency Factors

Isomer Group	Minimum Level (pg/L)	Toxicity Equivalency Factor (TEF)	Bioaccumulation Equivalency Factor (BEF)
2,3,7,8-TCDD	10	1.0	1.0
1,2,3,7,8-PeCDD	50	0.5	0.9
1,2,3,4,7,8-HxCDD	50	0.1	0.3
1,2,3,6,7,8-HxCDD	50	0.1	0.1
1,2,3,7,8,9-HxCDD	50	0.1	0.1
1,2,3,4,6,7,8-HpCDD	50	0.01	0.05
OCDD	100	0.001	0.01
2,3,7,8-TCDF	10	0.1	0.8
1,2,3,7,8-PeCDF	50	0.05	0.2
2,3,4,7,8-PeCDF	50	0.5	1.6
1,2,3,4,7,8-HxCDF	50	0.1	0.08
1,2,3,6,7,8-HxCDF	50	0.1	0.2
1,2,3,7,8,9-HxCDF	50	0.1	0.6
2,3,4,6,7,8-HxCDF	50	0.1	0.7
1,2,3,4,6,7,8-HpCDF	50	0.01	0.01
1,2,3,4,7,8,9-HpCDF	50	0.01	0.4
OCDF	100	0.001	0.02

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Test of Significant Toxicity (TST)

A statistical approach used to analyze toxicity test data. The TST statistical approach is described in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, 2010).

Toxicity Reduction Evaluation (TRE)

Study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical or chemicals responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

Waste

As used in the Ocean Plan, a Discharger's total discharge, of whatever origin (i.e., gross, not net, discharge).

Water Recycling

Treatment of wastewater to render it suitable for reuse, the transportation of treated wastewater to the place of use, and the actual use of treated wastewater for a direct beneficial use or controlled use that would not otherwise occur.

Wet Weather

Weather in which any one of the following conditions exists as a result of rain (determined on a day-by-day basis):


1. Instantaneous influent flow to the Oceanside Water Pollution Control Plant exceeds 43 MGD; or
2. Average daily influent concentration of TSS is less than 100 mg/L; or
3. Westside Transport/Storage Structure flow elevation exceeds 0 feet in the West Box or 18 feet in the East Box. (Flow from the East Box to the West Box occurs only when the East Box storage level exceeds 18 feet.)

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

ATTACHMENT B – FACILITY AND RECEIVING WATER MAPS

Figure B-1. Facility Overview Map




The Facility subject to this Order is shown in light red (western area) and includes the Oceanside Water Pollution Control Plant, wastewater collection system, and Westside Recycled Water Project. The Southeast Water Pollution Control Plant, North Point Wet Weather Facility, and Bayside Wet Weather Facilities are shown only for reference in light green (eastern area).


City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Figure B-2. Topographical Map




Scale: 1 inch = 24,000 inches (2,000 feet). Contour interval: 20 feet.
 North American Vertical Datum of 1988.



City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681


Figure B-3. Oceanside Water Pollution Control Plant Map



City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681


Figure B-4. Combined Sewer Discharge and Pump Station Locations



City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681


Figure B-5. Combined Sewer Discharge and Transport/Storage Structure Locations



City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681


Figure B-6. Shoreline Receiving Water Monitoring Locations



City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Figure B-7. Offshore Receiving Water Monitoring Locations




City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

ATTACHMENT C – PROCESS FLOW SCHEMATICS


Figure C-1. Oceanside Water Pollution Control Plant Process Flow



City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Figure C-2. Oceanside Water Pollution Control Plant Wet Weather Operations




Pump/Lift Stations		CSD Number and Name		Transport/Storage Structures		Legend	
Peak Wet-Weather Flows (mgd)				Name	Usable Storage (MG)	CSD	Combined Sewer Discharge
Name						MG	million gallons
Seacliff #1	0.005	CSD-001	Lake Merced	Richmond Transport	12.0	mgd	million gallons per day
Seacliff #2	0.090	CSD-002	Vicente Street	Westside Transport	49.3	T/S	Transport/Storage Structure
Westside	175.000	CSD-003	Lincoln Way	Lake Merced Transport	10.0	→	Force Main
		CSD-004	Mile Rock			→	Gravity Flow Lines
		CSD-005	Seacliff #1 PS			# ←	Combined Sewer Discharge
		CSD-006	Seacliff			PS	Pump Station
		CSD-007	Seacliff #2 PS				

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Figure C-3. Oceanside Water Pollution Control Plant and Planned Westside Recycled Water Project Monitoring Locations
 (see Monitoring and Reporting Program [MRP] Table E-1 in Attachment E of this Order for monitoring location descriptions)



City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

ATTACHMENT D – STANDARD PROVISIONS

I. STANDARD PROVISIONS—PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the terms, requirements, and conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application; or a combination thereof. (40 C.F.R. § 122.41(a); Wat. Code §§ 13261, 13263, 13265, 13268, 13000, 13001, 13304, 13350, 13385.)
2. The Discharger shall comply with effluent standards or prohibitions established under CWA section 307(a) for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 C.F.R. § 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 C.F.R. § 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 C.F.R. § 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 C.F.R. § 122.41(e).)

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 C.F.R. § 122.41(g).)

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 C.F.R. § 122.5(c).)

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, U.S. EPA, or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (33 U.S.C. § 1318(a)(4)(B); 40 C.F.R. § 122.41(i); Wat. Code, §§ 13267, 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (33 U.S.C. § 1318(a)(4)(B)(i); 40 C.F.R. § 122.41(i)(1); Wat. Code, §§ 13267, 13383);
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (33 U.S.C. § 1318(a)(4)(B)(ii); 40 C.F.R. § 122.41(i)(2); Wat. Code, §§ 13267, 13383);
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (33 U.S.C. § 1318(a)(4)(B)(ii); 40 C.F.R. § 122.41(i)(3); Wat. Code, §§ 13267, 13383); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (33 U.S.C. § 1318(a)(4)(B); 40 C.F.R. § 122.41(i)(4); Wat. Code, §§ 13267, 13383.)

G. Bypass

1. Definitions

- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 C.F.R. § 122.41(m)(1)(i).)
- b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 C.F.R. § 122.41(m)(1)(ii).)

2. **Bypass not exceeding limitations.** The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions—Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 C.F.R. § 122.41(m)(2).)

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

3. **Prohibition of bypass.** Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 C.F.R. § 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 C.F.R. § 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 C.F.R. § 122.41(m)(4)(i)(B)); and
 - c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions—Permit Compliance I.G.5 below. (40 C.F.R. § 122.41(m)(4)(i)(C).)
4. **Approval.** The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions—Permit Compliance I.G.3 above. (40 C.F.R. § 122.41(m)(4)(ii).)

5. Notice

- a. **Anticipated bypass.** If the Discharger knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 10 days before the date of the bypass. The notice shall be sent to the Regional Water Board. As of December 21, 2020, a notice shall also be submitted electronically to the initial recipient defined in Standard Provisions—Reporting V.J below. Notices shall comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. (40 C.F.R. § 122.41(m)(3)(i).)
- b. **Unanticipated bypass.** The Discharger shall submit a notice of an unanticipated bypass as required in Standard Provisions—Reporting V.E below (24-hour notice). The notice shall be sent to the Regional Water Board. As of December 21, 2020, a notice shall also be submitted electronically to the initial recipient defined in Standard Provisions—Reporting V.J below. Notices shall comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. (40 C.F.R. § 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 C.F.R. § 122.41(n)(1).)

1. **Effect of an upset.** An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of Standard Provisions—Permit Compliance I.H.2 below are met. No determination made

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 C.F.R. § 122.41(n)(2).)

2. **Conditions necessary for a demonstration of upset.** A discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 C.F.R. § 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 C.F.R. § 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 C.F.R. § 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions—Reporting V.E.2.b below (24-hour notice) (40 C.F.R. § 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions—Permit Compliance I.C above. (40 C.F.R. § 122.41(n)(3)(iv).)
3. **Burden of proof.** In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 C.F.R. § 122.41(n)(4).)

II. STANDARD PROVISIONS—PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 C.F.R. § 122.41(f).)

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 C.F.R. § 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code. (40 C.F.R. §§ 122.41(l)(3), 122.61.)

III. STANDARD PROVISIONS—MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 C.F.R. § 122.41(j)(1).)

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

B. Monitoring must be conducted according to test procedures approved under 40 C.F.R. part 136 for the analyses of pollutants unless another method is required under 40 C.F.R. chapter 1, subchapter N. Monitoring must be conducted according to sufficiently sensitive test methods approved under 40 C.F.R. part 136 for the analysis of pollutants or pollutant parameters or required under 40 C.F.R. chapter 1, subchapter N. For the purposes of this paragraph, a method is sufficiently sensitive when:

1. The method minimum level (ML) is at or below the level of the effluent limitation established in the permit for the measured pollutant or pollutant parameter, and either (a) the method ML is at or below the level of the applicable water quality criterion for the measured pollutant or pollutant parameter, or (b) the method ML is above the applicable water quality criterion but the amount of the pollutant or pollutant parameter in a facility's discharge is high enough that the method detects and quantifies the level of the pollutant or pollutant parameter in the discharge; or
2. The method has the lowest ML of the analytical methods approved under 40 C.F.R. part 136 or required under 40 C.F.R. chapter 1, subchapter N, for the measured pollutant or pollutant parameter.

In the case of pollutants or pollutant parameters for which there are no approved methods under 40 C.F.R. part 136 or otherwise required under 40 C.F.R. chapter 1, subchapter N, monitoring must be conducted according to a test procedure specified in this Order for such pollutants or pollutant parameters. (40 C.F.R. §§ 122.21(e)(3), 122.41(j)(4), 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS—RECORDS

- A.** The Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 C.F.R. § 122.41(j)(2).)
- B.** Records of monitoring information shall include the following:
1. The date, exact place, and time of sampling or measurements (40 C.F.R. § 122.41(j)(3)(i));
 2. The individual(s) who performed the sampling or measurements (40 C.F.R. § 122.41(j)(3)(ii));
 3. The date(s) the analyses were performed (40 C.F.R. § 122.41(j)(3)(iii));
 4. The individual(s) who performed the analyses (40 C.F.R. § 122.41(j)(3)(iv));
 5. The analytical techniques or methods used (40 C.F.R. § 122.41(j)(3)(v)); and
 6. The results of such analyses. (40 C.F.R. § 122.41(j)(3)(vi).)

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

C. Claims of confidentiality for the following information will be denied (40 C.F.R. § 122.7(b)):

1. The name and address of any permit applicant or Discharger (40 C.F.R. § 122.7(b)(1)); and
2. Permit applications and attachments, permits, and effluent data. (40 C.F.R. § 122.7(b)(2).)

V. STANDARD PROVISIONS—REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or U.S. EPA within a reasonable time, any information which the Regional Water Board, State Water Board, or U.S. EPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or U.S. EPA copies of records required to be kept by this Order. (40 C.F.R. § 122.41(h); Wat. Code, §§ 13267, 13383.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or U.S. EPA shall be signed and certified in accordance with Standard Provisions—Reporting V.B.2, V.B.3, V.B.4, V.B.5, and V.B.6 below. (40 C.F.R. § 122.41(k).)
2. For a corporation, all permit applications shall be signed by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures. (40 C.F.R. § 122.22(a)(1).)

For a partnership or sole proprietorship, all permit applications shall be signed by a general partner or the proprietor, respectively. (40 C.F.R. § 122.22(a)(2).)

For a municipality, State, federal, or other public agency, all permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of U.S. EPA). (40 C.F.R. § 122.22(a)(3).)

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or U.S. EPA shall be signed by a person described in Standard Provisions—Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions—Reporting V.B.2 above (40 C.F.R. § 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 C.F.R. § 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 C.F.R. § 122.22(b)(3).)
4. If an authorization under Standard Provisions—Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions—Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 C.F.R. § 122.22(c).)
5. Any person signing a document under Standard Provisions—Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 C.F.R. § 122.22(d).)
6. Any person providing the electronic signature for documents described in Standard Provisions—V.B.1, V.B.2, or V.B.3 that are submitted electronically shall meet all relevant requirements of Standard Provisions—Reporting V.B, and shall ensure that all relevant requirements of 40 C.F.R. part 3 (Cross-Media Electronic Reporting) and 40 C.F.R. part 127 (NPDES Electronic Reporting Requirements) are met for that submission. (40 C.F.R. § 122.22(e).)

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program in this Order. (40 C.F.R. § 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board. As of December 21, 2016, all reports and forms must be submitted electronically to the initial recipient defined in Standard Provisions—Reporting V.J and comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. (40 C.F.R. § 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under 40 C.F.R. part 136, or another method required for an industry-specific waste stream under 40 C.F.R. chapter 1, subchapter N, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR reporting form specified by the Regional Water Board or State Water Board. (40 C.F.R. § 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 C.F.R. § 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 C.F.R. § 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written report shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

For noncompliance related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports must include the data described above (with the exception of time of discovery) as well as the type of event (i.e., combined sewer overflow, sanitary sewer overflow, or bypass event), type of overflow structure (e.g., manhole, combined sewer overflow outfall), discharge volume untreated by the treatment works treating domestic sewage, types of human health and environmental impacts of the event, and whether the noncompliance was related to wet weather.

As of December 21, 2020, all reports related to combined sewer overflows, sanitary sewer overflows, or bypass events must be submitted to the Regional Water Board and must be

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

submitted electronically to the initial recipient defined in Standard Provisions—Reporting V.J. The reports shall comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. The Regional Water Board may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section. (40 C.F.R. § 122.41(l)(6)(i).)

2. The following shall be included as information that must be reported within 24 hours:
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 C.F.R. § 122.41(l)(6)(iii).)

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 C.F.R. § 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 C.F.R. section 122.29(b) (40 C.F.R. § 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (Alternatively, for an existing manufacturing, commercial, mining, or silvicultural discharge as referenced in 40 C.F.R. section 122.42(a), this notification applies to pollutants that are subject neither to effluent limitations in this Order nor to notification requirements under 40 C.F.R. section 122.42(a)(1) (see Additional Provisions—Notification Levels VII.A.1).) (40 C.F.R. § 122.41(l)(1)(ii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with this Order's requirements. (40 C.F.R. § 122.41(l)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions—Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provisions—Reporting V.E above. For noncompliance related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports shall contain the information described in Standard Provisions—

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Reporting V.E and the applicable required data in appendix A to 40 C.F.R. part 127. The Regional Water Board may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section. (40 C.F.R. § 122.41(l)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or U.S. EPA, the Discharger shall promptly submit such facts or information. (40 C.F.R. § 122.41(l)(8).)

J. Initial Recipient for Electronic Reporting Data

The owner, operator, or duly authorized representative is required to electronically submit NPDES information specified in appendix A to 40 C.F.R. part 127 to the initial recipient defined in 40 C.F.R. section 127.2(b). U.S. EPA will identify and publish the list of initial recipients on its website and in the Federal Register, by state and by NPDES data group (see 40 C.F.R. § 127.2(c)). U.S. EPA will update and maintain this list. (40 C.F.R. § 122.41(l)(9).)

VI. STANDARD PROVISIONS—ENFORCEMENT

- A.** The Regional Water Board is authorized to enforce the terms of this Order under several provisions of the Water Code, including, but not limited to, sections 13268, 13350, 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS—NOTIFICATION LEVELS

A. Non-Municipal Facilities

Existing manufacturing, commercial, mining, and silvicultural dischargers shall notify the Regional Water Board as soon as they know or have reason to believe (40 C.F.R. § 122.42(a)):

- 1.** That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following “notification levels” (40 C.F.R. § 122.42(a)(1)):
 - a.** 100 micrograms per liter (µg/L) (40 C.F.R. § 122.42(a)(1)(i));
 - b.** 200 µg/L for acrolein and acrylonitrile; 500 µg/L for 2,4-dinitrophenol and 2-methyl-4,6-dinitrophenol; and 1 milligram per liter (mg/L) for antimony (40 C.F.R. § 122.42(a)(1)(ii));
 - c.** Five (5) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge (40 C.F.R. § 122.42(a)(1)(iii)); or
 - d.** The level established by the Regional Water Board in accordance with section 40 C.F.R. section 122.44(f). (40 C.F.R. § 122.42(a)(1)(iv).)

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

2. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following “notification levels” (40 C.F.R. § 122.42(a)(2)):
 - a. 500 micrograms per liter ($\mu\text{g/L}$) (40 C.F.R. § 122.42(a)(2)(i));
 - b. 1 milligram per liter (mg/L) for antimony (40 C.F.R. § 122.42(a)(2)(ii));
 - c. Ten (10) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge (40 C.F.R. § 122.42(a)(2)(iii)); or
 - d. The level established by the Regional Water Board in accordance with 40 C.F.R. section 122.44(f). (40 C.F.R. § 122.42(a)(2)(iv).)

B. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 C.F.R. § 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to CWA sections 301 or 306 if it were directly discharging those pollutants (40 C.F.R. § 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of this Order. (40 C.F.R. § 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 C.F.R. § 122.42(b)(3).)

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Contents

I.	General Monitoring Provisions.....	E-2
II.	Monitoring Locations.....	E-2
III.	Influent Monitoring Requirements	E-6
IV.	Effluent Monitoring Requirements	E-6
	A. Oceanside Water Pollution Control Plant	E-6
	B. Combined Sewer System	E-8
	C. Westside Recycled Water Project	E-10
	D. Discharge Point No. 001	E-11
V.	Chronic Toxicity Monitoring Requirements.....	E-12
VI.	Receiving Water Monitoring Requirements	E-15
	A. Shoreline Monitoring	E-15
	B. Offshore Monitoring	E-17
VII.	Pretreatment and Biosolids Monitoring Requirements.....	E-18
VIII.	Recycled Water Monitoring Requirements	E-19
IX.	Reporting Requirements	E-21
	A. General Monitoring and Reporting Requirements	E-21
	B. Self-Monitoring Reports (SMRs).....	E-21
	C. Discharge Monitoring Reports (DMRs).....	E-24
	D. Annual Recycled Water Reports	E-24

Tables

Table E-1.	Monitoring Locations.....	E-2
Table E-2.	Plant Influent Monitoring.....	E-6
Table E-3.	Plant Effluent Monitoring	E-7
Table E-4.	Dry Weather Plant Effluent Monitoring	E-7
Table E-5.	Wet Weather Plant Effluent Monitoring	E-8
Table E-6.	Westside Transport/Storage Structure Effluent Monitoring	E-8
Table E-7.	Combined Sewer Discharge Monitoring.....	E-9
Table E-8.	Westside Recycled Water Project Concentrate Monitoring.....	E-10
Table E-9.	Dry Weather Discharge Point No. 001 Monitoring	E-11
Table E-10.	Critical Life Stage Toxicity Tests	E-15
Table E-11.	Ambient Shoreline Monitoring	E-16
Table E-12.	Post-CSD Event Shoreline Monitoring	E-16
Table E-13.	Pretreatment and Biosolids Monitoring	E-18
Table E-14.	CIWQS Reporting.....	E-21
Table E-15.	Monitoring Periods	E-22

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

Clean Water Act section 308 and 40 C.F.R. sections 122.41(h), 122.41(j)-(l), 122.44(i), and 122.48 require that all NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. This MRP establishes monitoring, reporting, and recordkeeping requirements that implement federal and State laws and regulations.

I. GENERAL MONITORING PROVISIONS

- A. The Discharger shall comply with this MRP. The Regional Water Board Executive Officer and U.S. EPA may amend this MRP pursuant to 40 C.F.R. sections 122.62, 122.63, and 124.5. If any discrepancies exist between this MRP and the “Regional Standard Provisions, and Monitoring and Reporting Requirements (Supplement to Attachment D) for NPDES Wastewater Discharge Permits” (Attachment G), this MRP shall prevail.
- B. The Discharger shall conduct all monitoring in accordance with Attachment D section III, as supplemented by Attachment G. Equivalent test methods must be more sensitive than those specified in 40 C.F.R. part 136 and must be specified in this permit.
- C. The Discharger shall ensure that results of the Discharge Monitoring Report-Quality Assurance (DMR-QA) Study or most recent Water Pollution Performance Evaluation Study are submitted annually to the State Water Board at the following address or as otherwise directed:

State Water Resources Control Board
Quality Assurance Program Officer
Office of Information Management and Analysis
1001 I Street, Sacramento, CA 95814
- D. The Discharger shall implement a Quality Assurance-Quality Control Program for any onsite field tests (e.g., turbidity, pH, temperature, dissolved oxygen, conductivity, disinfectant residual) analyzed by a noncertified laboratory. The Discharger shall keep a manual onsite containing the steps followed in this program and must demonstrate sufficient capability to adequately perform these field tests (e.g., qualified and trained employees, properly calibrated and maintained field instruments). The program shall conform to U.S. EPA guidelines or other approved procedures.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-1. Monitoring Locations

Monitoring Location Type	Monitoring Location Name	Monitoring Location Description ^[1]
Oceanside Water Pollution Control Plant Influent (dry weather)	INF-001A	During dry weather, any point in the plant headworks where all waste tributary to the plant is present and preceding any phase of treatment at the plant, exclusive of any return flows or process side streams.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Monitoring Location Type	Monitoring Location Name	Monitoring Location Description ^[1]
Oceanside Water Pollution Control Plant Influent (wet weather)	INF-001B	During wet weather, any point in the plant headworks where all waste tributary to the plant is present and preceding any phase of treatment at the plant, exclusive of any return flows or process side streams.
Oceanside Water Pollution Control Plant Effluent (dry weather)	EFF-001A	During dry weather, any point at the plant following all phases of treatment, prior to contact with Westside Recycled Water Project concentrate and the receiving water at Discharge Point No. 001.
Oceanside Water Pollution Control Plant Effluent (wet weather)	EFF-001B	During wet weather, any point at the plant following all phases of treatment, prior to contact with Westside Transport/Storage Structure effluent, Westside Recycled Water Project concentrate, and the receiving water at Discharge Point No. 001.
Oceanside Water Pollution Control Plant Effluent and Westside Recycled Water Project Concentrate (dry weather)	EFF-001C	During dry weather, any point at which all plant effluent and Westside Recycled Water Project concentrate tributary to Discharge Point No. 001 is present and after all phases of treatment. The Discharger may combine 24-hour composite samples from Monitoring Locations EFF-001A and EFF-001R to create a volumetrically flow-weighted representative sample for Monitoring Location EFF-001C.
Westside Transport/Storage Structure Effluent (wet weather) (identified in the previous order as "decant")	EFF-001D	During wet weather, any point following the Westside Pump Station wet weather pumps, prior to contact with treated plant effluent, Westside Recycled Water Project concentrate, and the receiving water at Discharge Point No. 001.
Westside Recycled Water Project Reverse Osmosis Concentrate	EFF-001R	Any point at the Westside Recycled Water Project following all phases of treatment, prior to contact with plant effluent, Westside Transport/Storage Structure effluent, and the receiving water at Discharge Point No. 001.
Combined Sewer Discharge Effluent	EFF-CSD	A monitoring location representative of combined sewer discharges from the Westside Transport/Storage Structure.
Shoreline Receiving Water	SRF-15	Nearshore receiving water along Baker Beach, in the surf at the terminus of Lobos Creek.
Shoreline Receiving Water	SRF-15 east	Nearshore receiving water along Baker Beach, in the surf east of Monitoring Location SRF-15.
Shoreline Receiving Water	SRF-16	Nearshore receiving water along Baker Beach, in the surf opposite the Sea Cliff No. 2 Pump Station.
Shoreline Receiving Water	SRF-17	Nearshore receiving water along China Beach, in the surf opposite the Sea Cliff No. 1 Pump Station.
Shoreline Receiving Water	SRF-18	Nearshore receiving water along Ocean Beach, in the surf at the foot of Balboa Street.
Shoreline Receiving Water	SRF-19	Nearshore receiving water along Ocean Beach, in the surf at the foot of Lincoln Way, opposite the Lincoln Combined Sewer Discharge Structure.
Shoreline Receiving Water	SRF-20	Nearshore receiving water along Ocean Beach, in the surf at the foot of Pacheco Street.
Shoreline Receiving Water	SRF-21	Nearshore receiving water along Ocean Beach, in the surf at the foot of Vicente Street, opposite the Vicente Combined Sewer Discharge Structure.
Shoreline Receiving Water	SRF-21.1	Nearshore receiving water along Ocean Beach, in the surf at the foot of Sloat Boulevard.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Monitoring Location Type	Monitoring Location Name	Monitoring Location Description ⁽¹⁾
Shoreline Receiving Water	SRF-22	Nearshore receiving water along Ocean Beach, in the surf at Fort Funston, opposite the Lake Merced Combined Sewer Discharge Structure.
Offshore Receiving Water	Station 1	Offshore monitoring program station location. <i>Longitude -122.57533°, Latitude 37.70333°</i>
Offshore Receiving Water	Station 2	Offshore monitoring program station location. <i>Longitude -122.57500°, Latitude 37.71050°</i>
Offshore Receiving Water	Station 4	Offshore monitoring program station location. <i>Longitude -122.59500°, Latitude 37.71167°</i>
Offshore Receiving Water	Station 6	Offshore monitoring program station location. <i>Longitude -122.53750°, Latitude 37.66667°</i>
Offshore Receiving Water	Station 25	Offshore monitoring program station location. <i>Longitude -122.57500°, Latitude 37.70383°</i>
Offshore Receiving Water	Station 28	Offshore monitoring program station location. <i>Longitude -122.57467°, Latitude 37.69833°</i>
Offshore Receiving Water	Station 31	Offshore monitoring program station location. <i>Longitude -122.56717°, Latitude 37.72467°</i>
Offshore Receiving Water	Station 32 (formerly R1)	Offshore monitoring program station location. <i>Longitude -122.64128°, Latitude 37.86799°</i>
Offshore Receiving Water	Station 33 (formerly R2)	Offshore monitoring program station location. <i>Longitude -122.60024°, Latitude 37.85171°</i>
Offshore Receiving Water	Station 34 (formerly R3)	Offshore monitoring program station location. <i>Longitude -122.64744°, Latitude 37.85129°</i>
Offshore Receiving Water	Station 35 (formerly R4)	Offshore monitoring program station location. <i>Longitude -122.67920°, Latitude 37.84832°</i>
Offshore Receiving Water	Station 36 (formerly R5)	Offshore monitoring program station location. <i>Longitude -122.62008°, Latitude 37.83773°</i>
Offshore Receiving Water	Station 37 (formerly R6)	Offshore monitoring program station location. <i>Longitude -122.59485°, Latitude 37.83656°</i>
Offshore Receiving Water	Station 38 (formerly R7)	Offshore monitoring program station location. <i>Longitude -122.65501°, Latitude 37.82802°</i>
Offshore Receiving Water	Station 39 (formerly R8)	Offshore monitoring program station location. <i>Longitude -122.69042°, Latitude 37.82200°</i>
Offshore Receiving Water	Station 40 (formerly R9)	Offshore monitoring program station location. <i>Longitude -122.62493°, Latitude 37.80880°</i>
Offshore Receiving Water	Station 43 (formerly R12)	Offshore monitoring program station location. <i>Longitude -122.61608°, Latitude 37.78552°</i>
Offshore Receiving Water	Station 45 (formerly R14)	Offshore monitoring program station location. <i>Longitude -122.64399°, Latitude 37.77483°</i>
Offshore Receiving Water	Station 47 (formerly R16)	Offshore monitoring program station location. <i>Longitude -122.61792°, Latitude 37.76106°</i>
Offshore Receiving Water	Station 48 (formerly R17)	Offshore monitoring program station location. <i>Longitude -122.64888°, Latitude 37.75941°</i>
Offshore Receiving Water	Station 50 (formerly R19)	Offshore monitoring program station location. <i>Longitude -122.66556°, Latitude 37.75000°</i>

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Monitoring Location Type	Monitoring Location Name	Monitoring Location Description ^[1]
Offshore Receiving Water	Station 51 (formerly R20)	Offshore monitoring program station location. Longitude -122.59875°, Latitude 37.74622°
Offshore Receiving Water	Station 52 (formerly R21)	Offshore monitoring program station location. Longitude -122.51989°, Latitude 37.72863°
Offshore Receiving Water	Station 53 (formerly R22)	Offshore monitoring program station location. Longitude -122.64514°, Latitude 37.71787°
Offshore Receiving Water	Station 54 (formerly R23)	Offshore monitoring program station location. Longitude -122.54650°, Latitude 37.71651°
Offshore Receiving Water	Station 55 (formerly R24)	Offshore monitoring program station location. Longitude -122.57086°, Latitude 37.71569°
Offshore Receiving Water	Station 56 (formerly R25)	Offshore monitoring program station location. Longitude -122.60786°, Latitude 37.71146°
Offshore Receiving Water	Station 57 (formerly R26)	Offshore monitoring program station location. Longitude -122.51912°, Latitude 37.70940°
Offshore Receiving Water	Station 58 (formerly R27)	Offshore monitoring program station location. Longitude -122.58201°, Latitude 37.70430°
Offshore Receiving Water	Station 59 (formerly R28)	Offshore monitoring program station location. Longitude -122.53662°, Latitude 37.69324°
Offshore Receiving Water	Station 60 (formerly R29)	Offshore monitoring program station location. Longitude -122.60180°, Latitude 37.68914°
Offshore Receiving Water	Station 61 (formerly R30)	Offshore monitoring program station location. Longitude -122.55807°, Latitude 37.68204°
Offshore Receiving Water	Station 62 (formerly R31)	Offshore monitoring program station location. Longitude -122.62865°, Latitude 37.68227°
Offshore Receiving Water	Station 63 (formerly R32)	Offshore monitoring program station location. Longitude -122.56150°, Latitude 37.65879°
Offshore Receiving Water	Station 64 (formerly R33)	Offshore monitoring program station location. Longitude -122.53465°, Latitude 37.65406°
Offshore Receiving Water	Station 65 (formerly R34)	Offshore monitoring program station location. Longitude -122.54111°, Latitude 37.63414°
Offshore Receiving Water	Station 66 (formerly R35)	Offshore monitoring program station location. Longitude -122.61113°, Latitude 37.62840°
Offshore Receiving Water	Station 67 (formerly R36)	Offshore monitoring program station location. Longitude -122.56486°, Latitude 37.62633°
Offshore Receiving Water	Station 68 (formerly R37)	Offshore monitoring program station location. Longitude -122.61549°, Latitude 37.61694°
Offshore Receiving Water	Station 69 (formerly R38)	Offshore monitoring program station location. Longitude -122.59134°, Latitude 37.61449°
Offshore Receiving Water	Station 70 (formerly R39)	Offshore monitoring program station location. Longitude -122.53371°, Latitude 37.60893°
Offshore Receiving Water	Station 71 (formerly R40)	Offshore monitoring program station location. Longitude -122.55084°, Latitude 37.60465°
Offshore Receiving Water	Station 72 (formerly R41)	Offshore monitoring program station location. Longitude -122.65550°, Latitude 37.80367°
Offshore Receiving Water	Station 80 (formerly R49)	Offshore monitoring program station location. Longitude -122.51500°, Latitude 37.71500°

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Monitoring Location Type	Monitoring Location Name	Monitoring Location Description ^[1]
Biosolids	BIO-001	Biosolids (treated sludge)

Footnote:

^[1] Latitude and longitude information is approximate.

III. INFLUENT MONITORING REQUIREMENTS

The Discharger shall monitor Oceanside Water Pollution Control Plant influent at Monitoring Location INF-001A during dry weather and Monitoring Location INF-001B during wet weather as follows:

Table E-2. Plant Influent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency ^[2]
Flow ^[1]	MG/MGD	Continuous	Continuous/D
Carbonaceous Biochemical Oxygen Demand (5-day @ 20°C)(CBOD ₅) ^[3]	mg/L	C-24	1/Week
Total Suspended Solids (TSS)	mg/L	C-24	5/Week

Abbreviations:

MG = million gallons
MGD = million gallons per day
mg/L = milligrams per liter

Sample Types and Frequencies:

Continuous = measured continuously
Continuous/D = measured continuously, and recorded and reported daily
C-24 = 24-hour composite
1/Week = once per week
5/Week = five times per week

Footnotes:

^[1] The following information shall be reported in monthly self-monitoring reports:

- Daily average flow (MGD)
- Total monthly flow volume (MG)

^[2] The minimum sampling frequency is the total number of influent samples to be collected during the specified sampling period, including samples collected during dry and wet weather at Monitoring Locations INF-001A and INF-001B.

^[3] The Discharger may monitor Chemical Oxygen Demand at Monitoring Location INF-001B in lieu of CBOD₅ during wet weather.

IV. EFFLUENT MONITORING REQUIREMENTS

A. Oceanside Water Pollution Control Plant

- 1. Dry and Wet Weather.** The Discharger shall monitor plant effluent at Monitoring Location EFF-001A during dry weather and at Monitoring Location EFF-001B during wet weather as follows:

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Table E-3. Plant Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency ^[3]
Flow ^[1]	MG/MGD	Continuous	Continuous/D
CBOD ₅ ^[2]	mg/L	C-24	1/Week
TSS	mg/L	C-24	5/Week
pH	standard units	Continuous or Grab	1/Week

Abbreviations:

MG = million gallons
MGD = million gallons per day
mg/L = milligrams per liter

Sample Types and Frequencies:

Continuous = measured continuously
Continuous/D = measured continuously, and recorded and reported daily
C-24 = 24-hour composite
Grab = grab sample
1/Week = once per week
5/Week = five times per week

Footnotes:

^[1] The following information shall be reported in monthly self-monitoring reports:

- Daily average flow (MGD)
- Total monthly flow volume (MG)

^[2] The Discharger may monitor Chemical Oxygen Demand at Monitoring Location EFF-001B in lieu of CBOD₅ during wet weather.

^[3] The minimum sampling frequency is the total number of effluent samples to be collected during the specified sampling period, including samples collected during dry and wet weather at Monitoring Locations EFF-001A and EFF-001B.

2. **Dry Weather.** During dry weather, the Discharger shall monitor plant effluent at Monitoring Location EFF-001A as follows:

Table E-4. Dry Weather Plant Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency
Oil and Grease	mg/L	Grab	1/Quarter
Ammonia, total	mg/L as N	C-24	1/Quarter
Arsenic	µg/L	C-24	1/Quarter
Cadmium	µg/L	C-24	1/Quarter
Copper	µg/L	C-24	1/Quarter
Lead	µg/L	C-24	1/Quarter
Nickel	µg/L	C-24	1/Quarter
Selenium	µg/L	C-24	1/Quarter
Silver	µg/L	C-24	1/Quarter
Zinc	µg/L	C-24	1/Quarter
Remaining Ocean Plan Table 1 Pollutants ^[1]	µg/L	C-24 ^[2]	1/Year

Abbreviations:

mg/L = milligrams per liter
mg/L as N = milligrams per liter as nitrogen
µg/L = micrograms per liter

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Sample Types and Frequencies:

C-24 = 24-hour composite
Grab = grab sample
1/Quarter = once per quarter
1/Year = once per year

Footnotes:

- [1] The Discharger shall monitor for the pollutants listed in Ocean Plan Table 1, except chlorine, tributyltin, radioactivity, acute toxicity, and chronic toxicity. The Discharger may monitor for total chromium in lieu of hexavalent chromium.
- [2] For mercury and other parameters with analytical methods that require grab sampling, the Discharger may collect a grab sample instead of a 24-hour composite sample.

3. **Wet Weather.** During wet weather, the Discharger shall monitor plant effluent at Monitoring Location EFF-001B as follows:

Table E-5. Wet Weather Plant Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency
Duration of Blending ^[1]	minutes	Calculated	Continuous/D
Volume of Blended Wastewater Discharged ^[1]	MG	Calculated	Continuous/D
Ocean Plan Table 1 Pollutants ^[2]	µg/L	C-24 ^[3]	1/Year

Abbreviations:

MG = million gallons
µg/L = micrograms per liter

Sample Types and Frequencies:

Continuous/D = measured continuously, and recorded and reported daily
C-24 = 24-hour composite
1/Year = once per year

Footnotes:

- [1] Blended wastewater is biologically-treated wastewater blended with wastewater diverted around biological treatment units at the Oceanside Water Pollution Control Plant. For each day on which blending occurs, the Discharger shall report the duration of blending and the volume of primary-only-treated wastewater blended.
- [2] The Discharger shall monitor for the pollutants listed in Ocean Plan Table 1, except chlorine, tributyltin, radioactivity, acute toxicity, and chronic toxicity. The Discharger may monitor for total chromium in lieu of hexavalent chromium.
- [3] For mercury and other parameters with analytical methods that require grab sampling, the Discharger may collect a grab sample instead of a 24-hour composite sample.

B. Combined Sewer System

1. **Westside Transport/Storage Structure Effluent.** During wet weather, the Discharger shall monitor Westside Transport/Storage Structure effluent at Monitoring Location EFF-001D as shown in Table E-6.

Table E-6. Westside Transport/Storage Structure Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency
Flow Volume ^[1]	MG	Continuous	Continuous/D
TSS	mg/L	C-X ^[3]	3/Year
Ammonia, total	mg/L as N	C-X ^[3]	3/Year
Arsenic	µg/L	C-X ^[3]	3/Year

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Parameter	Units	Sample Type	Minimum Sampling Frequency
Cadmium	µg/L	C-X ^[3]	3/Year
Copper	µg/L	C-X ^[3]	3/Year
Lead	µg/L	C-X ^[3]	3/Year
Nickel	µg/L	C-X ^[3]	3/Year
Selenium	µg/L	C-X ^[3]	3/Year
Silver	µg/L	C-X ^[3]	3/Year
Zinc	µg/L	C-X ^[3]	3/Year
Remaining Ocean Plan Table 1 Pollutants ^[2]	µg/L	C-X ^[3,4]	1/Year

Abbreviations:

MG = million gallons
mg/L = milligrams per liter
mg/L as N = milligrams per liter as nitrogen
µg/L = micrograms per liter

Sample Types and Frequencies:

Continuous = measured continuously
Continuous/D = measured continuously, and recorded and reported daily
C-X = composite sample comprised of individual grab samples collected at equal intervals of no more than one hour at least until a sufficient sample volume for the required analyses is obtained.
1/Year = once per year
3/Year = three times per year

Footnotes:

- ^[1] The following information shall be reported in monthly self-monitoring reports:
- Total daily flow volume from the Westside Transport/Storage Structure to Discharge Point No. 001
 - Total monthly flow volume from the Westside Transport/Storage Structure to Discharge Point No. 001
- ^[2] The Discharger shall monitor for the pollutants listed in Ocean Plan Table 1, except chlorine, tributyltin, radioactivity, acute toxicity, chronic toxicity, and volatile organic compounds. The Discharger may monitor for total chromium in lieu of hexavalent chromium.
- ^[3] If the discharge lasts less than 24 hours, the Discharger shall sample at equal intervals for as long as possible and record the duration. The Discharger shall begin collecting aliquots or grab samples within two hours of commencing discharge from the Westside Transport/Storage Structure directly to Discharge Point No. 001.
- ^[4] For mercury and other parameters with analytical methods that require grab sampling, the Discharger may collect a grab sample instead of a 24-hour composite sample.

2. Combined Sewer Discharges

- a. During combined sewer discharge events, the Discharger shall monitor combined sewer discharge effluent at Monitoring Location EFF-CSD as follows:

Table E-7. Combined Sewer Discharge Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency
TSS	mg/L	C-X ^[2]	1/Event
Ammonia, total	mg/L as N	C-X ^[2]	1/Event
Arsenic	µg/L	C-X ^[2]	1/Event
Cadmium	µg/L	C-X ^[2]	1/Event
Copper	µg/L	C-X ^[2]	1/Event
Lead	µg/L	C-X ^[2]	1/Event
Nickel	µg/L	C-X ^[2]	1/Event

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Parameter	Units	Sample Type	Minimum Sampling Frequency
Selenium	µg/L	C-X ^[2]	1/Event
Silver	µg/L	C-X ^[2]	1/Event
Zinc	µg/L	C-X ^[2]	1/Event
Remaining Ocean Plan Table 1 Pollutants ^[1]	µg/L	C-X ^[2,3]	1/Year

Abbreviations:

mg/L = milligrams per liter
mg/L as N = milligrams per liter as nitrogen
µg/L = micrograms per liter

Sample Types and Frequencies:

C-X = composite sample comprised of individual grab samples collected at equal intervals of no more than one hour at least until a sufficient sample volume for the required analysis is obtained.
Grab = grab sample
1/Event = once per combined sewer discharge event
1/Year = once per year

Footnotes:

- ^[1] The Discharger shall monitor for the pollutants listed in Ocean Plan Table 1, except chlorine, tributyltin, radioactivity, acute toxicity, chronic toxicity, and volatile organic compounds. The Discharger may monitor for total chromium in lieu of hexavalent chromium.
- ^[2] If the discharge lasts less than 24 hours, the Discharger shall sample for as long as possible at equal intervals and record the duration. If the discharge lasts less than one hour, the Discharger shall collect at least one grab sample.
- ^[3] For mercury and other parameters with analytical methods that require grab sampling, the Discharger may collect a grab sample instead of a composite sample.

- b. The Discharger shall record and report in each self-monitoring report the following information for each discharge at Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007:
- i. Date and time the combined sewer discharge started;
 - ii. Event duration (in minutes) and volume (in million gallons);
 - iii. Rainfall intensity and amount (in inches per day and peak hourly rainfall intensity per day) at representative locations where rainfall was measured;
 - iv. Information supporting discharge volume estimates (if estimated); and
 - v. Documentation of compliance or noncompliance with each wet weather operational requirement in Provision VI.C.5.c of the Order.

C. Westside Recycled Water Project

When the Westside Recycled Water Project is operating, the Discharger shall monitor reverse osmosis concentrate at Monitoring Location EFF-001R as follows:

Table E-8. Westside Recycled Water Project Concentrate Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency
Flow ^[1]	MG/MGD	Continuous	Continuous/D

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Parameter	Units	Sample Type	Minimum Sampling Frequency
TSS	mg/L	C-24	1/Month
pH	standard units	Continuous or Grab	1/Month
Settleable Solids	mL/L	Grab or C-24	1/Month
Turbidity	NTU	C-24	1/Month
Oil and Grease	mg/L	Grab	1/Quarter
Ocean Plan Table 1 Pollutants ^[2]	µg/L	C-24 ^[3]	1/Year

Abbreviations:

MG = million gallons
MGD = million gallons per day
mg/L = milligrams per liter
mL/L = milliliters per liter
µg/L = micrograms per liter
NTU = nephelometric turbidity units

Sample Types and Frequencies:

Continuous = measured continuously
Continuous/D = measured continuously, and recorded and reported daily
C-24 = 24-hour composite
Grab = grab sample
1/Month = once per month
1/Quarter = once per quarter
1/Year = once per year

Footnotes:

^[1] The following information shall be reported in monthly self-monitoring reports:

- Daily average flow (MGD)
- Total monthly flow volume (MG)

^[2] The Discharger shall monitor for the pollutants listed in Ocean Plan Table 1, except chlorine, tributyltin, radioactivity, acute toxicity, and chronic toxicity. The Discharger may monitor for total chromium in lieu of hexavalent chromium.

^[3] For mercury and other parameters with analytical methods that require grab sampling, the Discharger may collect a grab sample instead of a 24-hour composite sample.

D. Discharge Point No. 001

During dry weather, the Discharger shall monitor discharges at Discharge Point No. 001 at Monitoring Location EFF-001C as specified in Table E-9, below. If during the year the discharge at Discharge Point No. 001 is ever entirely reverse osmosis concentrate, the Discharger shall collect at least one sample during that time, if feasible. Otherwise, the Discharger shall collect samples when the Recycled Water Project is operating, if possible.

Table E-9. Dry Weather Discharge Point No. 001 Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency
Chronic Toxicity ^[1]	Pass or Fail and Percent Effect	C-24	1/Quarter

Sample Type and Frequency:

C-24 = 24-hour composite
1/Quarter = once per quarter

Footnote:

^[1] Chronic toxicity test samples shall be collected coincident with routine composite effluent samples and analyzed in accordance with MRP section V.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

V. CHRONIC TOXICITY MONITORING REQUIREMENTS

A. Methodology

1. The Discharger shall conduct static non-renewal chronic toxicity tests with the purple sea urchin (*Strongylocentrotus purpuratus*) or the sand dollar (*Dendraster excentricus*) with the embryo-larval development test method. Bioassays shall be conducted in compliance with the most recently promulgated test methods, currently *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms* (EPA 600/R-95/136, 1995). If these protocols prove unworkable, the Regional Water Board and U.S. EPA may grant exceptions in writing upon the Discharger's request with justification.
2. The in-stream waste concentration (IWC) shall depend on the amount of recycled water being produced. When the Westside Recycled Water Project produces less than 1.0 MGD of recycled water for distribution, the IWC shall be 0.67 percent effluent. When the Westside Recycled Water Project produces at least 1.0 MGD of recycled water for distribution, the IWC shall be 0.37 percent effluent. Recycled water production for this purpose shall be determined based on the volume of recycled water produced during the 24-hour composite sampling period for the chronic toxicity test.
3. If an effluent toxicity test does not meet all test acceptability criteria in the test methods manual, the Discharger shall resample and retest within 14 days.
4. Dilution and control water, including brine controls, shall be 1- μ m-filtered uncontaminated natural seawater, hypersaline brine prepared using uncontaminated natural seawater, or laboratory water prepared and used as specified in the test methods manual. If dilution water and control water are different from test organism culture water, the Discharger shall test a second control using culture water.
5. The Discharger shall conduct concurrent reference toxicant tests at least quarterly. The Discharger shall review and report all reference toxicant test results using the EC₂₅ and EC₅₀.

B. Compliance Determination

Samples collected during routine and accelerated monitoring shall be used to evaluate compliance. Compliance with the chronic toxicity effluent limitation shall be evaluated using the TST statistical approach at the discharge IWC. The Discharger shall determine "Pass" or "Fail" and "percent effect" from a toxicity test at the discharge IWC using the TST statistical approach in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, 2010), Appendix A, Figure A-1 and Table A-1. The TST null hypothesis shall be the following:

$$\text{mean discharge IWC response} \leq 0.75 \times \text{mean control response}$$

The Discharger shall report a test that rejects this null hypothesis as "Pass" and a test that does not reject this null hypothesis as "Fail." The relative "percent effect" at the discharge IWC shall be calculated and reported as:

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

$$([\text{mean control response} - \text{mean discharge response}] / \text{mean control response}) \times 100\%$$

C. Accelerated Monitoring

If a chronic bioassay test indicates a violation of the chronic toxicity effluent limitation, the Discharger shall retest within five days of receiving test results, or within seven days if the sample is contracted out to a commercial laboratory. Accelerated monitoring shall consist of four toxicity tests conducted at approximately two-week intervals. The Discharger shall return to routine monitoring if all four monitoring test results are “Pass.”

If any accelerated monitoring test violates the chronic toxicity effluent limitation, the Discharger shall immediately initiate toxicity reduction evaluation (TRE) procedures in accordance with MRP section V.E. Accelerated monitoring is not required once the Discharger has initiated a TRE; however, the Discharger shall continue to conduct routine effluent monitoring for compliance determination purposes during the TRE.

D. Reporting Requirements

For each chronic toxicity test, whether identified as valid or not, the Discharger shall report the following, at a minimum, in monthly self-monitoring reports:

1. Sample date;
2. Test initiation date;
3. Test species;
4. TST statistical results (i.e., “Pass” or “Fail,” and “percent effect” at the IWC);
5. Other biological and statistical endpoint values as appropriate (e.g., number of young, growth rate, NOEC, EC₂₅);
6. Summary of water quality measurements for each toxicity test (e.g., pH, dissolved oxygen, temperature, conductivity, hardness, salinity, and ammonia);
7. Statistical program output results for each toxicity test, including tabular data and graphical plots;
8. Tabular data and graphical plots showing the laboratory’s performance for (1) the reference toxicant for the previous 20 tests; and (2) the control mean, control standard deviation, and control coefficient of variation for the previous 12 months; and
9. Status of any ongoing TRE work, including completed and planned investigative activities.

E. Toxicity Reduction Evaluation (TRE)

1. **Generic TRE Work Plan.** The Discharger shall prepare and submit an initial investigation TRE work plan within 90 days of the effective date of this Order. The Discharger shall prepare the work plan based on *Toxicity Reduction Evaluation Guidance for Municipal*

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Wastewater Treatment Plants (EPA/833/B-99/002, 1999), or the most current version. The work plan shall describe the steps the Discharger intends to follow if toxicity is detected. At a minimum, the work plan shall include a description of the following:

- a. Investigation and evaluation techniques that will be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency;
 - b. Methods of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in the operation of the Facility; and
 - c. Staff responsible for conducting TIEs (e.g., in-house expert, outside contractor).
2. **Specific TRE Work Plan.** If an accelerated monitoring test violates the chronic toxicity effluent limitation, the Discharger shall immediately initiate a TRE and submit a specific TRE work plan within 15 days. The specific work plan shall be the generic work plan revised as appropriate for this toxicity event. The Discharger shall implement the TRE in accordance with the work plan, incorporating any comments received from the Regional Water Board Executive Officer or U.S. EPA. The specific TRE work plan shall include the following:
- a. Actions to investigate, identify, and correct the causes of toxicity;
 - b. Actions to mitigate the effects of the discharge and prevent the recurrence of toxicity; and
 - c. Schedule for these actions, progress reports, and the final report.
3. **Toxicity Identification Evaluation (TIE).** The Discharger may initiate a TIE as part of a TRE to identify the cause of toxicity. The Discharger shall employ all reasonable efforts using currently available TIE methodologies (*Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I* [EPA 600/6-91/005F, 1992]; *Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity* [EPA 600/R-92/080, 1993]; *Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity* [EPA 600/R-92/081, 1993]; and *Marine Toxicity Identification Evaluation [TIE]: Phase I Guidance Document* [EPA 600/R-96-054, 1996]).

F. Species Screening

1. The Discharger shall conduct a chronic toxicity screening test as described below (or as described in applicable State Water Board plan provisions that become effective after adoption of this Order) following any significant change in the nature of the effluent, except a change that reduces pollutant concentrations or a change resulting from operation of the Westside Recycled Water Project. If there is no significant change in the nature of the effluent, the Discharger shall conduct a screening test prior to submitting an application for permit reissuance.
2. Prior to undertaking a screening test, the Discharger shall submit a screening test proposal. The proposal shall address the elements below. If within 30 days the Regional Water Board

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Executive Officer and U.S. EPA do not comment on the proposal, the Discharger shall commence the screening test.

3. The screening test shall use the protocols described in *Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to West Coast Marine and Estuarine Organisms* (EPA 600/R-95/136, 1995) and test species specified in the table below:

Table E-10. Critical Life Stage Toxicity Tests

Species	Scientific Name	Effect	Test Duration
Giant kelp	<i>Macrocystis pyrifera</i>	Percent germination; germ tube length	48 hours
Abalone	<i>Haliotis rufescens</i>	Abnormal shell development	48 hours
Oyster Mussel	<i>Crassostrea gigas</i> <i>Mytilus edulis</i>	Abnormal shell development; percent survival	48 hours
Echinoderms - Urchins Sand dollar	<i>Strongylocentrotus</i> <i>purpuratus</i> , <i>Strongylocentrotus</i> <i>franciscanus</i> , or <i>Dendraster excentricus</i>	Percent fertilization or larval development	1 hour (fertilization) or 72 hours (development)
Shrimp	<i>Holmesimysis costata</i>	Percent survival; growth	7 days
Topsmelt	<i>Atherinops affinis</i>	Percent survival; growth	7 days

4. The Discharger shall conduct screening tests in two stages:
 - a. Stage 1 shall consist of a minimum of one battery of at least four tests conducted concurrently. Test species shall include at least one plant, one invertebrate, and one fish.
 - b. Stage 2 shall consist of a minimum of two test batteries initiated in different calendar months using the three most sensitive species determined based on the stage 1 test results.
5. The Discharger shall use appropriate controls and conduct concurrent reference toxicant tests.
6. The Discharger shall conduct screening tests at 75, 20, 0.67, 0.37, and 0.17 percent effluent.

VI. RECEIVING WATER MONITORING REQUIREMENTS

A. Shoreline Monitoring

1. The Discharger shall monitor shoreline receiving waters at Monitoring Locations SRF-15 east, SRF-15, SRF-17, SRF-18, SRF-19, and SRF-21.1 as follows:

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Table E-11. Ambient Shoreline Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency
Enterococcus ^[1]	MPN/100 mL ^[2]	Grab	1/Week
Fecal coliform ^[3]	MPN/100 mL ^[2]	Grab	1/Week
Total coliform	MPN/100 mL ^[2]	Grab	1/Week

Abbreviation:

MPN/100 mL = most probable number per 100 milliliters

Sample Type and Frequency:

Grab = grab sample
1/Week = once per week

Footnotes:

^[1] The Discharger shall monitor for enterococcus using U.S. EPA-approved methods, such as the IDEXX Enterolert method. When replicate analyses are made, the reported result shall be the geometric mean of the replicate results.

^[2] Results may be reported as Colony Forming Units (CFU)/100 mL if the laboratory method used provides results in CFU/100 mL.

^[3] The Discharger shall begin monitoring fecal coliform on October 1, 2020.

- Following any combined sewer discharge at Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-005, CSD-006, or CSD-007, the Discharger shall monitor shoreline receiving waters as indicated in the table below. Monitoring shall be conducted at each specified location for up to seven days or until the single-sample bacteriological standards of Cal. Code of Regs. tit. 17, section 7958(a)(1), are met (i.e., the enterococcus density is less than 104 most probable number (MPN)/100 mL, the fecal coliform density is less than 400 MPN/100 mL, and the total coliform density is less than 10,000 MPN/100 mL).

Table E-12. Post-CSD Event Shoreline Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency
Enterococcus ^[1]	MPN/100 mL ^[2]	Grab	1/Day ^[3]
Fecal coliform ^[4]	MPN/100 mL ^[2]	Grab	1/Day ^[3]
Total coliform	MPN/100 mL ^[2]	Grab	1/Day ^[3]
Standard observations ^[5]	---	---	1/Day ^[3]

Abbreviation:

MPN/100 mL = most probable number per 100 milliliters

Sample Type and Frequency:

Grab = grab sample
1/Day = once per day

Footnotes:

^[1] The Discharger shall monitor for enterococcus using U.S. EPA-approved methods, such as the IDEXX Enterolert method. When replicate analyses are made, the reported result shall be the geometric mean of the replicate results.

^[2] Results may be reported as Colony Forming Units (CFU)/100 mL if the laboratory method used provides results in CFU/100 mL.

^[3] Sampling is only required at the monitoring locations indicated below when there is a combined sewer discharge at the discharge points indicated below:

<u>Discharge Point</u>	<u>Monitoring Locations</u>
CSD-001	SRF-22
CSD-002	SRF-20, SRF-21, and SRF-21.1
CSD-003	SRF-18, SRF-19, and SRF-20
CSD-005	SRF-17

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

CSD-006 SRF-15 east, SRF-15, and SRF-16
 CSD-007 SRF-15 east, SRF-15, and SRF-16

- [4] The Discharger shall begin monitoring fecal coliform on October 1, 2020.
- [5] Standard observations are defined in Attachment G section III.B.3 and shall include any apparent fish kills. The estimated size of the affected area is not required.

B. Offshore Monitoring

The Discharger shall continue the Southwest Ocean Outfall Regional Monitoring Program, monitoring the area outside San Francisco Bay between Rocky Point in Marin County and Point San Pedro in San Mateo County, to identify any environmental effects of the discharge on receiving waters, sediment, or aquatic life.

1. **Sampling Frequency.** The Discharger shall sample annually in the fall when sediments are least disturbed and benthic infauna are most abundant.
2. **Sediment Chemistry Sampling.** The Discharger shall collect benthic samples from the seven historical monitoring locations (Stations 1, 2, 4, 6, 25, 28, and 31) to maintain time series data, and a minimum of 23 out of the 37 other monitoring locations (Stations 32 through 80). Samples shall be collected using a 0.1-square meter Smith-McIntyre grab sampler. The Discharger shall collect two grab samples at each station and composite the top 5 centimeters of sediment from each grab prior to analysis. The Discharger shall analyze the sediment samples for the following:
 - Total volatile solids
 - Total organic carbon
 - Kjeldahl nitrogen
 - Grain size
 - Inorganic toxic pollutants: aluminum, arsenic, cadmium, chromium, chromium (VI), copper, iron, lead, manganese, mercury, nickel, selenium, silver, and zinc. The Discharger may elect to report total chromium in lieu of chromium (VI).
 - DDT, PCBs, and PAHs
3. **Infaunal Sampling.** The Discharger shall analyze one benthic grab sample collected from each of the locations identified in the paragraph above for infaunal organisms. This sample shall be passed through 1.0- and 0.5-millimeter sieves. The Discharger shall relax organisms retained on each sieve and preserve them for later enumeration and taxonomic determination to the lowest taxon.
4. **Bioaccumulation Monitoring.** The Discharger shall conduct bioaccumulation monitoring to assess whether the concentrations of priority pollutants in marine life bioaccumulate to levels harmful to human health or the marine community. Tissue samples to assess bioaccumulation shall be collected at two locations: one at Station 1, 2, 25, or 28, and one at a reference location outside the influence of the discharge. At each location, three composite samples shall be collected of one macroinvertebrate species. Each composite sample shall consist of ten or more organisms of each species, with the preferred species being Dungeness crab (*Metacarcinus magister*). Muscle and hepatopancreas tissues shall be analyzed for inorganic

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

pollutants (i.e., arsenic, cadmium, chromium, copper, lead, mercury, selenium, silver, and zinc), DDT, PCBs, and PAHs.

- 5. Reporting.** All offshore monitoring data shall be reported to the Regional Water Board and U.S. EPA in an Annual Report submitted by August 30 of the year following sampling. The report shall include raw data tables and summaries for each monitoring component. In addition to the annual reporting requirements, a comprehensive cumulative summary report shall be submitted with the application for permit reissuance.

VII. PRETREATMENT AND BIOSOLIDS MONITORING REQUIREMENTS

The Discharger shall comply with the following pretreatment monitoring requirements for influent at Monitoring Location INF-001A, effluent at Monitoring Location EFF-001A, and biosolids at Monitoring Location BIO-001. The Discharger shall report summaries of analytical results in pretreatment reports in accordance with Attachment H. If instructed to do so, the Discharger shall report biosolids analytical results with its electronic self-monitoring reports by manual entry, by EDF/CDF, or as an attached file.

Table E-13. Pretreatment and Biosolids Monitoring

Constituents	Influent INF-001A	Effluent EFF-001A ^[1]	Biosolids BIO-001	Sample Type	
				Influent and Effluent	Biosolids ^[7a]
VOC ^[2]	2/Year	2/Year	2/Year	Grab	Grab
BNA ^[3]	2/Year	2/Year	2/Year	Grab	Grab
Metals and Other Elements ^[4]	1/Month	1/Month	2/Year	C-24 ^[7b]	Grab
Hexavalent Chromium ^[5]	1/Month	1/Month	2/Year	Grab	Grab
Mercury	1/Month	1/Month ^[6]	2/Year	Grab	Grab
Cyanide	1/Month	1/Month	---	Grab	---
Molybdenum	---	---	2/Year	---	Grab
Organic Nitrogen	---	---	2/Year	---	Grab
Ammonia Nitrogen	---	---	2/Year	---	Grab
Total Solids	---	---	2/Year	---	Grab

Sample Types and Frequencies:

C-24 = 24-hour composite
Grab = grab sample
1/Month = once per month
2/Year = twice per year

Footnotes:

- ^[1] Effluent monitoring conducted in accordance with Table E-4 may be used to satisfy these pretreatment monitoring requirements.
- ^[2] VOC: volatile organic compounds.
- ^[3] BNA: base/neutrals and acid extractable organic compounds.
- ^[4] The metals and other elements are arsenic, cadmium, copper, lead, nickel, selenium, silver, and zinc.
- ^[5] The Discharger may elect to monitor total chromium instead of hexavalent chromium and may elect to collect 24-hour composite samples instead of grab samples for total chromium.
- ^[6] The Discharger shall use ultra-clean sampling (U.S. EPA Method 1669) and ultra-clean analytical methods (U.S. EPA Method 1631) for mercury monitoring, except when concentrations are expected to exceed 10 µg/L, in which case use of ultra-clean sampling and analysis methods is optional.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

^[7] Sample types:

- a. The biosolids sample shall be a composite of the biosolids to be disposed. Biosolids sample collection and monitoring shall comply with the requirements in Attachment H, Appendix H-4. The Discharger shall also comply with the biosolids monitoring requirements in 40 C.F.R. part 503.
- b. If an automatic compositor is used, the Discharger shall obtain 24-hour composite samples through flow-proportioned composite sampling. Alternatively, 24-hour composite samples may consist of discrete grab samples combined (volumetrically flow-weighted) prior to analysis or analyzed separately with the results mathematically flow-weighted.

VIII. RECYCLED WATER MONITORING REQUIREMENTS

A. Influent Monitoring

The Discharger shall monitor the monthly volume of influent to the Oceanside Water Pollution Control Plant.

B. Production Monitoring

The Discharger shall monitor the monthly volumes of effluent from the Oceanside Water Pollution Control Plant and Westside Recycled Water Project for each level of treatment.

C. Discharge Monitoring

The Discharger shall monitor the monthly volumes of effluent from the Oceanside Water Pollution Control Plant and Westside Recycled Water Project discharged to each of the following, for each level of treatment:

1. Inland surface waters, specifying volume required to maintain minimum instream flow;
2. Enclosed bays, estuaries and coastal lagoons, and ocean waters;
3. Natural systems, such as wetlands, wildlife habitats, and duck clubs, where augmentation or restoration has occurred, and that are not part of a wastewater treatment plant or water recycling treatment plant;
4. Underground injection wells, such as those classified by U.S. EPA's Underground Injection Control Program, excluding groundwater recharge via subsurface application intended to reduce seawater intrusion into a coastal aquifer with a seawater interface; and
5. Land, where beneficial use is not taking place, including evaporation or percolation ponds, overland flow, or spray irrigation disposal, excluding pasture or fields with harvested crops.

D. Reuse Monitoring

The Discharger shall monitor the following:

1. Monthly volume of recycled water distributed; and

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

2. Annual volumes of treated wastewater distributed for beneficial use in compliance with California Code of Regulations, title 22, in each of the use categories listed below:
 - a. Agricultural irrigation: pasture or crop irrigation;
 - b. Landscape irrigation: irrigation of parks, greenbelts, and playgrounds; school yards; athletic fields; cemeteries; residential landscaping, common areas; commercial landscaping; industrial landscaping; and freeway, highway, and street landscaping;
 - c. Golf course irrigation: irrigation of golf courses, including water used to maintain aesthetic impoundments within golf courses;
 - d. Commercial application: commercial facilities, business use (such as laundries and office buildings), car washes, retail nurseries, and appurtenant landscaping that is not separately metered;
 - e. Industrial application: manufacturing facilities, cooling towers, process water, and appurtenant landscaping that is not separately metered;
 - f. Geothermal energy production: augmentation of geothermal fields;
 - g. Other non-potable uses: including but not limited to dust control, flushing sewers, fire protection, fill stations, snow making, and recreational impoundments;
 - h. Groundwater recharge: the planned use of recycled water for replenishment of a groundwater basin or an aquifer that has been designated as a source of water supply for a public water system. Includes surface or subsurface application, except for seawater intrusion barrier use;
 - i. Seawater intrusion barrier: groundwater recharge via subsurface application intended to reduce seawater intrusion into a coastal aquifer with a seawater interface;
 - j. Reservoir water augmentation: the planned placement of recycled water into a raw surface water reservoir used as a source of domestic drinking water supply for a public water system, as defined in Health and Safety Code section 116275, or into a constructed system conveying water to such a reservoir (Wat. Code § 13561);
 - k. Raw water augmentation: the planned placement of recycled water into a system of pipelines or aqueducts that delivers raw water to a drinking water treatment plant that provides water to a public water system as defined in Health and Safety Code section 116275 (Wat. Code § 13561); and

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

1. Other potable uses: both indirect and direct potable reuse other than for groundwater recharge, seawater intrusion barrier, reservoir water augmentation, or raw water augmentation.

IX. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

The Discharger shall comply with all Standard Provisions (Attachments D, G, and H) related to monitoring, reporting, and recordkeeping.

B. Self-Monitoring Reports (SMRs)

1. **SMR Format.** The Discharger shall electronically submit SMRs using the State Water Board's California Integrated Water Quality System (CIWQS) Program website (http://www.waterboards.ca.gov/water_issues/programs/ciwqs). The CIWQS website will provide additional information for SMR submittal in the event of a service interruption for electronic submittal.
2. **SMR Due Dates and Contents.** The Discharger shall submit SMRs by the due dates, and with the contents, specified below:
 - a. **Monthly SMRs.** Monthly SMRs shall be due 30 days after the end of each calendar month, covering that calendar month. The monthly SMR shall contain the applicable items described in sections V.B and V.C of both Attachments D and G of this Order.

Monthly SMRs shall include all new monitoring results obtained since the last SMR was submitted. If the Discharger monitors any pollutant more frequently than required by this Order, the Discharger shall include the results of such monitoring in the calculations and reporting for the SMR.

- b. **Annual SMR.** Annual SMRs shall be due February 1 each year, covering the previous calendar year. The annual SMR shall contain the items described in Attachment G section V.C.1.f. See also Provision VI.C.2 (Effluent Characterization Study and Report) of the Order for requirements to submit reports with the annual SMR.
 - c. **Specifications for Submitting SMRs to CIWQS.** The Discharger shall submit analytical results and other information using one of the following methods:

Table E-14. CIWQS Reporting

Parameter	Method of Reporting	
	EDF/CDF data upload or manual entry	Attached File
All parameters identified in influent, effluent, and receiving water monitoring tables (except Dissolved Oxygen and Temperature)	Required for all results	
Dissolved Oxygen Temperature	Required for monthly maximum and minimum results only ⁽¹⁾	Discharger may use this method for all results or keep records

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Parameter	Method of Reporting	
	EDF/CDF data upload or manual entry	Attached File
Antimony Arsenic Beryllium Cadmium Chromium Copper Cyanide Lead Mercury Nickel Selenium	Silver Thallium Zinc Dioxins & Furans (by U.S. EPA Method 1613) Other Pollutants (by U.S. EPA Methods 601, 602, 608, 610, 614, 624, and 625)	Required for all results ^[2]
Volume and Duration of Blended Discharge ^[3]	Required for all blended effluent discharges	
Analytical Method	Not required (Discharger may select "data unavailable") ^[1]	
Collection Time Analysis Time	Not required (Discharger may select "0:00") ^[1]	

Footnotes:

- ^[1] The Discharger shall continue to monitor at the minimum frequency specified in this MRP, keep records of the measurements, and make the records available upon request.
- ^[2] These parameters require EDF/CDF data upload or manual entry regardless of whether monitoring is required by this MRP or other provisions of this Order (except for biosolids, sludge, or ash provisions).
- ^[3] The requirement for volume and duration of blended discharge applies only if this Order authorizes the Discharger to discharge blended effluent.

The Discharger shall arrange all reported data in a tabular format and summarize the data to clearly illustrate whether the Facility is operating in compliance with effluent limitations. The Discharger is not required to duplicate the submittal of data entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format, the Discharger shall electronically submit the data in a tabular format as an attachment.

3. Monitoring Periods. Monitoring periods for all required monitoring shall be as set forth below unless otherwise specified:

Table E-15. Monitoring Periods

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period
Continuous	Order effective date	All times
1/Day	Order effective date	Every 24-hour period, beginning at midnight and continuing through 11:59 p.m. (or any 24-hour period that reasonably represents a calendar day for purposes of sampling)
1/Week 5/Week	First Sunday following or on Order effective date	Sunday through Saturday

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period
1/Month	First day of calendar month following or on Order effective date	First day of calendar month through last day of calendar month
1/Quarter	Closest of January 1, April 1, July 1, or October 1 following or on Order effective date	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31
1/Year 3/Year	Closest January 1 following or on Order effective date	January 1 through December 31
2/Year	Closest January 1 or July 1 following or on Order effective date	January 1 through June 30 July 1 through December 31
1/Event	As soon as possible after combined sewer discharge event begins	Duration of the combined sewer discharge event

4. RL and MDL Reporting. The Discharger shall report with each sample result the Reporting Level (RL) and Method Detection Limit (MDL) as determined by the procedure in 40 C.F.R. part 136. The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ. The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (+/- a percentage of the reported value), numerical ranges (low to high), or any other means the laboratory considers appropriate.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected", or ND.
- d. The Discharger shall instruct laboratories to establish calibration standards so that the minimum level (ML) value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.

5. Compliance Determination. Compliance with effluent limitations shall be determined using sample reporting protocols defined above and in the Fact Sheet and Attachments A, D, and G. For purposes of reporting and administrative enforcement by the Regional Water Board, State Water Board, or U.S. EPA, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the RL.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

C. Discharge Monitoring Reports (DMRs)

DMRs are U.S. EPA reporting requirements. The Discharger shall electronically certify and submit DMRs together with SMRs using the Electronic Self-Monitoring Reports module eSMR 2.5 or the latest upgraded version. Electronic DMR submittal shall be in addition to electronic SMR submittal. Information about electronic DMR submittal is available at the DMR website at http://www.waterboards.ca.gov/water_issues/programs/discharge_monitoring.

D. Annual Recycled Water Reports

The Discharger shall electronically submit annual reports to the State Water Board by April 30 each year covering the previous calendar year using the State Water Board's GeoTracker website (<http://geotracker.waterboards.ca.gov>) under a site-specific global identification number. For the 2019 calendar year, the Discharger shall submit a report by April 30, 2020, covering January through December 2019. The annual report shall include the elements specified in Attachment E section VIII.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

ATTACHMENT F – FACT SHEET

Contents

I.	Permit Information.....	F-3
II.	Facility Description.....	F-4
	A. Wastewater and Biosolids Treatment.....	F-4
	B. Discharge Points and Receiving Waters	F-6
	C. Summary of Previous Requirements and Self-Monitoring Data.....	F-7
III.	Applicable Plans, Policies, and Regulations.....	F-9
	A. Legal Authorities	F-9
	B. California Environmental Quality Act	F-9
	C. State and Federal Laws, Regulations, Policies, and Plans	F-9
	D. Impaired Waters on CWA 303(d) List	F-14
IV.	Rationale for Effluent Limitations and Discharge Specifications	F-14
	A. Discharge Prohibitions	F-15
	B. Technology-Based Effluent Limitations	F-16
	C. Water Quality-Based Effluent Limitations (WQBELs).....	F-17
	1. Scope and Authority	F-17
	2. Beneficial Uses and Water Quality Objectives	F-18
	3. Minimum Initial Dilution	F-18
	4. Need for Water Quality-Based Effluent Limitations (Reasonable Potential Analysis)	F-19
	5. WQBELs	F-25
	D. Discharge Requirement Considerations	F-25
V.	Rationale for Receiving Water Limitations	F-26
VI.	Rationale for Provisions.....	F-27
	A. Standard Provisions.....	F-27
	B. Monitoring and Reporting Program (MRP) Requirements.....	F-27
	C. Special Provisions	F-27
	1. Reopener Provisions.....	F-27
	2. Effluent Characterization Study and Report.....	F-27
	3. Pollutant Minimization Program	F-28
	4. Special Provisions for Publicly-Owned Treatment Works (POTWs).....	F-28
	5. Combined Sewer System Controls.....	F-29
	6. Westside Recycled Water Project Operations Notification.....	F-31
	7. Flame Retardant Special Study	F-32
	8. Efficacy of Combined Sewer System Controls Special Study	F-32
VII.	Rationale for Monitoring and Reporting Requirements	F-32
VIII.	Public Participation.....	F-34

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Tables

Table F-1. Facility Information.....	F-3
Table F-2. Previous Dry Weather Effluent Limitations and Monitoring Data.....	F-7
Table F-3. Combined Sewer Discharge Frequency	F-7
Table F-4. Combined Sewer Discharge Duration (July 1, 2012, through June 30, 2013).....	F-8
Table F-5. Basin Plan Beneficial Uses	F-9
Table F-6. Ocean Plan Beneficial Uses	F-11
Table F-7. Secondary Treatment Requirements	F-16
Table F-8. Ocean Plan Table 2 Effluent Limitations.....	F-17
Table F-9. Reasonable Potential Analysis No. 1 - Existing Conditions	F-20
Table F-10. Reasonable Potential Analysis No. 2 - Westside Recycled Water Project Conditions.....	F-23

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

ATTACHMENT F – FACT SHEET

This Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order. As described in section II.B of this Order, the Regional Water Board and U.S. EPA incorporate this Fact Sheet as findings supporting the issuance of this Order.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table F-1. Facility Information

WDID	2 386009001
CIWQS Place ID	256498
Discharger	City and County of San Francisco
Name of Facility	Oceanside Water Pollution Control Plant, Wastewater Collection System, and Westside Recycled Water Project
Facility Address	3500 Great Highway San Francisco, CA 94132 San Francisco County
Facility Contact, Title and Phone	Dale Miller, Operations Superintendent, Wastewater Enterprise, (415) 242-2225
Authorized Person to Sign and Submit Reports	Greg Norby, Assistant General Manager, Wastewater Enterprise, (415) 554-2465
Mailing Address	San Francisco Public Utilities Commission/Wastewater Enterprise 525 Golden Gate Ave., 13th Floor, San Francisco, CA 94102
Billing Address	Same
Type of Facility	Publicly-Owned Treatment Works (POTW) and Combined Sewer System
Major or Minor Facility	Major
Threat to Water Quality	2
Complexity	A
Pretreatment Program	Yes
Reclamation Requirements	State Water Board Order WQ 2016-0068-DDW
Facility Permitted Flow	43 million gallons per day (MGD), maximum dry weather flow
Facility Design Flow	<u>Oceanside Water Pollution Control Plant</u> 43 MGD maximum dry weather design flow (secondary treatment) 65 MGD maximum wet weather design flow (secondary treatment for 43 MGD and primary treatment for an additional 22 MGD) <u>Westside Recycled Water Project</u> 4 MGD maximum design flow (1.6 MGD annual average)
Watershed	San Mateo Coastal Basin
Receiving Water	Pacific Ocean
Receiving Water Type	Ocean waters

- A. The City and County of San Francisco (Discharger) owns and operates the Oceanside Water Pollution Control Plant and its wastewater collection system. The Discharger plans to construct, own, and operate the Westside Recycled Water Project during this Order's term. Collectively, the Oceanside Water Pollution Control Plant, wastewater collection system, and Westside

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Recycled Water Project are referred to as the Facility. The Facility discharges to the Pacific Ocean, a water of the United States.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B.** The Discharger is regulated pursuant to National Pollutant Discharge Elimination System (NPDES) Permit No. CA0037681. It was previously subject to Order No. R2-2009-0062 (previous order). The Discharger filed a Report of Waste Discharge and submitted an application for reissuance of its waste discharge requirements (WDRs) and NPDES permit on April 3, 2014, and the previous order was administratively extended by operation of law. Order No. R2-2010-0054 amended the previous order to update the Regional Standard Provisions (Attachment G); Order No. R2-2011-0009 amended the previous order to update the pretreatment program requirements (Attachment H).

The Discharger is authorized to discharge subject to the WDRs and NPDES permit requirements in this Order at the discharge locations described in Table 2 of this Order. Regulations at 40 C.F.R. section 122.46 limit the duration of NPDES permits to a fixed term not to exceed five years. Accordingly, Table 3 of this Order limits the duration of the discharge authorization. Pursuant to California Code of Regulations, title 23, section 2235.4, the terms and conditions of an expired permit are automatically continued pending reissuance of the permit if the Discharger complies with all requirements for continuation of expired permits. (See 40 C.F.R § 122.6[d].)

II. FACILITY DESCRIPTION

A. Wastewater and Biosolids Treatment

- 1. Location and Service Area.** The Oceanside Water Pollution Control Plant is located at 3500 Great Highway, San Francisco. The plant provides wastewater treatment for western San Francisco and a small portion of Daly City owned and operated by the North San Mateo County Sanitation District. The service area population is approximately 250,000. The Discharger is constructing a recycled water project at the plant site during this Order’s term. The wastewater collection system is located throughout the western side of San Francisco. Attachment B shows maps of the Facility area.
- 2. Collection System.** The Discharger’s collection system is predominantly a combined sewer system with some limited separate sanitary sewers. The combined sewer system consists of approximately 250 miles of pipe, one major pump station (Westside Pump Station), six minor pump stations (four all-weather pump stations: Westside, Sea Cliff No. 1, Sea Cliff No. 2, and Pine Lake; and two wet weather pump stations: Sea Cliff No. 3 and Zoo Wet Weather Lift Station), and three large transport/storage structures (Westside Transport/Storage Structure, a 49.3-million-gallon box-like structure located beneath the Great Highway; Richmond Tunnel, a 12.0-million-gallon tunnel located to the north; and Lake Merced Tunnel, a 10.0-million-gallon tunnel located to the south). The separate sanitary sewer systems serve isolated areas and are also regulated under State Water Board

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

Order No. 2006-0003-DWQ as amended by State Water Board Order No. WQ 2013-0058-EXEC.

3. Wastewater Treatment

- a. **Oceanside Water Pollution Control Plant.** During dry weather, the plant provides secondary treatment. The treatment processes include coarse screening at the Westside Pump Station, fine screening and grit removal at the plant headworks, primary sedimentation, activated sludge treatment by a high-purity oxygen process, and secondary clarification. The effluent is not disinfected. The plant has a maximum secondary treatment design capacity of about 43 million gallons per day (MGD). During wet weather, the plant can provide primary treatment for about 22 MGD more, which is combined with the secondary-treated effluent prior to discharge for a total treatment capacity of 65 MGD. Plant effluent flows to Discharge Point No. 001 by gravity.
- b. **Combined Sewer System.** The combined storage capacity of the three transport/storage structures is about 71 million gallons. Collection system piping provides about 2 million gallons of additional storage. The transport/storage structures provide flow equalization and convey combined sewer system flows up to 65 MGD to the plant by way of the Westside Pump Station.

Flows above the plant's 65-MGD treatment capacity receive equivalent-to-primary treatment through solids settling, skimming of floatable solids, and in some cases screening within the combined sewer system. In addition to pumping up to 65 MGD to the plant, the Westside Pump Station can also pump flow from the Westside Transport/Storage Structure to Discharge Point No. 001 during wet weather (identified in the previous order as "decant"). The design capacity of the Westside Pump Station wet weather pumps ranges from 98 to 133 MGD depending on the number and model of pumps operating when there are high water levels in the West Box of the Westside Transport/Storage Structure (typically observed during wet weather operations). Flows that exceed the capacities of the Oceanside Water Pollution Control Plant and combined sewer system may discharge from Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007. Four of these discharge points are directly connected to transport/storage structures (Discharge Point Nos. CSD-001, CSD-002, CSD-003, and CSD-004), and three are associated with pump station sumps (Discharge Point Nos. CSD-005, CSD-006, and CSD-007). After wet weather events, stored combined sewer system flows and accumulated solids remaining in the transport/storage structures are conveyed to the plant for treatment.

4. **Sludge and Biosolids Management.** The Discharger uses temperature-phased anaerobic digestion, which is capable of producing Class A biosolids. Primary sludge, waste activated sludge, and secondary scum are mixed and co-thickened using gravity belt thickeners prior to being fed to the anaerobic digestion system. The digestion system accepts hauled-in batches of primary and secondary sludge from the Treasure Island Wastewater Treatment Plant. Digested biosolids are dewatered using screw presses and stored in hoppers prior to being loaded into covered trucks for transport. During the wet season, the majority of biosolids are hauled to a landfill for storage and eventual use as interim cover, final cover, or landfill

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

building material; a small percentage is reused for agricultural land application. During the dry season, biosolids are hauled offsite for agricultural land application.

5. **Water Recycling and Reclamation.** The Discharger is constructing a recycled water project at the Oceanside Water Pollution Control Plant site during this Order's term. Secondary-treated effluent will be treated further with membrane filtration, reverse osmosis, and ultraviolet (UV) light disinfection to produce recycled water. The concentrate from the reverse osmosis process will be commingled with plant effluent prior to discharge at Discharge Point No. 001. Filter backwash water generated at the Westside Recycled Water Project will be directed to the plant headworks for treatment. The project is expected to produce and deliver an annual average flow of 1.6 MGD of recycled water for distribution in the western portion of San Francisco, with peak deliveries of up to 4 MGD during summer. Water recycling operations will not increase the mass of pollutants discharged at Discharge Point No. 001, but will increase the concentration of pollutants discharged. The requirements of this Order account for the discharge from this water recycling project. Reclamation requires waste discharge requirements beyond those specified here, such as those in State Water Board Order No. WQ 2016-0068-DDW (Water Reclamation Requirements for Recycled Water Use).

B. Discharge Points and Receiving Waters

1. **Discharge Point No. 001.** During dry weather, secondary-treated effluent is discharged at Discharge Point No. 001. During wet weather, the discharge at Discharge Point No. 001 comprises primary-treated and secondary-treated effluent from the Oceanside Water Pollution Control Plant and equivalent-to-primary-treated effluent from the Westside Transport/Storage Structure. When the Westside Recycled Water Project becomes operational, reverse osmosis concentrate will also be discharged at Discharge Point No. 001.

Discharge Point No. 001 is a 4.5-mile-long (3.9 nautical mile-long) deepwater outfall that terminates with a diffuser that begins approximately 3.8 miles (3.3 nautical miles) from shore at a depth of 78 feet below mean lower low water (MLLW). The diffuser has 85 risers spread along a 3,000-foot outfall pipe. Each riser has eight ports. Discharge Point No. 001 discharges to the Pacific Ocean beyond the territorial waters of the State, which end three nautical miles from MLLW at shore.

2. **Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007.** During wet weather, equivalent-to-primary-treated wastewater is discharged to the Pacific Ocean at Discharge Point Nos. CSD-001, CSD-002, CSD-003, and CSD-004 when the Westside Pump Station capacity is exceeded, and at Discharge Point Nos. CSD-005, CSD-006, and CSD-007 when the capacities of the corresponding pump stations (i.e., Sea Cliff No. 1 and Sea Cliff No. 2 Pump Stations) are exceeded, including the capacity of the wet well connected to Discharge Point No. CSD-006. These discharge points are located within the territorial waters of the State.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

C. Summary of Previous Requirements and Self-Monitoring Data

- 1. Dry Weather.** Dry weather effluent limitations and representative monitoring data from the previous order term are presented below for discharges from the Oceanside Water Pollution Control Plant at Discharge Point No. 001:

Table F-2. Previous Dry Weather Effluent Limitations and Monitoring Data

Parameter	Units	Effluent Limitations				Monitoring Data (1/2011 – 12/2017)				
		6-Month Median	Monthly Average	Weekly Average	Daily Max.	Median	Highest 6-Month Median	Highest Monthly Average	Highest Weekly Average	Highest Daily Max.
Biochemical Oxygen Demand, 5-day @ 20°C (BOD ₅)	mg/L	---	30	45	---	15	---	29	51 ^[1]	---
Total Suspended Solids (TSS)	mg/L	---	30	45	---	10	---	18	26	---
BOD ₅ percent removal	%	---	85 (min.)	---	---	95	---	87 ^[2]	---	---
TSS percent removal	%	---	85 (min.)	---	---	96	---	92 ^[2]	---	---
pH	s.u.	Within a range of 6.0 – 9.0				Within a range of 6.0 – 8.3				
Chronic Toxicity	TU _c	---	---	---	150	50	---	---	---	149
Mercury	µg/L	5.9	---	---	24	0.0068	0.0093	---	---	0.071

Abbreviations:

Max. = maximum
min. = minimum
mg/L = milligrams per liter
µg/L = micrograms per liter
s.u. = standard units
TU_c = chronic toxicity units

Footnotes:

- ^[1] The Discharger exceeded the weekly average effluent limitation three times during the previous order term, in October 2013, July 2014, and June 2017. The Discharger attributes these exceedances to the presence of nitrifying bacteria since carbonaceous biochemical oxygen demand (CBODs) concentrations were within the expected range. This Order allows CBODs effluent limitations to be substituted for BOD₅ effluent limitations to address this concern, as described in Fact Sheet section IV.B.2, below.
- ^[2] Lowest monthly average.

- 2. Wet Weather.** Wet weather requirements from the previous order term included implementation of the nine minimum controls and the long-term control plan. The combined sewer system was designed to achieve a long-term average of eight combined sewer discharges per year. The following two tables summarize combined sewer discharges over a 20-year period and average combined sewer discharge durations for wet season 2012-2013.

Table F-3. Combined Sewer Discharge Frequency

Year (July 1 – June 30)	Rain (inches)	Number of Combined Sewer Discharges ^[1]						
		Lake Merced CSD-001	Vicente CSD-002	Lincoln CSD-003	Mile Rock CSD-004	Sea Cliff No. 1 CSD-005	Sea Cliff Sewer CSD-006	Sea Cliff No. 2 CSD-007
1997-1998	41.1	10	13	13	^[2]	2	^[3]	10

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Year (July 1 – June 30)	Rain (inches)	Number of Combined Sewer Discharges ^[1]						
		Lake Merced CSD-001	Vicente CSD-002	Lincoln CSD-003	Mile Rock CSD-004	Sea Cliff No. 1 CSD-005	Sea Cliff Sewer CSD-006	Sea Cliff No. 2 CSD-007
1998-1999	18.9	6	7	7	[2]	0	[3]	0
1999-2000	23.2	5	6	6	[2]	1	[3]	1
2000-2001	13.8	2	0	0	[2]	2	[3]	2
2001-2002	24.4	6	6	6	[2]	1	[3]	1
2002-2003	22.3	5	6	6	[2]	1	[3]	7
2003-2004	18.8	4	4	4	[2]	2	[3]	8
2004-2005	26.2	7	7	6	[2]	5	[3]	8
2005-2006	31.8	11	9	9	[2]	3	[3]	9
2006-2007	14.8	2	1	1	[2]	0	[3]	2
2007-2008	18.4	4	4	4	[2]	0	[3]	1
2008-2009	18.3	4	4	4	[2]	0	[3]	1
2009-2010	25.8	4	3	3	[2]	6	[3]	7
2010-2011	30.1	5	4	4	[2]	0	0	3
2011-2012	17.0	3	3	2	[2]	2	0	3
2012-2013	19.7	6	6	6	[2]	3	1	3
2013-2014	12.0	3	2	2	[2]	0	1	3
2014-2015	17.7	6	6	6	[2]	3	0	4
2015-2016	18.6	9	8	6	[2]	1	0	4
2016-2017	32.4	13	13	13	[2]	1	0	14
2017-2018	18.0	3	3	3	[2]	0	0	5
Average	22.1	5.6	5.5	5.3	[2]	1.5	0.3	4.6

Footnotes:

[1] This table reflects rain and discharge frequencies reported in monthly self-monitoring reports.

[2] The previous order did not require monitoring at Discharge Point No. CSD-004.

[3] The Discharger did not monitor combined sewer discharge frequency at Discharge Point No. CSD-006 until it installed telemetry in 2010.

Table F-4. Combined Sewer Discharge Duration (July 1, 2012, through June 30, 2013)

	Lake Merced CSD-001	Vicente CSD-002	Lincoln CSD-003	Mile Rock CSD-004	Sea Cliff No. 1 CSD-005	Sea Cliff Sewer CSD-006	Sea Cliff No. 2 CSD-007
Days with Rainfall	53	53	53	[1]	53	53	53
Discharge Events	6	6	6 [2]	[1]	3	1	3
Average Duration (hours)	2.39	3.28	3 [2]	[1]	0.08	0.58	0.28
Average Volume/Event (million gallons)	2.75	3.16	[2]	[1]	0.002	0.08	0.01

Footnotes:

[1] The previous order did not require monitoring at Discharge Point No. CSD-004.

[2] Telemetry equipment for Discharge Point No. CSD-003 was not operational in December 2012. Due to similar weir heights and positions within the system, discharges likely occur simultaneously at Discharge Point Nos. CSD-002 and CSD-003. As such, about six discharges likely occurred from Discharge Point No. CSD-003 between July 1, 2012, and June 30, 2013, lasting an average duration of about 3 hours.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

A. Legal Authorities

This Order serves as WDRs pursuant to California Water Code article 4, chapter 4, division 7 (commencing with § 13260) for discharges to waters of the State. This Order is also issued pursuant to federal Clean Water Act (CWA) section 402 and implementing regulations adopted by U.S. EPA, and Water Code chapter 5.5, division 7 (commencing with § 13370). It serves as an NPDES permit for point source discharges from the Facility to surface waters.

B. California Environmental Quality Act

Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of the California Environmental Quality Act, Public Resources Code division 13, chapter 3 (commencing with § 21100). On September 3, 2015, the San Francisco Planning Commission certified the Final Environmental Impact Report for the Westside Recycled Water Project, finding that the Discharger, acting through the San Francisco Planning Department, fulfilled all California Environmental Quality Act procedural requirements.

C. State and Federal Laws, Regulations, Policies, and Plans

1. **Water Quality Control Plan.** The Regional Water Board adopted the *Water Quality Control Plan for the San Francisco Bay Basin* (Basin Plan), which designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters in the San Francisco Bay Region. Requirements of this Order implement the Basin Plan. The table below lists the beneficial uses the Basin Plan attributes to the Pacific Ocean:

Table F-5. Basin Plan Beneficial Uses

Receiving Water	Beneficial Uses
Pacific Ocean	<ul style="list-style-type: none"> • Industrial Service Supply (IND) • Commercial and Sport Fishing (COMM) • Shellfish Harvesting (SHELL) • Marine Habitat (MAR) • Fish Migration (MIGR) • Preservation of Rare and Endangered Species (RARE) • Fish Spawning (SPWN) • Wildlife Habitat (WILD) • Water Contact Recreation (REC1) • Noncontact Water Recreation (REC2) • Navigation (NAV)

Basin Plan Table 4-1, Discharge Prohibition 1, prohibits wastewater discharges with particular characteristics of concern to beneficial uses at any point at which the wastewater does not receive a minimum initial dilution of at least 10:1. Basin Plan section 4.2 provides for exceptions under certain circumstances:

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

- An inordinate burden would be placed on the Discharger relative to the beneficial uses protected, and an equivalent level of environmental protection can be achieved by alternate means;
- A discharge is approved as part of a reclamation project;
- Net environmental benefits will be derived as a result of the discharge; or
- A discharge is approved as part of a groundwater cleanup project.

The Basin Plan further states:

Significant factors to be considered by the Regional Water Board in reviewing requests for exceptions will be the reliability of the discharger's system in preventing inadequately treated wastewater from being discharged to the receiving water and the environmental consequence of such discharges.

During wet weather, this Order grants an exception to Basin Plan Discharge Prohibition 1 for discharges at Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007 for the following reasons:

- Eliminating all wet weather combined sewer discharges or ensuring that these discharges receive a minimum initial dilution of 10:1 would be an inordinate burden disproportionate to the beneficial uses protected. The Discharger continues to invest in infrastructure to improve the combined sewer system (San Francisco Public Utilities Commission Wastewater Enterprise, *Report of Waste Discharge, Supplemental Information, Capital Improvements and Operational Changes*, April 3, 2014). This Order continues to require capture and treatment of all combined wastewater and stormwater. This Order also requires the Discharger to evaluate control alternatives to eliminate, relocate, or reduce the magnitude or frequency of combined-sewer discharges.
- An equivalent level of environmental protection is provided because operating a combined sewer system, as opposed to a separate sewer system, removes many pollutants in urban runoff that elsewhere in the Region are discharged through stormwater outfalls with little or no treatment. This additional treatment comes at the cost of occasionally discharging partially-treated combined sewage and stormwater through Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007. The Monitoring and Reporting Program (MRP) (Attachment E) requires the Discharger to monitor combined sewer discharges and receiving waters to verify that an equivalent level of environmental protection is provided.

2. **California Ocean Plan.** The State Water Board adopted the *Water Quality Control Plan for Ocean Waters of California, California Ocean Plan* (Ocean Plan) in 1972 and has amended it several times, including in 1978 and most recently in 2018. The most recent changes became effective February 4, 2019. The Ocean Plan establishes water quality objectives and a program of implementation to protect beneficial uses of the Pacific Ocean within the territorial waters of the State.

The territorial waters of the State end 3 nautical miles from shore. Discharge Point No. 001 is approximately 3.8 miles (3.3 nautical miles) offshore in federal waters. The Ocean Plan

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

(Appendix 1, Ocean Waters) states, “If a discharge outside the territorial waters of the State could affect the quality of the waters of the State, the discharge may be regulated to assure no violation of the Ocean Plan will occur in ocean waters.” This Order contains discharge prohibitions, effluent limitations, receiving water limitations, and other provisions to ensure that discharges from Discharge Point No. 001 do not affect State waters. This Order’s requirements related to Discharge Point No. 001 are based on U.S. EPA’s federal authorities pursuant to the Clean Water Act.

- a. **Beneficial Uses.** The table below lists the beneficial uses the Ocean Plan assigns to the Pacific Ocean:

Table F-6. Ocean Plan Beneficial Uses

Receiving Water	Beneficial Uses
Pacific Ocean	<ul style="list-style-type: none"> • Industrial Water Supply • Water Contact and Non-Contact Recreation, including Aesthetic Enjoyment • Navigation • Commercial and Sport Fishing • Mariculture • Preservation and Enhancement of Designated Areas of Special Biological Significance (ASBS) • Rare and Endangered Species • Marine Habitat • Fish Migration • Fish Spawning • Shellfish Harvesting

- b. **State Water Board Order No. WQ 79-16.** During wet weather, State Water Board Order No. WQ 79-16 sets forth requirements for discharges from Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007. Ocean Plan chapter III.J allows the State Water Board to grant exceptions to Ocean Plan requirements on a case-by-case basis if the public interest is served and the exception does not compromise beneficial uses (exceptions are listed in Ocean Plan Table VII-1). In 1979, the State Water Board granted the Discharger an exception from Ocean Plan requirements and imposed conditions, including but not limited to the following:

- Except for the bacteriological standards, to the greatest extent practical, the Discharger is to design, construct, and operate facilities to conform to the remaining standards set forth in chapter II of the 1978 Ocean Plan. These standards relate to physical characteristics (i.e., floating particulates, discoloration, natural light, and inert solids deposition), chemical characteristics (i.e., dissolved oxygen, pH, dissolved sulfide, toxic and organic chemicals in marine sediments, and nutrients), biological characteristics (i.e., marine communities and taste, odor, and color of marine resources used for human consumption), and radioactivity. Provisions V and VI.C.5 of this Order, and Attachments D and G sections I.C and I.D, require the Discharger to design, construct, and operate its facilities to conform to these standards to the greatest extent practical.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

- To the greatest extent practical, the Discharger is to design, construct, and operate facilities to comply with the conditions controlled by the requirements set forth in chapter III, sections A and B, of the 1978 Ocean Plan. These requirements call for waste management systems to be designed and operated in a manner that will maintain indigenous marine life and a healthy and diverse marine community. They also call for waste discharges to be essentially free of floatable and settleable material, substances toxic to marine life due to increases in concentrations in water or sediments, substances that significantly decrease natural light, and materials that result in esthetically undesirable discoloration of the ocean surface. Provisions V and VI.C.5 of this Order and Attachments D and G sections I.C and I.D require the Discharger to design, construct, and operate its facilities to conform to these requirements to the greatest extent practical.
- The Discharger is to design and construct facilities to contain all stormwater runoff beyond that associated with an average of eight combined sewer discharges per year. Section III and Provision VI.C.5.c of this Order implement this condition.
- Beaches affected by combined sewer discharges are to be posted with warning signs beginning when the discharge commences until analysis indicates that water quality meets Ocean Plan bacteriological standards for recreation. Provision VI.C.5.a.viii of this Order implements this condition.
- Shellfish areas harvested for human consumption that may be affected by combined sewer discharges are to be posted with warning signs beginning when the discharge commences until the City and County Health Department indicates that no further posting is required. Provision VI.C.5.a.viii of this Order implements this condition.
- The Discharger is to comply with federal and State source control programs to minimize the entry of toxic substances into the waste collection system from industrial sources. Provisions VI.C.4.b and VI.C.5.a.iii of this Order and Attachment H implement this condition.
- The Discharger is to implement a self-monitoring program in accordance with Regional Water Board specifications. Provision VI.B of this Order and Attachment E implement this condition.

State Water Board Order No. WQ 79-16 explains the rationale for this exception and its conditions. It also states that the Regional Water Board or U.S. EPA may require construction of additional facilities or modification of existing Facility operations if it finds (1) changes in the location, intensity, or importance of affected beneficial uses, or (2) demonstrated unacceptable adverse impacts result from Facility operations as currently constructed.

3. **Combined Sewer Overflow (CSO) Control Policy.** On April 11, 1994, U.S. EPA adopted the *Combined Sewer Overflow (CSO) Control Policy* to establish a national approach for controlling combined sewer discharges and overflows (59 Fed. Reg. 18688-18698, April 19, 1994). The Wet Weather Water Quality Act of 2000 amended the CWA to require that

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

permits issued after December 21, 2000, for discharges from combined sewer systems conform to the *Combined Sewer Overflow (CSO) Control Policy* (33 U.S.C. § 1342[q][1]). Requirements of this Order implement the *Combined Sewer Overflow (CSO) Control Policy*, including the implementation of the nine minimum controls, a Long-Term Control Plan, and a post-construction monitoring program. (See Fact Sheet § VI.C.5.)

4. **Antidegradation Policy.** Federal regulations at 40 C.F.R. section 131.12 require that state water quality standards include an antidegradation policy consistent with stated requirements. The State Water Board established California's antidegradation policy through State Water Board Resolution No. 68-16, "*Statement of Policy with Respect to Maintaining High Quality of Waters in California*," which meets the federal antidegradation policy requirements. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Basin Plan implements, and incorporates by reference, the antidegradation policy. Permitted discharges must be consistent with the antidegradation provisions of 40 C.F.R. section 131.12 and Resolution No. 68-16. (See Fact Sheet § IV.D.2.)
5. **Anti-Backsliding Requirements.** CWA sections 402(o) and 303(d)(4) and 40 C.F.R. section 122.44(l) restrict backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed. (See Fact Sheet § IV.D.1.)
6. **Endangered Species Act Requirements.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code §§ 2050 to 2097) or the federal Endangered Species Act (16 U.S.C. §§ 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other provisions to protect beneficial uses, including protecting rare and endangered species. The Discharger is responsible for meeting all Endangered Species Act requirements.

U.S. EPA's reissuance of this NPDES permit is subject to certain requirements of the federal Endangered Species Act of 1973 and the Magnuson-Stevens Fishery Conservation and Management Act. In October 2017, U.S. EPA requested updated information from the National Marine Fisheries Service and the U.S. Fish and Wildlife Service (collectively, the Services) related to (1) essential fish habitat and managed and associated species, and (2) threatened and endangered species and their designated critical habitats near Discharge Point No. 001. U.S. EPA made a "may affect, not likely to adversely affect" determination for the southern California steelhead, Central California Coho salmon, Central Valley, spring-run chinook salmon, Sacramento River winter-run chinook salmon, humpback whale, leatherback turtle, green sea turtle, loggerhead turtle, white abalone, and olive ridley sea turtle; and a "no effect" determination for the remaining listed species under the Services' jurisdictions (*U.S. EPA Biological Evaluation*, September 2018). U.S. EPA provided a revised biological evaluation to the Services in April 2019. U.S. EPA may decide that changes to this Order are warranted based on the results of the completed consultation, and may modify or reopen it prior to the expiration date as described in Provision VI.C.1 of this Order.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

7. **Sludge and Biosolids.** U.S. EPA administers 40 C.F.R. part 503, “Standards for the Use or Disposal of Sewage Sludge,” which regulates the final use or disposal of sewage sludge generated during the treatment of domestic sewage in a municipal wastewater treatment facility. This Order does not authorize any act that violates those requirements. The Discharger is responsible for meeting all applicable requirements of 40 C.F.R. part 503.
8. **Ocean Discharge Criteria Evaluation.** CWA section 403(c) and implementing regulations at 40 C.F.R. part 125, subpart M, establish ocean discharge criteria for preventing unreasonable degradation of the marine environment of the territorial seas, contiguous zones, and oceans. The regulations at 40 C.F.R. section 125.122(b) allow a permitting authority to presume that a discharge will not cause unreasonable degradation for specific pollutants or conditions if the discharge complies with state water quality standards. This Order implements State water quality standards for discharges from Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007. This Order also implements State water quality standards for discharges from Discharge Point No. 001, with the modifications described below.

This Order’s requirements for Discharge Point No. 001 are consistent with the Ocean Plan, except with respect to chronic toxicity and TCDD equivalents. In all other respects, therefore, U.S. EPA presumes that the discharge will not cause unreasonable degradation. With respect to chronic toxicity and TCDD equivalents, U.S. EPA is required to consider the site-specific factors listed in 40 C.F.R. section 125.122(a). U.S. EPA prepared an evaluation under CWA section 403(c) for chronic toxicity and TCDD equivalents and concluded that no unreasonable degradation of ocean waters will occur.

9. **Coastal Zone Management Act.** The California Coastal Commission has indicated that it is unnecessary to obtain a consistency certification pursuant to the Coastal Zone Management Act (16 U.S.C. § 1451 et seq.).

D. Impaired Waters on CWA 303(d) List

On April 6, 2018, U.S. EPA approved a revised list of California’s impaired waters pursuant to CWA section 303(d), which requires identification of specific waters where it is expected that water quality standards will not be met after implementation of technology-based effluent limitations on point sources. Where it has not done so already, the Regional Water Board plans to adopt total maximum daily loads (TMDLs) for waters on the 303(d) list. TMDLs establish wasteload allocations for point sources and load allocations for nonpoint sources, and are established to achieve the water quality standards for the impaired waters. This Order does not authorize any discharge to receiving waters on California’s list of impaired waters.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations: 40 C.F.R. section 122.44(a) requires that permits include applicable technology-based limitations and standards; and 40 C.F.R.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

section 122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water.

A. Discharge Prohibitions

1. **Prohibition III.A (Discharge different than described).** This prohibition is based on 40 C.F.R. section 122.21(a) and Water Code section 13260, which require filing an application and Report of Waste Discharge before a discharge can occur. Discharges not described in the application and Report of Waste Discharge, and subsequently in this Order, are prohibited.
2. **Prohibition III.B (Bypass of untreated or partially-treated wastewater).** This prohibition is based on the *Combined Sewer Overflow (CSO) Control Policy* and 40 C.F.R. section 122.41(m) (see Attachment D section I.G). Pursuant to 40 C.F.R. section 122.41(m)(4)(ii), the Regional Water Board and U.S. EPA approve bypass of the biological treatment units (i.e., blending primary-treated effluent with biologically-treated effluent) during wet weather, when treatment plant influent flow exceeds 43 MGD (the hydraulic capacity of the biological treatment units), because such bypass meets the criteria for approval set forth in 40 C.F.R. sections 122.41(m)(4)(i)(A)-(C):
 - When influent flow exceeds 43 MGD, bypass of biological treatment is unavoidable to prevent loss of life, personal injury, or severe property damage. Such bypass prevents the washout of solids and the microbial population from the biological treatment system and thus ensures treatment reliability. Moreover, such bypass prevents backups and flooding in the community that could cause personal injury or severe property damage.
 - There are no feasible alternatives to bypass when influent flow exceeds 43 MGD. Provisions VI.C.5.c and VI.C.5.d require the Discharger to implement all feasible measures to maximize treatment. As long as the Discharger complies with these provisions, it is implementing all feasible alternatives to avoid bypass during wet weather.
 - The Discharger provided notice at least ten days before any wet weather bypass in its *Report of Waste Discharge, Oceanside Water Pollution Control Plant and Westside Wet Weather Facilities* (April 3, 2014) and *Wastewater Enterprise Westside Operations Summary Baseline Report* (March 2014).
3. **Prohibition III.C (Discharge at Discharge Point No. 001 without minimum initial dilution of at least 148:1).** This prohibition is necessary to ensure that the assumptions used to derive the dilution credits established through this Order for Discharge Point No. 001 remain substantially the same so the effluent limitations at Discharge Point No. 001 remain protective of water quality. This Order considered a dilution credit of 148:1, as modeled assuming no currents, based on the Discharger's *Southwest Ocean Outfall Dilution Modeling Report, Final Report* (April 2014) to conduct the reasonable potential analysis described in Fact Sheet section IV.C.4. Moreover, the in-stream waste concentration (IWC) to be used to evaluate compliance with this Order's chronic toxicity effluent limitation is based on this dilution credit. When the Discharger produces 1.0 MGD of recycled water and discharges

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

reverse osmosis concentrate, the IWC for chronic toxicity testing reflects a dilution credit of 266:1, as modeled assuming currents. Both dilution credits correspond to the same outfall configuration, which this prohibition seeks to maintain.

4. **Prohibition III.D (Discharge from location other than Discharge Point No. 001, except during wet weather).** This prohibition clarifies that any discharges other than those to Discharge Point No. 001 are unauthorized, except those to Discharge Point Nos. CSD-001, CSD-002, CSD-003, CSD-004, CSD-005, CSD-006, and CSD-007 as explicitly authorized during wet weather in accordance with the *Combined Sewer Overflow (CSO) Control Policy*.
5. **Prohibition III.E (Discharge in excess of permitted flow).** This Order prohibits an average dry weather effluent flow greater than 43 MGD based on the plant's secondary treatment design capacity. Exceeding the secondary treatment design capacity could result in lowering the reliability of achieving this Order's treatment requirements.

B. Technology-Based Effluent Limitations

1. **Scope and Authority.** CWA section 301(b) and 40 C.F.R. section 122.44 require that permits include conditions meeting applicable technology-based requirements, at a minimum, and any more stringent effluent limitations necessary to meet water quality standards.
2. **Oceanside Water Pollution Control Plant.** During dry weather, the technology-based requirements for the Oceanside Water Pollution Control Plant are based on the Secondary Treatment Standards at 40 C.F.R. section 133.102, listed in the following table:

Table F-7. Secondary Treatment Requirements

Parameter	Monthly Average	Weekly Average
BOD ₅ ^[1,2]	30 mg/L	45 mg/L
CBOD ₅ ^[1,2]	25 mg/L	40 mg/L
TSS ^[2]	30 mg/L	45 mg/L
pH	6.0 – 9.0 standard units	

Abbreviation:

mg/L = milligrams per liter

Footnotes:

^[1] CBOD₅ effluent limitations may be substituted for BOD₅ effluent limitations.

^[2] The monthly average percent removal, by concentration, is not to be less than 85 percent.

This Order does not include the additional technology-based effluent limitations established in Ocean Plan chapter III.B.1 (i.e., oil and grease, turbidity, settleable solids) because the plant provides secondary treatment.

During wet weather, the *Combined Sewer Overflow (CSO) Control Policy* establishes the minimum technology-based requirements for combined sewer systems as the implementation of the nine minimum controls based on 40 C.F.R. section 125.3. Provision VI.C.5.a of this Order contains these requirements.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

- 3. Westside Recycled Water Project.** Ocean Plan chapter III.B.1 establishes technology-based effluent limitations for publicly-owned treatment works and industrial discharges for which effluent limitation guidelines have not been established pursuant to CWA sections 301, 302, 304, or 306. This Order requires Westside Recycled Water Project discharges to meet the minimum technology-based effluent limitations established in Ocean Plan Table 2, listed in the following table:

Table F-8. Ocean Plan Table 2 Effluent Limitations

Parameter	Units	Monthly Average	Weekly Average	Instantaneous
Oil and Grease	mg/L	25	40	75
TSS	mg/L	60 ^[1]	---	---
Settleable Solids	mL/L	1.0	1.5	3.0
Turbidity	NTU	75	100	225
pH	standard units	within 6.0 to 9.0 range (all times)		

Abbreviations:

mg/L = milligrams per liter
mL/L = milliliters per liter
NTU = nephelometric turbidity units

Footnote:

- ^[1] Ocean Plan Table 2 notes state, "Suspended Solids: Dischargers shall, as a 30-day average, remove 75% of suspended solids from the influent stream before discharging wastewaters to the ocean, except that the effluent limitation to be met shall not be lower than 60 mg/L." Because the monthly average effluent limitation for suspended solids has been established as 60 mg/L, the Discharger is not required to remove 75% of influent suspended solids.

- 4. Combined Sewer System.** The Westside Transport/Storage Structure and combined sewer discharge points discharge only during wet weather. As such, the *Combined Sewer Overflow (CSO) Control Policy* establishes the minimum technology-based requirements for combined sewer systems as the implementation of nine minimum controls based on 40 C.F.R. section 125.3. Provision VI.C.5.a of this Order contains these requirements.

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

CWA section 301(b) and 40 C.F.R. section 122.44(d) require that permits include limitations more stringent than federal technology-based requirements where necessary to achieve applicable water quality standards. According to 40 C.F.R. section 122.44(d)(1)(i), permits must include effluent limitations for all pollutants that are or may be discharged at levels that have a reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective, WQBELs must be established using (1) U.S. EPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, which may be derived using a proposed state criterion or policy interpreting a state narrative water quality criterion, supplemented with other relevant information (40 C.F.R. § 122.44[d][1][vi]). The process for determining reasonable potential and calculating WQBELs is intended to achieve applicable water quality objectives and criteria, protect the

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

designated uses of receiving waters as specified in the Basin Plan and Ocean Plan, and ensure no unreasonable degradation under CWA section 403(c) and 40 C.F.R. part 125, subpart M.

During dry weather, this Order imposes numeric effluent limitations at Discharge Point No. 001 for pollutants with reasonable potential to cause or contribute to exceedances of water quality standards.

During wet weather, this Order imposes narrative effluent limitations, not numeric limitations. In accordance with the *Combined Sewer Overflow (CSO) Control Policy*, this Order requires the Discharger to implement and update its Long-Term Control Plan. The *Combined Sewer Overflow (CSO) Control Policy* describes the presumption and demonstration approaches regarding water quality-based requirements and requires that a post-construction water quality monitoring program be in place to verify compliance with applicable water quality standards. This Order requires the combined sewer system to capture 100 percent of combined wastewater and stormwater and provide equivalent-to-primary treatment consisting of floatables and settleable solids removal. Provision VI.C.5.d (Task 3.b) of the Order requires the Discharger to assess the feasibility and necessity of disinfecting combined sewer discharges.

2. Beneficial Uses and Water Quality Objectives

Fact Sheet sections III.C.1 and III.C.2, above, identify the beneficial uses of the Pacific Ocean. Ocean Plan chapter II (including Table 1) lists water quality objectives for the Pacific Ocean.

3. Minimum Initial Dilution

In accordance with Ocean Plan chapter III.C, the minimum initial dilution at Discharge Point No. 001 can be estimated by experimental observation or computer simulation. The Discharger submitted an updated dilution study in April 2014, *Southwest Ocean Outfall (Discharge Point No. 001) Dilution Modeling Report – Final*, which estimated dilution based on NRFIELD and UM3 models and ambient water data measured from April 2012 through October 2013. Based on the more conservative estimate assuming no currents, the minimum initial dilution ratio is 148:1 (148 parts seawater per 1 part wastewater). This represents the minimum 30-day average dilution during the period of maximum stratification, observed from November 2012 through January 2013. The Discharger's dilution study also estimated dilution based on existing current velocity data measured at mid-depth of the water column. Accounting for ocean currents, the more conservative estimate of the minimum 30-day average dilution during the period of maximum stratification is 266:1.

A minimum initial dilution of 148:1 is used in the reasonable potential analysis described in Fact Sheet section III.C.4, below. The IWC to be used in chronic toxicity testing is also based on this minimum initial dilution, except when the Westside Recycled Water Project operates at full capacity to produce 1.0 MGD of recycled water, in which case the IWC is to be based on a minimum initial dilution of 266:1 as described in MRP section V.A.2. This increase in minimum initial dilution accounts for ocean currents, which move parallel to the coast, not

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

toward State waters (*Assessment of Effects on California State Waters from the Oceanside Southeast Ocean Outfall*, September 26, 2008).

4. Need for Water Quality-Based Effluent Limitations (Reasonable Potential Analysis)

a. Methodology

i. **Dry Weather.** Ocean Plan Appendix VI sets forth a procedure for reasonable potential analyses applicable to dry weather discharges from Discharge Point No. 001. The procedure assumes a lognormal distribution for the effluent data and compares the 95th percentile concentration at 95 percent confidence for each parameter listed in Ocean Plan Table 1, accounting for dilution, to the applicable water quality objective listed in Ocean Plan Table 1. The analysis results in one of three endpoints for each pollutant based on four triggers:

- Endpoint 1 – There is reasonable potential. WQBELs and monitoring are required.
- Endpoint 2 – There is no reasonable potential. WQBELs are not required, but monitoring may be required.
- Endpoint 3 – The analysis is inconclusive. Any existing WQBELs are retained and monitoring is required.

The four triggers are as follows:

(a) **Trigger 1.** If any detected value after adjustment for dilution (X) is greater than the applicable water quality objective (Co), then Endpoint 1 applies.

For Table 1 pollutants: $X = (C_e + D_m C_s) / (D_m + 1)$

For acute toxicity: $X = C_e / (0.1 D_m + 1)$

Where:

Ce is the effluent concentration

Dm is the minimum initial dilution expressed as parts seawater per part wastewater (148:1)

Cs is the background seawater concentration from Ocean Plan Table 3.

(b) **Trigger 2.** If there are three or more detected values and the number of non-detected (ND) or detected but not quantified (DNQ) values (c) is less than or equal to 80 percent of the number of data points (n) (i.e., if $c/n \leq 80\%$), a parametric reasonable potential analysis is performed. If the calculated upper confidence bound is greater than Co, then Endpoint 1 is concluded; otherwise Endpoint 2 is concluded.

(c) **Trigger 3.** If there are less than three detected values or if there are more than three detected values but the percentage of non-detected (ND) or detected but not quantified (DNQ) values is more than 80 percent (i.e., if $c/n > 80\%$), a non-

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

parametric reasonable potential analysis is performed. Depending on the results, either Endpoint 2 or Endpoint 3 is concluded.

(d) **Trigger 4.** If any other information about the receiving water or the discharge supports a finding of reasonable potential, then the reasonable potential analysis may be based on best professional judgment. If data or other information is unavailable or insufficient to determine if a WQBEL is required, Endpoint 3 is concluded. Otherwise, either Endpoint 1 or Endpoint 2 is concluded.

ii. **Wet Weather.** For wet weather discharges from Discharge Point No. 001 and the combined sewer discharge points, the requirements described in Provision VI.C.5.c of the Order serve as narrative WQBELs.

b. **Effluent Data.** Since the Westside Recycled Water Project is expected to become operational during this permit term, two reasonable potential analyses were performed based on the Ocean Plan methodology: one based on current effluent quality and one based on potential future Westside Recycled Water Project effluent quality. In both cases, the analyses were based on dry weather effluent monitoring data the Discharger collected for Discharge Point No. 001 from January 2011 through December 2017. However, with full operation of the Westside Recycled Water Project, the Discharger anticipates that the discharge could potentially consist entirely of reverse osmosis concentrate approximately 1.4 percent of the time. Under these rare circumstances, the effluent could be as much as four times more concentrated when compared to existing conditions. For purposes of the Westside Recycled Water Project reasonable potential analysis, however, existing effluent data were multiplied by a concentration factor of 1.5, which reflects the foreseeable increase based on a 30-day averaging period. This concentration factor is sufficient to evaluate reasonable potential when the most stringent objectives (those with six-month averaging periods) apply.

c. **Reasonable Potential Analysis Results.** The following tables present the results of the two reasonable potential analyses performed (i.e., existing conditions and potential future Westside Recycled Water Project conditions). The analyses show reasonable potential for chronic toxicity based on Trigger 4. Chronic toxicity tests are intended to detect toxicity from a wide range of pollutants, and since the Facility has a municipal combined sewer system, there is a reasonable potential that unanticipated pollutants could be discharged into the system. Moreover, effluent monitoring data collected during the previous order term showed chronic toxicity at levels close to the previous order's effluent limit (see Table F-2) and similar toxicity could occur in the future.

Table F-9. Reasonable Potential Analysis No. 1 - Existing Conditions

Table 1 Pollutant	Most Stringent WQO (µg/L)	No. of Samples	No. of Non-Detects	Max Effluent Concentration (µg/L)	Max Effluent Concentration After Mixing (µg/L)	Projected 95 th Percentile (µg/L)	Result
Objectives for Protection of Marine Aquatic Life							
Ammonia (as nitrogen)	600	30	0	54,000	360	400	Endpoint 2
Arsenic	8	83	83	<2.0	<3.0	---	Endpoint 2
Cadmium	1	83	76	1.2	0.0082	---	Endpoint 2

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Table 1 Pollutant	Most Stringent WQO (µg/L)	No. of Samples	No. of Non-Detects	Max Effluent Concentration (µg/L)	Max Effluent Concentration After Mixing (µg/L)	Projected 95 th Percentile (µg/L)	Result
Chlorinated Phenolics	1	7	7	<6.0	<0.040	---	Endpoint 3
Chromium (VI)	2	81	76	8.1	0.055	---	Endpoint 2
Acute Toxicity ^[1]	Not applicable						
Chronic Toxicity	1 TUc	28	0	149 TUc	1.0 TUc	1.1 TUc	Endpoint 1
Copper	3	83	0	26	2.2	2.1	Endpoint 2
Cyanide	1	28	25	8.2	0.055	---	Endpoint 2
Endosulfan (total)	0.009	7	7	<0.0062	<4.2E-5	---	Endpoint 3
Endrin	0.002	7	7	<0.0028	<1.9E-5	---	Endpoint 3
HCH	0.004	7	7	<0.0026	<1.7E-5	---	Endpoint 3
Lead	2	83	26	1.6	0.011	0.0090	Endpoint 2
Mercury	0.04	83	1	0.071	0.00097	0.000070	Endpoint 2
Nickel	5	83	0	27	0.18	0.033	Endpoint 2
Non-chlorinated Phenolics	30	7	6	1.2	0.0081	---	Endpoint 3
Radioactivity ^[2]	Not applicable						
Selenium	15	83	83	<2.0	<0.013	---	Endpoint 2
Silver	0.7	83	82	0.40	0.16	---	Endpoint 2
Total Chlorine Residual ^[3]	Not applicable						
Zinc	20	83	0	97	8.6	8.3	Endpoint 2
Objectives for Protection of Human Health – Noncarcinogens							
1,1,1-Trichloroethane	540,000	7	7	<0.24	<0.0016	---	Endpoint 3
2,4-Dinitrophenol	4.0	7	7	<0.90	<0.0060	---	Endpoint 3
2-Methyl-4,6-Dinitrophenol	220	7	7	<1.6	<0.010	---	Endpoint 3
Acrolein	220	7	7	<2.0	<0.013	---	Endpoint 3
Antimony	1,200	82	74	2.8	0.018	---	Endpoint 2
Bis(2-Chloroethoxy)Methane	4.4	7	7	<0.93	<0.0062	---	Endpoint 3
Bis(2-Chloroisopropyl)Ether	1,200	7	7	<0.81	<0.0054	---	Endpoint 3
Chlorobenzene	570	7	7	<0.25	<0.0017	---	Endpoint 3
Chromium (III) ^[4]	Not applicable						
Dichlorobenzenes	5,100	7	7	<3.0	<0.020	---	Endpoint 3
Diethyl Phthalate	33,000	7	7	<0.86	<0.0058	---	Endpoint 3
Dimethyl Phthalate	820,000	7	7	<0.97	<0.0065	---	Endpoint 3
Di-n-Butyl Phthalate	3,500	7	7	<0.91	<0.0061	---	Endpoint 3
Ethylbenzene	4,100	7	7	<1.0	<0.0067	---	Endpoint 3
Fluoranthene	15	8	8	<0.55	<0.0037	---	Endpoint 3
Hexachlorocyclopentadiene	58	7	7	<0.91	<0.0061	---	Endpoint 3
Nitrobenzene	4.9	7	7	<0.95	<0.0064	---	Endpoint 3
Thallium	2	82	82	<1.0	<0.0067	---	Endpoint 2
Toluene	85,000	7	7	<0.50	<0.0034	---	Endpoint 3
Tributyltin	0.0014	7	7	<0.0026	<1.7E-5	---	Endpoint 3
Objectives for Protection of Human Health – Carcinogens							
1,1,2,2-Tetrachloroethane	2.3	7	7	<0.68	<0.0045	---	Endpoint 3
1,1,2-Trichloroethane	9.4	7	7	<0.14	<0.00094	---	Endpoint 3
1,1-Dichloroethylene	0.9	7	7	<0.089	<0.00060	---	Endpoint 3
1,2-Dichloroethane	28	7	7	<0.15	<0.0010	---	Endpoint 3
1,2-Diphenylhydrazine	0.16	7	7	<0.90	<0.0060	---	Endpoint 3
1,3-Dichloropropylene	8.9	7	7	<0.24	<0.0016	---	Endpoint 3
1,4-Dichlorobenzene	18	7	7	<1.0	<0.0067	---	Endpoint 3

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Table 1 Pollutant	Most Stringent WQO (µg/L)	No. of Samples	No. of Non-Detects	Max Effluent Concentration (µg/L)	Max Effluent Concentration After Mixing (µg/L)	Projected 95 th Percentile (µg/L)	Result
TCDD Equivalents	3.9E-9	7	7	<2.6E-8	<1.7E-10	---	Endpoint 3
2,4,6-Trichlorophenol	0.29	7	7	<1.0	<0.0067	---	Endpoint 3
2,4-Dinitrotoluene	2.6	7	7	<0.96	<0.0064	---	Endpoint 3
3,3'-Dichlorobenzidine	0.0081	7	7	<5.0	<0.034	---	Endpoint 3
Acrylonitrile	0.10	7	7	<0.80	<0.0054	---	Endpoint 3
Aldrin	2.2E-5	7	7	<0.00075	<5.0E-6	---	Endpoint 3
Benzene	5.9	7	7	<0.20	<0.0013	---	Endpoint 3
Benzidine	6.9E-5	7	7	<5.0	<0.034	---	Endpoint 3
Beryllium	0.033	82	82	<0.50	<0.0034	---	Endpoint 2
Bis(2-Chloroethyl)Ether	0.045	7	7	<0.95	<0.0064	---	Endpoint 3
Bis(2-Ethylhexyl)Phthalate	3.5	7	2	3.3	0.022	---	Endpoint 3
Carbon Tetrachloride	0.90	7	7	<0.19	<0.0013	---	Endpoint 3
Chlordane	2.3E-5	7	7	<0.018	<0.00012	---	Endpoint 3
Chlorodibromomethane	8.6	7	7	<0.13	<0.00089	---	Endpoint 3
Chloroform	130	7	3	3.7	0.025	---	Endpoint 2
DDT (total)	0.00017	7	7	<2.1	<0.014	---	Endpoint 3
Dichlorobromomethane	6.2	7	7	<0.50	<0.0034	---	Endpoint 3
Dichloromethane	450	7	7	<0.50	<0.0034	---	Endpoint 3
Dieldrin	4.0E-5	7	7	<0.0013	<8.9E-6	---	Endpoint 3
Halomethanes	130	7	7	<0.69	<0.0046	---	Endpoint 3
Heptachlor	5E-5	7	7	<0.0013	<9.0E-6	---	Endpoint 3
Heptachlor Epoxide	2E-5	7	7	<0.00056	<3.8E-6	---	Endpoint 3
Hexachlorobenzene	0.00021	7	7	<0.91	<0.0061	---	Endpoint 3
Hexachlorobutadiene	14	7	7	<0.92	<0.0062	---	Endpoint 3
Hexachloroethane	2.5	7	7	<0.94	<0.0063	---	Endpoint 3
Isophorone	730	7	7	<0.93	<0.0062	---	Endpoint 3
N-Nitrosodimethylamine	7.3	7	7	<0.88	<0.0059	---	Endpoint 3
N-Nitrosodi-n-Propylamine	0.38	7	7	<0.97	<0.0065	---	Endpoint 3
N-Nitrosodiphenylamine	2.5	7	7	<0.83	<0.0056	---	Endpoint 3
PAHs (total)	0.0088	6	6	<1.2	<0.0081	---	Endpoint 3
PCBs	1.9E-5	7	7	<0.40	<0.0027	---	Endpoint 3
Tetrachloroethylene	2.0	7	7	<0.14	<0.0010	---	Endpoint 3
Toxaphene	0.00021	7	7	<0.058	<0.00039	---	Endpoint 3
Trichloroethylene	27	7	7	<0.38	<0.0025	---	Endpoint 3
Vinyl Chloride	36	7	7	<0.66	<0.0044	---	Endpoint 3

Abbreviations:

WQO = water quality objective
µg/L = micrograms per liter
TUc = chronic toxicity units

Footnotes:

- [1] The previous order did not require acute toxicity monitoring.
[2] The previous order did not require monitoring for radioactivity.
[3] Chlorine is not added for disinfection, and the previous order did not require monitoring for residual chlorine.
[4] The previous order did not require monitoring for chromium (III); however, the maximum detected concentration of total chromium (8.1 µg/L) is less than the water quality objective for chromium (III) of 190,000 µg/L.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Table F-10. Reasonable Potential Analysis No. 2 - Westside Recycled Water Project Conditions

Table 1 Pollutant	Most Stringent WQO (µg/L)	No. of Samples	No. of Non-Detects	Max Effluent Concentration (µg/L)	Max Effluent Concentration After Mixing (µg/L)	Projected 95 th Percentile (µg/L)	Result
Objectives for Protection of Marine Aquatic Life							
Ammonia (as nitrogen)	600	9	0	81,000	550	600	Endpoint 2
Arsenic	8	83	83	<3.0	<3.0	---	Endpoint 2
Cadmium	1	83	76	1.8	0.012	---	Endpoint 2
Chlorinated Phenolics	1	7	7	<9.0	<0.060	---	Endpoint 3
Chromium (VI)	2	81	76	12	0.082	---	Endpoint 2
Acute Toxicity ^[1]	Not applicable						
Chronic Toxicity ^[2]	1 TUc	28	0	220 TUc	1.5 TUc	1.6 TUc	Endpoint 1
Copper	3	83	0	39	2.2	2.2	Endpoint 2
Cyanide	1	28	25	12	0.082	---	Endpoint 3
Endosulfan (total)	0.009	7	7	<0.0093	<6.2E-5	---	Endpoint 3
Endrin	0.002	7	7	<0.0042	<2.8E-5	---	Endpoint 3
HCH	0.004	7	7	<0.0039	<2.6E-5	---	Endpoint 3
Lead	2	83	26	2.4	0.016	0.012	Endpoint 2
Mercury	0.04	83	1	0.11	0.0012	0.000074	Endpoint 2
Nickel	5	83	0	41	0.27	0.050	Endpoint 2
Non-chlorinated Phenolics	30	7	6	1.8	0.012	---	Endpoint 3
Radioactivity ^[3]	Not applicable						
Selenium	15	83	83	<3.0	<0.020	---	Endpoint 2
Silver	0.7	83	82	0.60	0.16	---	Endpoint 2
Total Chlorine Residual ^[4]	Not applicable						
Zinc	20	83	0	150	8.9	8.5	Endpoint 2
Objectives for Protection of Human Health – Noncarcinogens							
1,1,1-Trichloroethane	540,000	7	7	<0.35	<0.0024	---	Endpoint 3
2,4-Dinitrophenol	4.0	7	7	<1.4	<0.0091	---	Endpoint 3
2-Methyl-4,6-Dinitrophenol	220	7	7	<2.3	<0.016	---	Endpoint 3
Acrolein	220	7	7	<3.0	<0.020	---	Endpoint 3
Antimony	1,200	82	74	4.1	0.028	---	Endpoint 2
Bis(2-Chloroethoxy)Methane	4.4	7	7	<1.4	<0.0094	---	Endpoint 3
Bis(2-Chloroisopropyl)Ether	1,200	7	7	<1.2	<0.0082	---	Endpoint 3
Chlorobenzene	570	7	7	<0.37	<0.0025	---	Endpoint 3
Chromium (III) ^[5]	Not applicable						
Dichlorobenzenes	5,100	7	7	<4.5	<0.030	---	Endpoint 3
Diethyl Phthalate	33,000	7	7	<1.3	<0.087	---	Endpoint 3
Dimethyl Phthalate	820,000	7	7	<1.5	<0.0098	---	Endpoint 3
Di-n-Butyl Phthalate	3,500	7	7	<1.4	<0.0092	---	Endpoint 3
Ethylbenzene	4,100	7	7	<1.5	<0.010	---	Endpoint 3
Fluoranthene	15	8	8	<0.82	<0.0055	---	Endpoint 3
Hexachlorocyclopentadiene	58	7	7	<1.4	<0.0092	---	Endpoint 3
Nitrobenzene	4.9	7	7	<1.4	<0.0096	---	Endpoint 3
Thallium	2	82	82	<1.5	<0.010	---	Endpoint 2
Toluene	85,000	7	7	<0.42	<0.0028	---	Endpoint 3
Tributyltin	0.0014	7	7	<0.0039	<2.6E-5	---	Endpoint 3
Objectives for Protection of Human Health – Carcinogens							
1,1,2,2-Tetrachloroethane	2.3	7	7	<1.0	<0.0068	---	Endpoint 3
1,1,2-Trichloroethane	9.4	7	7	<0.21	<0.0014	---	Endpoint 3
1,1-Dichloroethylene	0.9	7	7	<0.13	<0.00090	---	Endpoint 3
1,2-Dichloroethane	28	7	7	<0.22	<0.0015	---	Endpoint 3

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Table 1 Pollutant	Most Stringent WQO (µg/L)	No. of Samples	No. of Non-Detects	Max Effluent Concentration (µg/L)	Max Effluent Concentration After Mixing (µg/L)	Projected 95 th Percentile (µg/L)	Result
1,2-Diphenylhydrazine	0.16	7	7	<1.4	<0.0091	---	Endpoint 3
1,3-Dichloropropylene	8.9	7	7	<0.36	<0.0024	---	Endpoint 3
1,4-Dichlorobenzene	18	7	7	<1.5	<0.010	---	Endpoint 3
TCDD Equivalents	3.9E-9	7	7	<0.95E-8	<6.4E-11	---	Endpoint 2
2,4,6-Trichlorophenol	0.29	7	7	<1.5	<0.010	---	Endpoint 3
2,4-Dinitrotoluene	2.6	7	7	<1.4	<0.0097	---	Endpoint 3
3,3'-Dichlorobenzidine	0.0081	7	7	<7.5	<0.050	---	Endpoint 3
Acrylonitrile	0.10	7	7	<1.2	<0.0081	---	Endpoint 3
Aldrin	2.2E-5	7	7	<0.0011	<7.6E-6	---	Endpoint 3
Benzene	5.9	7	7	<0.30	<0.0020	---	Endpoint 3
Benzidine	6.9E-5	7	7	<7.5	<0.050	---	Endpoint 3
Beryllium	0.033	82	82	<0.75	<0.0050	---	Endpoint 2
Bis(2-Chloroethyl)Ether	0.045	7	7	<1.4	<0.0096	---	Endpoint 3
Bis(2-Ethylhexyl)Phthalate	3.5	7	2	5.0	0.034	---	Endpoint 3
Carbon Tetrachloride	0.90	7	7	<0.29	<0.0020	---	Endpoint 3
Chlordane ^[1]	2.3E-5	7	7	<0.027	<0.00018	---	Endpoint 3
Chlorodibromomethane	8.6	7	7	<0.20	<0.0013	---	Endpoint 3
Chloroform	130	7	3	5.6	0.038	---	Endpoint 2
DDT (total)	0.00017	7	7	<3.12	<0.021	---	Endpoint 3
Dichlorobromomethane	6.2	7	7	<0.26	<0.0018	---	Endpoint 3
Dichloromethane	450	7	7	<0.75	<0.0050	---	Endpoint 3
Dieldrin	0.00004	7	7	<0.0020	<1.3E-5	---	Endpoint 3
Halomethanes	130	7	7	<1.0	<0.0070	---	Endpoint 3
Heptachlor	0.00005	7	7	<0.0013	<1.3E-5	---	Endpoint 3
Heptachlor Epoxide	0.00002	7	7	<0.00084	<5.6E-6	---	Endpoint 3
Hexachlorobenzene	0.00021	7	7	<1.4	<0.0092	---	Endpoint 3
Hexachlorobutadiene	14	7	7	<1.4	<0.0093	---	Endpoint 3
Hexachloroethane	2.5	7	7	<1.4	<0.0095	---	Endpoint 3
Isophorone	730	7	7	<1.4	<0.0094	---	Endpoint 3
N-Nitrosodimethylamine	7.3	7	7	<1.3	<0.0089	---	Endpoint 3
N-Nitrosodi-n-Propylamine	0.38	7	7	<1.5	<0.0098	---	Endpoint 3
N-Nitrosodiphenylamine	2.5	7	7	<1.2	<0.0084	---	Endpoint 3
PAHs (total)	0.0088	6	6	<1.8	<0.012	---	Endpoint 3
PCBs	1.9E-5	7	7	<0.59	<0.0040	---	Endpoint 3
Tetrachloroethylene	2.0	7	7	<0.21	<0.0014	---	Endpoint 3
Toxaphene	0.00021	7	7	<0.087	<0.00058	---	Endpoint 3
Trichloroethylene	27	7	7	<0.57	<0.0038	---	Endpoint 3
Vinyl Chloride	36	7	7	<0.98	<0.0066	---	Endpoint 3

Abbreviations:

WQO = water quality objective
µg/L = micrograms per liter

Footnotes:

- [1] The previous order did not require monitoring for acute toxicity.
- [2] The projection is particularly uncertain because chronic toxicity may occur as a result of various pollutants within the effluent and their toxic effects may not be linearly related to discharge concentrations.
- [3] The previous order did not require monitoring for radioactivity.
- [4] The previous order did not require monitoring for total residual chlorine.
- [5] The previous order did not require monitoring for chromium (III); however, the maximum projected concentration of total chromium (12 µg/L) is less than the water quality objective for chromium (III) of 190,000 µg/L.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

5. WQBELs

- a. Dry Weather.** For dry weather discharges from Discharge Point No. 001, the Ocean Plan calls for chronic toxicity WQBELs based on “toxic units” derived from multi-concentration toxicity tests. This Order introduces an updated approach. In 2010, U.S. EPA published the Test of Significant Toxicity (TST) statistical approach in *National Pollutant Discharge Elimination System Test of Significant Toxicity Implementation Document* (EPA 833-R-10-003, 2010). The TST statistical approach relies on the same U.S. EPA toxicity test methods. For example, section 9.4.1.2 of *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms* (EPA/600/R-95/0136, 1995) states, “the statistical methods recommended in this manual are not the only possible methods of statistical analysis.”

To comply with the chronic toxicity WQBEL, effluent must “Pass” a single chronic toxicity test conducted at the IWC as defined in MRP section V.A.2 using the Test of Significant Toxicity (TST) statistical approach (Welch’s t-test). The test result must reject the following null hypothesis:

H_0 : mean discharge IWC response $\leq 0.75 \times$ mean control response.

In other words, the mean chronic toxicity response for a test sample must be statistically determined to be less than or equal to 75 percent of the response for a control sample. The 75 percent response level reflects a regulatory management decision intended to ensure that differences observed between test sample responses and control sample responses are meaningful. A test result that fails to reject the null hypothesis would not comply with the chronic toxicity WQBEL.

The chronic toxicity WQBEL is expressed as a single-sample maximum. For publicly-owned treatment works, 40 C.F.R. section 122.45(d) requires monthly and weekly effluent limitations unless impracticable. In this case, the single-sample WQBEL is necessary to protect against short-term effects. Limits expressed with monthly or weekly averaging periods could allow chronic toxicity to occur over shorter periods. This approach is comparable to that of the Ocean Plan, which calls for a daily maximum chronic toxicity limit. Single-sample and maximum daily chronic toxicity limits are comparable because chronic toxicity tests can take several days to complete, depending on the test species used. U.S. EPA recommends this approach in *EPA Regions 8, 9 and 10 Toxicity Training Tool* (January 2010).

- b. Wet Weather.** For wet weather discharges from Discharge Point No. 001 and the combined sewer discharge points, the Long-Term Control Plan required pursuant to the *Combined Sewer Overflow (CSO) Control Policy* and described in Provision VI.C.5.c of the Order serves as narrative WQBELs.

D. Discharge Requirement Considerations

- 1. Anti-Backsliding.** This Order complies with the anti-backsliding provisions of CWA sections 402(o) and 303(d)(4) and 40 C.F.R. section 122.44(l), which generally require

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

effluent limitations in a reissued permit to be as stringent as those in the previous permit. The requirements of this Order are at least as stringent as those in the previous order, with the exception of mercury. This Order does not contain dry weather mercury effluent limitations because there is no longer reasonable potential to exceed water quality objectives based on mercury effluent data. Removing the mercury WQBELs is consistent with State Water Board Order No. WQ 2001-16. Consistent with State Water Board Order No. WQ 2001-06, reliance on the TST statistical approach to evaluate chronic toxicity for dry weather discharges from the Oceanside Water Pollution Control Plant is not backsliding because this Order's effluent limitation is not comparable to the effluent limitation in the previous order.

2. **Antidegradation.** This Order complies with the antidegradation provisions of 40 C.F.R. section 131.12 and State Water Board Resolution No. 68-16. It continues the status quo with respect to the level of discharge authorized in the previous order, which was adopted in accordance with antidegradation policies, and thus serves as the baseline by which to measure whether degradation will occur. This Order does not allow for a flow increase or a reduced level of treatment. The only potentially less stringent effluent limitation is the chronic toxicity WQBEL after Westside Recycled Water Project operations commence. The Westside Recycled Water Project is expected to concentrate, but not increase, existing pollutant loads; therefore, it will not degrade Pacific Ocean water quality.
3. **Stringency of Requirements for Individual Pollutants.** This Order contains both technology-based and water quality-based effluent limitations. This Order's technology-based requirements implement minimum, applicable federal technology-based requirements. This Order also contains more stringent effluent limitations as necessary to meet water quality standards. These limitations are no more stringent than the CWA requires.

This Order's WQBELs have been derived to implement water quality objectives that protect beneficial uses. The beneficial uses and water quality objectives set forth in the Ocean Plan and Basin Plan have been approved pursuant to federal law and are federal water quality standards. U.S. EPA approved the Ocean Plan on February 14, 2006, and also approved subsequent amendments. Most Basin Plan beneficial uses and water quality objectives were approved under State law and submitted to and approved by U.S. EPA prior to May 30, 2000. Beneficial uses and water quality objectives submitted to U.S. EPA prior to May 30, 2000, but not approved by U.S. EPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to 40 C.F.R. section 131.21(c)(1). U.S. EPA approved the remaining beneficial uses and water quality objectives implemented by this Order so they are applicable water quality standards pursuant to 40 C.F.R. section 131.21(c)(2).

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

This Order's receiving water limitations are based on Ocean Plan chapters II.C, II.D, and II.E, and State Water Board Order No. WQ 79-16. These limits are necessary to ensure compliance with applicable water quality standards in accordance with the CWA and regulations adopted thereunder.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

VI. RATIONALE FOR PROVISIONS

A. Standard Provisions

Attachment D contains standard provisions that apply to all NPDES permits in accordance with 40 C.F.R. section 122.41 and additional conditions applicable to specific categories of permits in accordance with 40 C.F.R. section 122.42. The Discharger must comply with these provisions.

In accordance with 40 C.F.R. section 123.25(a)(12), permits may impose more stringent requirements. Attachment G contains standard provisions that supplement the federal standard provisions in Attachment D.

In addition to federal conditions that address enforcement authority specified in 40 C.F.R. sections 122.41(a)(2), 122.41(j)(5), and (k)(2), this Order incorporates Water Code section 13387(e) by reference.

B. Monitoring and Reporting Program (MRP) Requirements

CWA section 308 and 40 C.F.R. sections 122.41(h), 122.41(j)-(l), 122.44(j), and 122.48 require that NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. The Monitoring and Reporting Program (Attachment E) of this Order establishes monitoring, reporting, and recordkeeping requirements that implement federal and State requirements. For more background regarding these requirements, see Fact Sheet section VII.

C. Special Provisions

1. Reopener Provisions

These provisions are based on 40 C.F.R. sections 122.62 and 122.63 and allow modification of this Order and its effluent limitations as necessary in response to updated water quality objectives, regulations, or other new and relevant information that may become available in the future, and other circumstances as allowed by law. Provision VI.C.1.f is based on *Combined Sewer Overflow (CSO) Control Policy* section IV.B.2.g.

2. Effluent Characterization Study and Report

This Order does not include effluent limitations for Ocean Plan Table 1 pollutants that do not demonstrate reasonable potential, but this provision requires the Discharger to evaluate monitoring data to verify that the reasonable potential analysis conclusions of this Order remain valid. This requirement is authorized pursuant to 40 C.F.R. section 122.41(h) and Water Code section 13267, and is necessary to inform the next permit reissuance and to

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

ensure that the Discharger takes timely steps in response to any unanticipated change in effluent quality during the term of this Order.

3. Pollutant Minimization Program

This provision is based on *Combined Sewer Overflow (CSO) Control Policy* section II.B.7, Basin Plan section 4.13.2, Ocean Plan chapter III.C.9, State Water Board Order No. WQ 79-16, and Water Code section 13263. The provision requires the Discharger to include copper and zinc as pollutants of concern because concentrations are often elevated in combined sewer discharges.

4. Special Provisions for Publicly-Owned Treatment Works (POTWs)

- a. **Sludge and Biosolids Management.** This provision is based on Basin Plan section 4.17. “Sludge” refers to the solid, semisolid, and liquid residue removed during primary, secondary, and advanced wastewater treatment processes. “Biosolids” refers to sludge that has been treated and may be beneficially reused.
- b. **Pretreatment Program.** This provision is based on 40 C.F.R. part 403. The Discharger implements a pretreatment program due to the nature and volume of its industrial influent. This provision lists the Discharger’s responsibilities regarding its pretreatment program and requires compliance with the provisions in Attachment H.
- c. **Anaerobically-Digestible Material.** Standard Operating Procedures are required for dischargers that accept hauled waste food, fats, oil, and grease for injection into anaerobic digesters. The development and implementation of Standard Operating Procedures for management of these materials is intended to allow the California Department of Resources Recycling and Recovery to exempt operations from separate and redundant permitting programs. If the Discharger does not accept fats, oil, and grease for resource recovery purposes, it is not required to develop and implement Standard Operating Procedures.

Some publicly-owned treatment works choose to accept organic material, such as waste food, fats, oils, and grease, into their anaerobic digesters to increase production of methane and other biogases for energy production and to prevent such materials from being discharged into the collection system and potentially causing sanitary sewer overflows. The California Department of Resources Recycling and Recovery has proposed to exclude publicly-owned treatment works from Process Facility/Transfer Station permit requirements when the same activities are regulated under waste discharge requirements or NPDES permits. The proposed exclusion is restricted to anaerobically-digestible materials that have been prescreened, slurried, processed, and conveyed in a closed system for co-digestion with regular sewage sludge. The exclusion assumes that the facility has developed Standard Operating Procedures for proper handling, processing, tracking, and management.

- d. **Separate Sanitary Sewer System.** This provision requires compliance with Attachments D and G and states that these requirements may be satisfied by complying

with State Water Board Order No. 2006-0003-DWQ, Statewide General Waste Discharge Requirements for Sanitary Sewer Systems, as amended by State Water Board Order No. WQ 2013-0058-EXEC and any subsequent order updating these requirements. These statewide WDRs require public agencies that own or operate sanitary sewer systems with greater than one mile of sewer lines to enroll for coverage and comply with requirements to develop sanitary sewer management plans and report sanitary sewer overflows, among other provisions and prohibitions. The statewide WDRs contain requirements for operation and maintenance of collection systems, and for reporting and mitigating sanitary sewer overflows, that are more extensive and, therefore, more stringent than the standard provisions in Attachments D and G.

5. Combined Sewer System Controls

a. **Nine Minimum Controls.** The *Combined Sewer Overflow (CSO) Control Policy* establishes nine minimum controls as the minimum technology-based requirements during wet weather for combined sewer systems based on 40 C.F.R. section 125.3:

- Conduct Proper Operations and Maintenance Program
- Maximize Use of Collection System for Storage
- Review and Modify Pretreatment Program
- Maximize Flow to Treatment Plant
- Prohibit Dry Weather Combined Sewer Overflows
- Control Solid and Floatable Materials in Combined Sewer Discharges
- Develop and Implement Pollution Prevention Program
- Notify Public of Combined Sewer Discharges
- Monitor to Characterize Combined Sewer Discharge Impacts and Efficacy of Controls

These nine minimum controls are the best conventional pollutant control technology (BCT) and the best available technology economically achievable (BAT). Provision VI.C.5.a of this Order requires implementation of these nine minimum controls and is consistent with U.S. EPA's guidance document, *Combined Sewer Overflows, Guidance for Nine Minimum Controls* (EPA 832-B-95-003, May 1995).

Provision VI.C.5.a.viii(a) contains specific signage and reporting requirements to inform the public of the location, occurrence, and possible health impacts of combined sewer discharges. The required signage language includes a telephone number so the public can report dry weather discharges to help ensure that corrective actions are taken and warning language to reduce public exposure to potential health risks. This provision contains requirements to protect the shellfish harvesting beneficial use in the Pacific Ocean (see Fact Sheet sections III.C.1 and III.C.2). This provision is consistent with State Water Board Order No. 79-16, U.S. EPA's *NPDES Compendium of Next Generation Compliance Examples* (September 2016), and 40 C.F.R. section 122.38 (*Public Notification Requirements for Combined Sewer Overflows to the Great Lakes Basin*, considered here as guidance).

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

For sewer overflows from the combined sewer system, Provision VI.C.5.a.ii(b) requires the Discharger to notify and report sewer overflows from the combined sewer system using the State's CIWQS database. Water Code sections 13267 and 13383, 40 C.F.R. section 122.41(h), and the *Combined Sewer Overflow (CSO) Control Policy* authorize the Regional Water Board and U.S. EPA to require information about releases of untreated or partially-treated wastewater. This information is necessary to evaluate combined sewer system performance, and operations and maintenance practices; to determine whether any diversions of untreated or partially-treated wastewater result in a discharge to surface waters; to satisfy public notification requirements; to identify whether the public could be affected; and to establish whether sewer overflows from the combined sewer system result in a nuisance as defined by Water Code section 13050.

- b. Documentation of Nine Minimum Controls.** Provision VI.C.5.b is based on section II.B of the *Combined Sewer Overflow (CSO) Control Policy*, which states that Dischargers should submit appropriate documentation demonstrating implementation of the nine minimum controls. Consistent with U.S. EPA's guidance document, *Combined Sewer Overflows, Guidance for Nine Minimum Controls* (EPA 832-B-95-003, May 1995), a community that has made substantial progress in implementing the nine minimum controls is still expected to provide documentation to the permitting authority to demonstrate how its program addresses each minimum control.
- c. Long-Term Control Plan (LTCP).** The *Combined Sewer Overflow (CSO) Control Policy* requires implementation of a Long-Term Control Plan (LTCP) to satisfy water quality-based requirements during wet weather. *Combined Sewer Overflow (CSO) Control Policy* section IV.B.2.f specifies that permits should contain requirements for maximizing the treatment of wet weather flows, as appropriate. The operational requirements in Provision VI.C.5.c of this Order are unchanged from the previous order, except that this Order requires the instantaneous influent flow rate to the Oceanside Water Pollution Control Plant prior to initiating discharge from the Westside Transport/Storage Structure to Discharge Point No. 001 to be 60 MGD to reflect the treatment capacity of the Oceanside Water Pollution Control Plant and operational considerations. This provision allows the Discharger to request changes to these operational parameters to ensure the Discharger's LTCP continues to minimize combined sewer discharges and maximize pollutant removal during wet weather. Provision VI.C.5.d (Task 4) of this Order requires the Discharger to re-evaluate each operational requirement and propose additional performance measures within 24 months of this Order's effective date to ensure wet weather operations are optimized based on current information.
- d. LTCP Update.** The Discharger's report *San Francisco Wastewater Long Term Control Plan Synthesis* (March 30, 2018) summarizes the various documents that comprise the Discharger's historical planning process and LTCP. Provision VI.C.5.d requires the Discharger to update its LTCP with respect to the elements listed in *Combined Sewer Overflow (CSO) Control Policy* section II.C. *Combined Sewer Overflow (CSO) Control Policy* section IV.B describes the major elements that should be included in NPDES permits to implement the policy and ensure protection of water quality. This provision is consistent with U.S. EPA's guidance document *Combined Sewer Overflows, Guidance*

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

for Long-Term Control Plan (EPA 832-B-95-002, September 1995). This provision also implements State Water Board Order No. WQ 79-16, which sets forth specific conditions to be implemented during wet weather (see Fact Sheet § III.C.2.b).

This provision requires the Discharger to update its LTCP for the following reasons:

- *Combined Sewer Overflow (CSO) Control Policy* section IV.B.2.b specifies that the permit should contain narrative requirements to ensure that selected controls are implemented, operated, and maintained as described in the Discharger's LTCP.
- *Combined Sewer Overflow (CSO) Control Policy* section IV.B.2.d specifies that the permit should contain a requirement to monitor and collect sufficient information to demonstrate compliance with water quality standards and protect designated uses, as well as to determine the effectiveness of combined sewer system controls.
- *Combined Sewer Overflow (CSO) Control Policy* section IV.B.2.e specifies that the permit should contain a requirement to reassess combined sewer discharges to sensitive areas in those cases where elimination or relocation was previously found to be not physically possible and economically achievable.
- *Combined Sewer Overflow (CSO) Control Policy* section IV.B.2.f specifies that the permit should contain requirements for maximizing the treatment of wet weather flows at the treatment plant, as appropriate.
- State Water Board Order No. WQ 79-16 requires the Discharger to design, construct, and operate facilities to the greatest extent practical to conform to the standards set forth in chapter II of the 1978 Ocean Plan, except for the bacteriological standards (see Fact Sheet § III.C.2.b).
- State Water Board Order No. WQ 79-16 requires the Discharger to design, construct, and operate facilities to the greatest extent practical to comply with the conditions controlled by the requirements set forth in chapter III, sections A and B, of the 1978 Ocean Plan (see Fact Sheet § III.C.2.b).
- An updated LTCP is necessary to document that the Discharger's LTCP is based on the most current information to assess whether water quality standards are being met and that wet weather discharges are not causing unreasonable degradation of the marine environment (40 C.F.R. § 125.122).

6. Westside Recycled Water Project Operations Notification

The effluent limitations and specifications in this Order are based on information available during the permit reissuance process. Assumptions regarding how effluent quality could change after commencement of Westside Recycled Water Project operations were based on information the Discharger provided prior to completion of project planning and construction. This provision is necessary to evaluate whether the assumptions made during the permitting process remain valid and to ensure that the permit continues to be protective of water quality standards. Moreover, because some requirements of this Order are contingent

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

upon Westside Recycled Water Project operations, notification is necessary for the Regional Water Board and U.S. EPA to know when such requirements apply.

7. Flame Retardant Special Study

This special study is necessary to evaluate the potential impacts of flame retardants (i.e., polybrominated diphenyl ethers and chlorinated organophosphate flame retardants) in receiving waters. During U.S. EPA consultation with the National Marine Fisheries Service pursuant to the Endangered Species Act and Magnuson-Stevens Act, the National Marine Fisheries Service expressed concern about the presence of flame retardants in plant effluent and flame retardant mass loadings to the Pacific Ocean because organophosphates have been widely detected in San Francisco Bay water, sediment, and aquatic life tissue, and because polybrominated diphenyl ether (PBDE) and tris(1,3-dichloro-2-propyl)phosphate (TDCP) concentrations in San Francisco Bay water have regularly exceeded predicted no effect concentrations for marine settings (*U.S. EPA Biological Evaluation*, April 2019). This special study is consistent with other NPDES permits that authorize discharge to the Pacific Ocean.

8. Efficacy of Combined Sewer System Controls Special Study

This special study is necessary to characterize the quality of the combined sewer discharges and the efficacy of the combined sewer system controls during wet weather. It is based on the *Combined Sewer Overflow (CSO) Control Policy*, which requires “a post-construction water quality monitoring program adequate to verify compliance with water quality standards and protection of designated uses as well as to ascertain the effectiveness of CSO controls.”

VII. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

CWA section 308 and 40 C.F.R. sections 122.41(h), 122.41(j)-(l), 122.44(i), and 122.48 require that all NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. The *Combined Sewer Overflow (CSO) Control Policy* requires monitoring to ascertain the effectiveness of controls and to verify compliance with water quality standards and protection of beneficial uses. The Monitoring and Reporting Program (MRP) in Attachment E of this Order establishes monitoring, reporting, and recordkeeping requirements that implement federal and State requirements. Specified monitoring frequencies take into account the quantity and variability of the discharge, past compliance, significance of pollutants, and cost of monitoring. The following provides the rationale for the monitoring and reporting requirements contained in the MRP.

- A. Influent Monitoring.** Influent flow monitoring is necessary to understand Facility operations and to evaluate compliance with Discharge Prohibition III.D. Influent CBOD₅ and TSS monitoring is necessary to evaluate compliance with this Order’s 85 percent removal requirement. Influent monitoring is also necessary to identify wet weather days, as defined in Attachment A.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

- B. Effluent Monitoring.** Dry weather monitoring is necessary to evaluate compliance with this Order's effluent limitations and to provide data for future reasonable potential analyses. Wet weather monitoring is necessary to characterize the efficacy of combined sewer system controls and assess receiving water impacts. Effluent flow monitoring is necessary to understand Facility operations and to assess impacts to receiving waters.
- C. Toxicity Testing.** Dry weather effluent chronic toxicity monitoring is necessary to evaluate compliance with this Order's chronic toxicity effluent limitation and to provide data for future reasonable potential analyses. Routine and accelerated chronic toxicity monitoring frequencies and Toxicity Reduction Evaluation requirements are based on the implementation provisions in Ocean Plan chapter III.C and the standard monitoring procedures guidance in section 7.1 of Ocean Plan Appendix III.

A tiered approach to determine the required effluent concentration in test samples removes impediments for the Discharger to construct and operate the Westside Recycled Water Project. When recycled water production exceeds 1.0 MGD, toxicity test samples are to contain an effluent concentration based on the dilution at Discharge Point No. 001 as modeled using observed ocean currents. This flexibility accounts for potential increases in pollutant concentrations as recycled water is removed from the discharge.

- D. Receiving Water Monitoring.** Receiving water monitoring is necessary to characterize the effects of the discharges authorized in this Order on the receiving water and species listed under the California Endangered Species Act or federal Endangered Species Act. The requirements are based on the monitoring guidance in Appendix III of the Ocean Plan. The MRP requires the Discharger to continue its Southwest Ocean Outfall Regional Monitoring Program to collect data on chemical and physical sediment quality, benthic infauna community structure, and physical anomalies and bioaccumulation of contaminants in organism tissues.

The MRP requires shoreline monitoring following combined sewer discharge events at beach locations where water contact recreation takes place. This monitoring is necessary to assess the possible effects of combined sewer discharges on the water contact recreation beneficial use and to establish when public notification is required pursuant to Provision VI.C.5.a.viii of this Order. The bacteria indicators, *Enterococcus* and fecal coliform, are consistent with the revised bacteria provisions approved by U.S. EPA on March 22, 2019. An additional bacteria indicator, total coliform, is required for shoreline monitoring following combined sewer discharges because monitoring for total coliform is consistent with the indicators identified by the California Department of Public Health.

The MRP no longer requires the Discharger to collect data on demersal fish and epibenthic invertebrate community structure because trawl sampling does not provide data that are useful in determining discharge effects (*Southwest Ocean Outfall Regional Monitoring Program 1997-2012 Summary Report*, April 2014). The MRP also no longer includes 12 offshore receiving water monitoring locations. Seven discontinued locations (Stations 73, 74, 75, 76, 77, 78, and 79) were part of a special study conducted from 2002 through 2016; the Discharger demonstrated that these locations are not significantly different from other reference monitoring locations (*A Review of Benthic Macrofaunal Assemblage and Sediment Conditions in the Reef-Effect Region of the SWOO-RMP*, August 2018). Sediment and infaunal sampling at the other

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

five discontinued locations (Stations 41, 42, 44, 46, 49) has historically provided very little information because of their location in a unique, high energy environment with little to no fine sediment or animals (Pang, Jennie, email communication, December 14, 2018).

- E. Pretreatment and Biosolids Monitoring.** The pretreatment and biosolids monitoring requirements for influent, effluent, and biosolids are necessary to evaluate compliance with the Discharger's U.S. EPA-approved pretreatment program. Biosolids monitoring is also required pursuant to 40 C.F.R. part 503.
- F. Other Monitoring Requirements.** Pursuant to CWA section 308, U.S. EPA requires dischargers to participate in a Discharge Monitoring Report-Quality Assurance (DMR-QA) Study Program. The program annually evaluates the analytical abilities of laboratories that perform or support NPDES permit-required monitoring. The program applies to discharger laboratories and contract laboratories. There are two options to comply: (1) dischargers can obtain and analyze DMR-QA samples, or (2) pursuant to a waiver U.S. EPA issued to the State Water Board, dischargers can submit results from the most recent Water Pollution Performance Evaluation Study. Dischargers must submit results annually to the State Water Board, which then forwards the results to U.S. EPA.

Recycled water monitoring and reporting requirements are required to be incorporated into this Order by State Water Board Order No. WQ 2019-0037-EXEC (Amending Monitoring and Reporting Programs for Waste Discharge Requirements, NPDES Permits, Water Reclamation Requirements, Master Recycling Permits, and General Waste Discharge Requirements) issued on July 24, 2019, pursuant to Water Code sections 13267 and 13383.

VIII. PUBLIC PARTICIPATION

The Regional Water Board and U.S. EPA considered the issuance of WDRs and an NPDES permit for the Facility. As a step this process, U.S. EPA and Regional Water Board staff developed a tentative order and encouraged public participation in the reissuance process.

- A. Notification of Interested Parties.** The Regional Water Board and U.S. EPA notified the Discharger and interested agencies and persons of their intent to adopt an order reissuing the NPDES permit for the Discharger's discharges and provided an opportunity to submit written comments and recommendations. Notification was provided through the *San Francisco Chronicle* and <http://www.epa.gov/region9/water/npdes/pubnotices.html>. The public had access to the Regional Water Board agenda and any changes in dates and locations through the Regional Water Board's website at <http://www.waterboards.ca.gov/sanfranciscobay> and U.S. EPA's website at <http://www.epa.gov/region9/water/npdes/pubnotices.html>.
- B. Written Comments.** Interested persons were invited to submit written comments concerning the tentative order as explained through the notification process. Comments to the Regional Water Board and U.S. EPA were to be submitted either in person or by mail to the U.S. EPA NPDES Permits Office (WTR 2-3) at 75 Hawthorne Street, San Francisco, California 94105, to the attention of Becky Mitschele, and to the Regional Water Board office at 1515 Clay Street, Suite 1400, Oakland, California 94612, to the attention of Jessica Watkins.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

For full staff response and Regional Water Board and U.S. EPA consideration, the written comments were due by 5:00 p.m. on May 20, 2019.

C. Public Hearing. The Regional Water Board held a public hearing on the tentative order during its regular meeting at the following date and time, and at the following location:

Date: Wednesday, September 11, 2019
Time: 9:00 a.m.
Location: Elihu Harris State Office Building
1515 Clay Street, 1st Floor Auditorium
Oakland, CA 94612
Contact: Jessica Watkins, (510) 622-2349, jessica.watkins@waterboards.ca.gov

Interested persons were invited to attend. At the public hearing, the Regional Water Board heard testimony pertinent to the discharge, WDRs, and permit. For accuracy of the record, important testimony was requested to be in writing.

Dates and venues change. The Regional Water Board web address is <http://www.waterboards.ca.gov/sanfranciscobay>, where one could access the current agenda for changes in dates and locations.

D. Reconsideration of Waste Discharge Requirements. Any aggrieved person may petition the State Water Board to review the Regional Water Board decision regarding the final WDRs. The State Water Board must receive the petition at the following address within 30 calendar days of the Regional Water Board's action:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

For instructions on how to file a petition for review, see http://www.waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instr.shtml.

E. Federal NPDES Permit Appeals. When U.S. EPA issues a final NPDES permit, it becomes effective on its effective date unless a request for review is filed. If a request for review is filed, only those permit conditions that are uncontested go into effect pending disposition of the request for review. Requests for review must be filed within 33 days following the date the final permit is mailed and must meet the requirements of 40 C.F.R. section 124.19. Requests for review should be addressed to the Environmental Appeals Board and sent through the U.S. Postal Service addressed to the Environmental Appeals Board's mailing address:

U.S. Environmental Protection Agency
Clerk of the Board
Environmental Appeals Board (MC 1103B)
Ariel Rios Building
1200 Pennsylvania Avenue, N.W.
Washington, D.C. 20460-0001

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Alternatively, filings delivered by hand or courier, including Federal Express, UPS, and U.S. Postal Express Mail, should be directed to the following address:

Environmental Appeals Board
U.S. Environmental Protection Agency
Colorado Building
1341 G Street, N.W., Suite 600
Washington, D.C. 20460

Persons filing a request for review must have filed written comments on the draft permit. Otherwise, any such request for review may be filed only to the extent that the request pertains to changes from the draft to the final permit decision.

- F. Information and Copying.** The Report of Waste Discharge, related supporting documents, and comments received are on file and may be inspected at the Regional Water Board office at 1515 Clay Street, Suite 1400, Oakland, California at any time between 8:00 a.m. and 5:00 p.m. (except noon to 1:00 p.m.), Monday through Friday, and at the U.S. EPA Region IX office at 75 Hawthorne Street, San Francisco, California at any time between 9:00 a.m. and 5:00 p.m., Monday through Friday. Copying of documents may be arranged by calling the Regional Water Board at (510) 622-2300 or U.S. EPA at (415) 972-3524.
- G. Register of Interested Persons.** Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board and U.S. EPA, reference this Facility, and provide a name, address, and phone number.
- H. Additional Information.** Requests for additional information or questions regarding this Order should be directed to Jessica Watkins at (510) 622-2349 or jessica.watkins@waterboards.ca.gov, or Becky Mitschele at (415) 972-3492 or mitschele.becky@epa.gov.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

ATTACHMENT G

**REGIONAL STANDARD PROVISIONS, AND
MONITORING AND REPORTING REQUIREMENTS
(SUPPLEMENT TO ATTACHMENT D)**

November 2017

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Contents

I. STANDARD PROVISIONS – PERMIT COMPLIANCE.....	G-1
A. Duty to Comply.....	G-1
B. Need to Halt or Reduce Activity Not a Defense	G-1
C. Duty to Mitigate	G-1
1. Contingency Plan.....	G-1
2. Spill Prevention Plan.....	G-2
D. Proper Operation and Maintenance	G-2
1. Operation and Maintenance Manual.....	G-2
2. Wastewater Facilities Status Report	G-2
3. Proper Supervision and Operation of Publicly-Owned Treatment Works (POTWs).....	G-2
E. Property Rights.....	G-2
F. Inspection and Entry	G-2
G. Bypass	G-2
H. Upset.....	G-2
I. Other.....	G-2
II. STANDARD PROVISIONS – PERMIT ACTION.....	G-3
III. STANDARD PROVISIONS – MONITORING.....	G-3
A. Sampling and Analyses	G-3
1. Certified Laboratories	G-3
2. Minimum Levels.....	G-3
3. Monitoring Frequency	G-3
B. Standard Observations.....	G-5
1. Receiving Water Observations	G-5
2. Wastewater Effluent Observations	G-6
3. Beach and Shoreline Observations	G-6
4. Waste Treatment and/or Disposal Facility Periphery Observations	G-6
IV. STANDARD PROVISIONS – RECORDS.....	G-6
A. Records to be Maintained.....	G-6
B. Records of Monitoring	G-6
1. Analytical Information.....	G-6
2. Disinfection Process.....	G-7
3. Wastewater Treatment Process Solids	G-7
4. Treatment Process Bypasses	G-7
5. Treatment Facility Overflows.....	G-7
C. Claims of Confidentiality	G-7
V. STANDARD PROVISIONS – REPORTING	G-8
A. Duty to Provide Information	G-8
B. Signatory and Certification Requirements	G-8
C. Monitoring Reports	G-8
1. Self-Monitoring Reports.....	G-8
D. Compliance Schedules	G-11
E. Twenty-Four Hour Reporting.....	G-11
1. Oil or Other Hazardous Material Spills	G-11
2. Unauthorized Municipal Wastewater Treatment Plant Discharges	G-12
F. Planned Changes	G-13
G. Anticipated Noncompliance	G-13
H. Other Noncompliance.....	G-13
I. Other Information.....	G-13
VI. STANDARD PROVISION – ENFORCEMENT	G-13

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS	G-13
VIII. DEFINITIONS	G-13

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

REGIONAL STANDARD PROVISIONS, AND MONITORING AND REPORTING REQUIREMENTS

APPLICABILITY

This document supplements the requirements of Federal Standard Provisions (Attachment D). For clarity, these provisions are arranged using to the same headings as those used in Attachment D.

I. STANDARD PROVISIONS - PERMIT COMPLIANCE

A. Duty to Comply – Not Supplemented

B. Need to Halt or Reduce Activity Not a Defense – Not Supplemented

C. Duty to Mitigate – Supplement to Attachment D, Provision I.C.

- 1. Contingency Plan.** The Discharger shall maintain a Contingency Plan as prudent in accordance with current facility emergency planning. The Contingency Plan shall describe procedures to ensure that existing facilities remain in, or are rapidly returned to, operation in the event of a process failure or emergency incident, such as employee strike, strike by suppliers of chemicals or maintenance services, power outage, vandalism, earthquake, or fire. The Discharger may combine the Contingency Plan and Spill Prevention Plan (see Provision I.C.2, below) into one document. In accordance with Regional Water Board Resolution No. 74-10, discharge in violation of the permit where the Discharger has failed to develop and implement a Contingency Plan as described below may be the basis for considering the discharge a willful and negligent violation of the permit pursuant to California Water Code section 13387. The Contingency Plan shall, at a minimum, provide for the following:
 - a. Sufficient personnel for continued facility operation and maintenance during employee strikes or strikes against contractors providing services;
 - b. Maintenance of adequate chemicals or other supplies, and spare parts necessary for continued facility operations;
 - c. Emergency standby power;
 - d. Protection against vandalism;
 - e. Expeditious action to repair failures of, or damage to, equipment, including any sewer lines;
 - f. Reporting of spills and discharges of untreated or inadequately treated wastes, including measures taken to clean up the effects of such discharges; and
 - g. Maintenance, replacement, and surveillance of physical condition of equipment and facilities, including any sewer lines.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

2. **Spill Prevention Plan.** The Discharger shall maintain a Spill Prevention Plan to prevent accidental discharges and to minimize the effects of any such discharges. The Spill Prevention Plan shall do the following:
 - a. Identify the possible sources of accidental discharge, untreated or partially-treated waste bypass, and polluted drainage;
 - b. State when current facilities and procedures became operational and evaluate their effectiveness; and
 - c. Predict the effectiveness of any proposed facilities and procedures and provide an implementation schedule with interim and final dates when the proposed facilities and procedures will be constructed, implemented, or operational.

D. Proper Operation and Maintenance – Supplement to Attachment D, Provision I.D

1. **Operation and Maintenance Manual.** The Discharger shall maintain an Operation and Maintenance Manual to provide the plant and regulatory personnel with a source of information describing all equipment, recommended operational strategies, process control monitoring, and maintenance activities. To remain a useful and relevant document, the Operation and Maintenance Manual shall be kept updated to reflect significant changes in treatment facility equipment and operational practices. The Operation and Maintenance Manual shall be maintained in usable condition and be available for reference and use by all relevant personnel and Regional Water Board staff.
2. **Wastewater Facilities Status Report.** The Discharger shall maintain a Wastewater Facilities Status Report and regularly review, revise, or update it, as necessary. This report shall document how the Discharger operates and maintains its wastewater collection, treatment, and disposal facilities to ensure that all facilities are adequately staffed, supervised, financed, operated, maintained, repaired, and upgraded as necessary to provide adequate and reliable transport, treatment, and disposal of all wastewater from both existing and planned future wastewater sources under the Discharger's service responsibilities.
3. **Proper Supervision and Operation of Publicly-Owned Treatment Works (POTWs).** POTWs shall be supervised and operated by persons possessing certificates of appropriate grade pursuant to Title 23, section 3680, of the California Code of Regulations.

E. Property Rights – Not Supplemented

F. Inspection and Entry – Not Supplemented

G. Bypass – Not Supplemented

H. Upset – Not Supplemented

I. Other – Addition to Attachment D

1. Neither the treatment nor the discharge of pollutants shall create pollution, contamination, or nuisance as defined by California Water Code section 13050.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

2. Collection, treatment, storage, and disposal systems shall be operated in a manner that precludes public contact with wastewater. If public contact with wastewater could reasonably occur on public property, warning signs shall be posted.
3. If the Discharger submits a timely and complete Report of Waste Discharge for permit reissuance, this permit shall continue in force and effect until the permit is reissued or the Regional Water Board rescinds the permit.

II. STANDARD PROVISIONS – PERMIT ACTION – Not Supplemented

III. STANDARD PROVISIONS – MONITORING

A. Sampling and Analyses – Supplement to Attachment D, Provisions III.A and III.B

1. **Certified Laboratories.** Water and waste analyses shall be performed by a laboratory certified for these analyses in accordance with California Water Code section 13176.
2. **Minimum Levels.** For the 126 priority pollutants, the Discharger should use the analytical methods listed in Table B unless the Monitoring and Reporting Program (MRP, Attachment E) requires a particular method or minimum level (ML). All monitoring instruments and equipment shall be properly calibrated and maintained to ensure accuracy of measurements.
3. **Monitoring Frequency.** The MRP specifies the minimum sampling and analysis schedule.
 - a. **Sample Collection Timing**
 - i. The Discharger shall collect influent samples on varying days selected at random and shall not include any plant recirculation or other sidestream wastes, unless otherwise stipulated in the MRP. The Executive Officer may approve an alternative influent sampling plan if it is representative of plant influent and complies with all other permit requirements.
 - ii. The Discharger shall collect effluent samples on days coincident with influent sampling, unless otherwise stipulated by the MRP. If influent sampling is not required, the Discharger shall collect effluent samples on varying days selected at random, unless otherwise stipulated in the MRP. The Executive Officer may approve an alternative effluent sampling plan if it is representative of plant discharge and in compliance with all other permit requirements.
 - iii. The Discharger shall collect effluent grab samples during periods of daytime maximum peak flows (or peak flows through secondary treatment units for facilities that recycle effluent).
 - iv. Effluent sampling for conventional pollutants shall occur on at least one day of any multiple-day bioassay the MRP requires. During the course of the bioassay, on at least one day, the Discharger shall collect and retain samples of the discharge. In the event that a bioassay result does not comply with effluent limitations, the Discharger

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

shall analyze the retained samples for pollutants that could be toxic to aquatic life and for which it has effluent limitations.

- (a) The Discharger shall perform bioassays on final effluent samples; when chlorine is used for disinfection, bioassays shall be performed on effluent after chlorination and dechlorination; and
- (b) The Discharger shall analyze for total ammonia nitrogen and calculate the amount of un-ionized ammonia whenever test results fail to meet effluent limitations.

b. Conditions Triggering Accelerated Monitoring

- i. **Average Monthly Effluent Limitation Exceedance.** If the results from two consecutive samples of a constituent monitored in a particular month exceed the average monthly effluent limitation for any parameter (or if the required sampling frequency is once per month or less and the monthly sample exceeds the average monthly effluent limitation), the Discharger shall, within 24 hours after the results are received, increase its sampling frequency to daily until the results from the additional sampling show that the parameter complies with the average monthly effluent limitation.
- ii. **Maximum Daily Effluent Limitation Exceedance.** If a sample result exceeds a maximum daily effluent limitation, the Discharger shall, within 24 hours after the result is received, increase its sampling frequency to daily until the results from two samples collected on consecutive days show compliance with the maximum daily effluent limitation.
- iii. **Acute Toxicity.** If final or intermediate results of an acute bioassay indicate a violation or threatened violation (e.g., the percentage of surviving test organisms of any single acute bioassay is less than 70 percent), the Discharger shall initiate a new test as soon as practical or as described in applicable State Water Board plan provisions that become effective after adoption of these Regional Standard Provisions. The Discharger shall investigate the cause of the mortalities and report its findings in the next self-monitoring report.
- iv. **Chlorine.** The Discharger shall calibrate chlorine residual analyzers against grab samples as frequently as necessary to maintain accurate control and reliable operation. If an effluent violation is detected, the Discharger shall collect grab samples at least every 30 minutes until compliance with the limitation is achieved, unless the Discharger monitors chlorine residual continuously. In such cases, the Discharger shall continue to conduct continuous monitoring.
- v. **Bypass.** Except as indicated below, if a Discharger bypasses any portion of its treatment facility, it shall monitor flows and collect samples at affected discharge points and analyze samples for all constituents with effluent limitations on a daily basis for the duration of the bypass. The Discharger need not accelerate chronic toxicity monitoring. The Discharger also need not collect and analyze samples for mercury, dioxin-TEQ, and PCBs after the first day of the bypass. The Discharger may

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

satisfy the accelerated acute toxicity monitoring requirement by conducting a flow-through test or static renewal test that captures the duration of the bypass (regardless of the method specified in the MRP). If bypassing disinfection units only, the Discharger shall only monitor bacteria indicators daily.

- (a) **Bypass for Essential Maintenance.** If a Discharger bypasses a treatment unit for essential maintenance pursuant to Attachment D section I.G.2, the Executive Officer may reduce the accelerated monitoring requirements above if the Discharger (i) monitors effluent at affected discharge points on the first day of the bypass for all constituents with effluent limitations, except chronic toxicity; and (ii) identifies and implements measures to ensure that the bypass will continue to comply with effluent limitations.
- (b) **Approved Wet Weather Bypasses.** If a Discharger bypasses a treatment unit or permitted outfall during wet weather with Executive Officer approval pursuant to Attachment D section I.G.4, the Discharger shall monitor flows and collect and retain samples for affected discharge points on a daily basis for the duration of the bypass. The Discharger shall analyze daily for TSS using 24-hour composites (or more frequent increments) and for bacteria indicators with effluent limitations using grab samples. If TSS exceeds 45 mg/L in any composite sample, the Discharger shall also analyze daily the retained samples for all other constituents with effluent limitations, except oil and grease, mercury, PCBs, dioxin-TEQ, and acute and chronic toxicity. Additionally, at least once each year, the Discharger shall analyze the retained samples for one approved bypass for all other constituents with effluent limitations, except oil and grease, mercury, PCBs, dioxin-TEQ, and acute and chronic toxicity. This monitoring shall be in addition to the minimum monitoring specified in the MRP.

B. Standard Observations – Addition to Attachment D

1. **Receiving Water Observations.** The following requirements only apply when the MRP requires standard observations of receiving waters. Standard observations shall include the following:
 - a. **Floating and Suspended Materials** (e.g., oil, grease, algae, and other macroscopic particulate matter) — presence or absence, source, and size of affected area.
 - b. **Discoloration and Turbidity** — color, source, and size of affected area.
 - c. **Odor** — presence or absence, characterization, source, and distance of travel.
 - d. **Beneficial Water Use** — estimated number of water-associated waterfowl or wildlife, fisherpeople, and other recreational activities.
 - e. **Hydrographic Condition** — time and height of high and low tides (corrected to nearest National Oceanic and Atmospheric Administration location for the sampling date and time).

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

- f. **Weather Conditions** — wind direction, air temperature, and total precipitation during five days prior to observation.
- 2. **Wastewater Effluent Observations.** The following requirements only apply when the MRP requires standard observations of wastewater effluent. Standard observations shall include the following:
 - a. **Floating and Suspended Material of Wastewater Origin** (e.g., oil, grease, algae, and other macroscopic particulate matter) — presence or absence.
 - b. **Odor** — presence or absence, characterization, source, distance of travel, and wind direction.
- 3. **Beach and Shoreline Observations.** The following requirements only apply when the MRP requires standard observations of beaches or shorelines. Standard observations shall include the following:
 - a. **Material of Wastewater Origin** — presence or absence, description of material, estimated size of affected area, and source.
 - b. **Beneficial Use** — estimate of number of people participating in recreational water contact, non-water contact, and fishing activities.
- 4. **Waste Treatment and/or Disposal Facility Periphery Observations.** The following requirements only apply when the MRP requires standard observations of the periphery of waste treatment or disposal facilities. Standard observations shall include the following:
 - a. **Odor** — presence or absence, characterization, source, and distance of travel.
 - b. **Weather Conditions** — wind direction and estimated velocity.

IV. STANDARD PROVISIONS – RECORDS

A. Records to be Maintained – Supplement to Attachment D, Provision IV.A

The Discharger shall maintain records in a manner and at a location (e.g., the wastewater treatment plant or the Discharger's offices) such that the records are accessible to Regional Water Board staff. The minimum retention period specified in Attachment D, Provision IV, shall be extended during the course of any unresolved litigation regarding permit-related discharges, or when requested by Regional Water Board or U.S. EPA, Region IX, staff.

A copy of the permit shall be maintained at the discharge facility and be available at all times to operating personnel.

B. Records of Monitoring – Supplement to Attachment D, Provision IV.B

Monitoring records shall include the following:

- 1. **Analytical Information.** Records shall include analytical method detection limits, minimum levels, reporting levels, and related quantification parameters.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

2. **Disinfection Process.** For the disinfection process, records shall include the following:
 - a. For bacteriological analyses:
 - i. Wastewater flow rate at the time of sample collection; and
 - ii. Required statistical parameters for cumulative bacterial values (e.g., moving median or geometric mean for the number of samples or sampling period identified in the MRP).
 - b. For the chlorination process (when chlorine is used for disinfection), at least daily average values for the following:
 - i. Chlorine residual of treated wastewater as it enters the chlorine contact basin (mg/L);
 - ii. Chlorine dosage (kg/day); and
 - iii. Dechlorination chemical dosage (kg/day).
3. **Wastewater Treatment Process Solids.** For each treatment unit process that involves solids removal from the wastewater stream, records shall include the following:
 - a. Total volume or mass of solids removed from each collection unit (e.g., grit, skimmings, undigested biosolids, or combination) for each calendar month or other time period as appropriate, but not to exceed annually; and
 - b. Final disposition of such solids (e.g., landfill, other subsequent treatment unit).
4. **Treatment Process Bypasses.** For all treatment process bypasses, including wet weather blending, records shall include the following:
 - a. Chronological log of treatment process bypasses;
 - b. Identification of treatment processes bypassed;
 - c. Beginning and ending dates and times of bypasses;
 - d. Bypass durations;
 - e. Estimated bypass volumes; and
 - f. Description of, or reference to other reports describing, the bypasses, their cause, the corrective actions taken (except for wet weather blending explicitly approved within the permit and in compliance with any related permit conditions), and any additional monitoring conducted.
5. **Treatment Plant Overflows.** The Discharger shall retain a chronological log of overflows at the treatment plant, including the headworks and all units and appurtenances downstream, and records supporting the information provided in accordance with Provision V.E.2, below.

C. Claims of Confidentiality – Not Supplemented

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information – Not Supplemented

B. Signatory and Certification Requirements – Not Supplemented

C. Monitoring Reports – Supplement to Attachment D, Provision V.C

- 1. Self-Monitoring Reports.** For each reporting period established in the MRP, the Discharger shall submit a self-monitoring report to the Regional Water Board in accordance with the requirements listed in the MRP and below:
 - a. Transmittal Letter.** Each self-monitoring report shall be submitted with a transmittal letter that includes the following:
 - i.** Identification of all violations of effluent limitations or other waste discharge requirements found during the reporting period;
 - ii.** Details regarding the violations, such as parameters, magnitude, test results, frequency, and dates;
 - iii.** Causes of the violations;
 - iv.** Corrective actions taken or planned to resolve violations and prevent recurrences, and dates or time schedules for implementation (the Discharger may refer to previously submitted reports that address the corrective actions);
 - v.** Explanation for any data invalidation. Data should not be submitted in a self-monitoring report if it does not meet quality assurance/quality control standards. However, if the Discharger wishes to invalidate a measurement after submitting it in a self-monitoring report, the Discharger shall identify the measurement suspected to be invalid and state the Discharger's intent to submit, within 60 days, a formal request to invalidate the measurement. The formal request shall include the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports invalidation (e.g., laboratory sheet, log entry, test results), and a discussion of the corrective actions taken or planned (with a time schedule for completion) to prevent recurrence of the sampling or measurement problem;
 - vi.** Description of blending, if any. If the Discharger blends, it shall describe the duration of blending events and certify whether the blending complied with all conditions for blending;
 - vii.** Description of other bypasses, if any. If the Discharger bypasses any treatment units (other than blending), it shall describe the duration of the bypasses and effluent quality during those times; and
 - viii.** Signature. The transmittal letter shall be signed in accordance with Attachment D, Provision V.B.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

- b. Compliance Evaluation Summary.** Each self-monitoring report shall include a compliance evaluation summary that addresses each parameter for which the permit specifies effluent limitations, the number of samples taken during the monitoring period, and the number of samples that exceed the effluent limitations.
- c. More Frequent Monitoring.** If the Discharger monitors any pollutant more frequently than required by the MRP, the Discharger shall include the results of such monitoring in the calculation and reporting of the data submitted in the self-monitoring report.
- d. Analysis Results**
 - i. Tabulation.** Each self-monitoring report shall include tabulations of all required analyses and observations, including parameters, dates, times, sample stations, types of samples, test results, method detection limits, method minimum levels, and method reporting levels (if applicable), signed by the laboratory director or other responsible official.
 - ii. Multiple Samples.** Unless the MRP specifies otherwise, when determining compliance with effluent limitations (other than instantaneous effluent limitations) and more than one sample result is available, the Discharger shall compute the arithmetic mean. If the data set contains one or more results that are “Detected, but Not Quantified (DNQ)” or “Not Detected” (ND), the Discharger shall instead compute the median in accordance with the following procedure:
 - (a)** The data set shall be ranked from low to high, reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - (b)** The median of the data set shall be determined. If the data set has an odd number of data points, the median is the middle value. If the data set has an even number of data points, the median is the average of the two values around the middle, unless one or both of these values is ND or DNQ, in which case the median shall be the lower of the two results (where DNQ is lower than a quantified value and ND is lower than DNQ).
 - iii. Duplicate Samples.** The Discharger shall report the average of duplicate sample analyses when reporting for a single sample result (or the median if one or more of the duplicates is DNQ or ND [see Provision V.C.1.d.ii, above]). For bacteria indicators, the Discharger shall report the geometric mean of the duplicate analyses.
 - iv. Dioxin-TEQ.** The Discharger shall report for each dioxin and furan congener the analytical results of effluent monitoring, including the reporting level, the method detection limit, and the measured concentration. The Discharger shall report all measured values of individual congeners, including data qualifiers. When calculating dioxin-TEQ, the Discharger shall set congener concentrations below the minimum levels (MLs) to zero. The Discharger shall calculate and report dioxin-TEQ using the

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

following formula, where the MLs, toxicity equivalency factors (TEFs), and bioaccumulation equivalency factors (BEFs) are as provided in Table A:

$$\text{Dioxin-TEQ} = \sum (C_x \times \text{TEF}_x \times \text{BEF}_x)$$

where: C_x = measured or estimated concentration of congener x
 TEF_x = toxicity equivalency factor for congener x
 BEF_x = bioaccumulation equivalency factor for congener x

Table A
 Minimum Levels, Toxicity Equivalency Factors,
 and Bioaccumulation Equivalency Factors

Dioxin or Furan Congener	Minimum Level (pg/L)	2005 Toxicity Equivalency Factor (TEF)	Bioaccumulation Equivalency Factor (BEF)
2,3,7,8-TCDD	10	1.0	1.0
1,2,3,7,8-PeCDD	50	1.0	0.9
1,2,3,4,7,8-HxCDD	50	0.1	0.3
1,2,3,6,7,8-HxCDD	50	0.1	0.1
1,2,3,7,8,9-HxCDD	50	0.1	0.1
1,2,3,4,6,7,8-HpCDD	50	0.01	0.05
OCDD	100	0.0003	0.01
2,3,7,8-TCDF	10	0.1	0.8
1,2,3,7,8-PeCDF	50	0.03	0.2
2,3,4,7,8-PeCDF	50	0.3	1.6
1,2,3,4,7,8-HxCDF	50	0.1	0.08
1,2,3,6,7,8-HxCDF	50	0.1	0.2
1,2,3,7,8,9-HxCDF	50	0.1	0.6
2,3,4,6,7,8-HxCDF	50	0.1	0.7
1,2,3,4,6,7,8-HpCDF	50	0.01	0.01
1,2,3,4,7,8,9-HpCDF	50	0.01	0.4
OCDF	100	0.0003	0.02

- e. **Results Not Yet Available.** The Discharger shall make all reasonable efforts to obtain analytical data for required parameter sampling in a timely manner. Certain analyses may require additional time to complete analytical processes and report results. In these cases, the Discharger shall describe the circumstances in the self-monitoring report and include the data for these parameters and relevant discussions of any violations in the next self-monitoring report due after the results are available.
- f. **Annual Self-Monitoring Reports.** By the date specified in the MRP, the Discharger shall submit an annual self-monitoring report covering the previous calendar year. The report shall contain the following:
 - i. Comprehensive discussion of treatment plant performance, including documentation of any blending or other bypass events, and compliance with the permit. This discussion shall include any corrective actions taken or planned, such as changes to facility equipment or operation practices that may be needed to achieve compliance,

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

and any other actions taken or planned that are intended to improve the performance and reliability of wastewater collection, treatment, or disposal practices;

ii. List of approved analyses, including the following:

(a) List of analyses for which the Discharger is certified;

(b) List of analyses performed for the Discharger by a separate certified laboratory (copies of reports signed by the laboratory director of that laboratory need not be submitted but shall be retained onsite); and

(c) List of “waived” analyses, as approved;

iii. Plan view drawing or map showing the Discharger’s facility, flow routing, and sampling and observation station locations; and

iv. Results of facility report reviews. The Discharger shall regularly review, revise, and update, as necessary, the Operation and Maintenance Manual, Contingency Plan, Spill Prevention Plan, and Wastewater Facilities Status Report so these documents remain useful and relevant to current practices. At a minimum, reviews shall be conducted annually. The Discharger shall describe or summarize its review and evaluation procedures, recommended or planned actions, and estimated time schedule for implementing these actions. The Discharger shall complete changes to these documents to ensure that they remain up-to-date.

D. Compliance Schedules – Not supplemented

E. Twenty-Four Hour Reporting – Supplement to Attachment D, Provision V.E

1. Oil or Other Hazardous Material Spills

a. Within 24 hours of becoming aware of a spill of oil or other hazardous material not contained onsite and completely cleaned up, the Discharger shall report as follows:

i. If the spill exceeds reportable quantities for hazardous materials listed in 40 C.F.R. part 302. The Discharger shall call the California Office of Emergency Services (800-852-7550).

ii. If the spill does not exceed reportable quantities for hazardous materials listed in 40 C.F.R., part 302, the Discharger shall call the Regional Water Board (510-622-2369).

b. The Discharger shall submit a written report to the Regional Water Board within five working days following either of the above telephone notifications unless directed otherwise by Regional Water Board staff. A report submitted electronically is acceptable. The written report shall include the following:

i. Date and time of spill, and duration if known;

ii. Location of spill (street address or description of location);

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

- iii. Nature of material spilled;
- iv. Quantity of material spilled;
- v. Receiving water body affected, if any;
- vi. Cause of spill;
- vii. Estimated size of affected area;
- viii. Observed impacts to receiving waters (e.g., oil sheen, fish kill, water discoloration);
- ix. Corrective actions taken to contain, minimize, or clean up the spill;
- x. Future corrective actions planned to prevent recurrence, and implementation schedule; and
- xi. Persons or agencies notified.

2. Unauthorized Municipal Wastewater Treatment Plant Discharges¹

- a. **Two-Hour Notification.** For any unauthorized discharge that enters a drainage channel or surface water, the Discharger shall, as soon as possible, but not later than two hours after becoming aware of the discharge, notify the California Office of Emergency Services (800-852-7550) and the local health officer or director of environmental health with jurisdiction over the affected water body. Notification shall include the following:
 - i. Incident description and cause;
 - ii. Location of threatened or involved waterways or storm drains;
 - iii. Date and time that the unauthorized discharge started;
 - iv. Estimated quantity and duration of the unauthorized discharge (to the extent known), and estimated amount recovered;
 - v. Level of treatment prior to discharge (e.g., raw wastewater, primary-treated wastewater, or undisinfected secondary-treated wastewater); and
 - vi. Identity of person reporting the unauthorized discharge.

¹ California Code of Regulations, Title 23, section 2250(b), defines an unauthorized discharge to be a discharge, not regulated by waste discharge requirements, of treated, partially-treated, or untreated wastewater resulting from the intentional or unintentional diversion of wastewater from a collection, treatment, or disposal system.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

- b. Five-Day Written Report.** Within five business days following the two-hour notification, the Discharger shall submit a written report that includes, in addition to the information listed in Provision V.E.2.a, above, the following:
- i.** Methods used to delineate the geographical extent of the unauthorized discharge within receiving waters;
 - ii.** Efforts implemented to minimize public exposure to the unauthorized discharge;
 - iii.** Visual observations of the impacts (if any) noted in the receiving waters (e.g., fish kill, discoloration of receiving water) and extent of sampling if conducted;
 - iv.** Corrective measures taken to minimize the impact of the unauthorized discharge;
 - v.** Measures to be taken to minimize the potential for a similar unauthorized discharge in the future;
 - vi.** Summary of Spill Prevention Plan or Operation and Maintenance Manual modifications to be made, if necessary, to minimize the potential for future unauthorized discharges; and
 - vii.** Quantity and duration of the unauthorized discharge, and the amount recovered.

F. Planned Changes – Not supplemented

G. Anticipated Noncompliance – Not supplemented

H. Other Noncompliance – Not supplemented

I. Other Information – Not supplemented

VI. STANDARD PROVISION – ENFORCEMENT – Not Supplemented

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS – Not Supplemented

VIII. DEFINITIONS – Addition to Attachment D

More definitions can be found in Attachment A of this NPDES Permit.

A. Arithmetic Calculations

- 1. Geometric Mean.** The antilog of the log mean or the back-transformed mean of the logarithmically transformed variables, which is equivalent to the multiplication of the antilogarithms. The geometric mean can be calculated with either of the following equations:

$$\text{Geometric Mean} = \text{Anti log} \left(\frac{1}{N} \sum_{i=1}^N \text{Log}(C_i) \right)$$

or

$$\text{Geometric Mean} = (C_1 \times C_2 \times \dots \times C_N)^{1/N}$$

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Where “N” is the number of data points for the period analyzed and “C” is the concentration for each of the “N” data points.

2. **Mass Emission Rate.** The rate of discharge expressed in mass. The mass emission rate is obtained from the following calculation for any calendar day:

$$\text{Mass emission rate (lb/day)} = \frac{8.345}{N} \sum_{i=1}^N Q_i C_i$$

$$\text{Mass emission rate (kg/day)} = \frac{3.785}{N} \sum_{i=1}^N Q_i C_i$$

In which “N” is the number of samples analyzed in any calendar day and “Q_i” and “C_i” are the flow rate (MGD) and the constituent concentration (mg/L) associated with each of the “N” grab samples that may be taken in any calendar day. If a composite sample is taken, “C_i” is the concentration measured in the composite sample and “Q_i” is the average flow rate occurring during the period over which the samples are composited. The daily concentration of a constituent measured over any calendar day shall be determined from the flow-weighted average of the same constituent in the combined waste streams as follows:

$$C_d = \text{Average daily concentration} = \frac{1}{Q_t} \sum_{i=1}^N Q_i C_i$$

In which “N” is the number of component waste streams and “Q” and “C” are the flow rate (MGD) and the constituent concentration (mg/L) associated with each of the “N” waste streams. “Q_t” is the total flow rate of the combined waste streams.

3. **Removal Efficiency.** The ratio of pollutants removed by the treatment facilities to pollutants entering the treatment facilities (expressed as a percentage). The Discharger shall determine removal efficiencies using monthly averages (by calendar month unless otherwise specified) of pollutant concentration of influent and effluent samples collected at about the same time and using the following equation (or its equivalent):

$$\text{Removal Efficiency (\%)} = 100 \times [1 - (\text{Effluent Concentration} / \text{Influent Concentration})]$$

- B. **Blending** – the practice of bypassing biological treatment units and recombining the bypass wastewater with biologically-treated wastewater.
- C. **Composite Sample** – a sample composed of individual grab samples collected manually or by an automatic sampling device on the basis of time or flow as specified in the MRP. For flow-based composites, the proportion of each grab sample included in the composite sample shall be within plus or minus five percent (+/-5%) of the representative flow of the waste stream being measured at the time of grab sample collection. Alternatively, equal volume grab samples may

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

be individually analyzed with the flow-weighted average calculated by averaging flow-weighted ratios of each grab sample analytical result. Grab samples comprising time-based composite samples shall be collected at intervals not greater than those specified in the MRP. The quantity of each grab sample comprising a time-based composite sample shall be a set of flow proportional volumes as specified in the MRP. If a particular time-based or flow-based composite sampling protocol is not specified in the MRP, the Discharger shall determine and implement the most representative protocol.

- D. Duplicate Sample** – a second sample taken from the same source and at the same time as an initial sample (such samples are typically analyzed identically to measure analytical variability).
- E. Grab Sample** – an individual sample collected during a short period not exceeding 15 minutes. Grab samples represent only the condition that exists at the time the sample is collected.
- F. Overflow** – the intentional or unintentional spilling or forcing out of untreated or partially-treated waste from a transport system (e.g., through manholes, at pump stations, or at collection points) upstream of the treatment plant headworks or from any part of a treatment plant.
- G. Priority Pollutants** – those constituents referred to in 40 C.F.R. part 122 as promulgated in the Federal Register, Vol. 65, No. 97, Thursday, May 18, 2000, also known as the California Toxics Rule.
- H. Untreated waste** – raw wastewater.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Table B
List of Monitoring Parameters and Analytical Methods

CTR No.	Pollutant/Parameter	Analytical Method ²	Minimum Levels ³ (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
1	Antimony	204.2					10	5	50	0.5	5	0.5		1000
2	Arsenic	206.3				20		2	10	2	2	1		1000
3	Beryllium						20	0.5	2	0.5	1			1000
4	Cadmium	200 or 213					10	0.5	10	0.25	0.5			1000
5a	Chromium (III)	SM 3500												
5b	Chromium (VI)	SM 3500				10	5							1000
	Chromium (total) ⁴	SM 3500					50	2	10	0.5	1			1000
6	Copper	200.9					25	5	10	0.5	2			1000
7	Lead	200.9					20	5	5	0.5	2			10,000
8	Mercury	1631 (note) ⁵												
9	Nickel	249.2					50	5	20	1	5			1000
10	Selenium	200.8 or SM 3114B or C						5	10	2	5	1		1000
11	Silver	272.2					10	1	10	0.25	2			1000
12	Thallium	279.2					10	2	10	1	5			1000
13	Zinc	200 or 289					20		20	1	10			
14	Cyanide	SM 4500 CN ⁻ C or I				5								
15	Asbestos (only required for dischargers to MUN waters) ⁶	0100.2 ⁷												
16	2,3,7,8-TCDD and 17 congeners (Dioxin)	1613												
17	Acrolein	603	2.0	5										
18	Acrylonitrile	603	2.0	2										
19	Benzene	602	0.5	2										
33	Ethylbenzene	602	0.5	2										
39	Toluene	602	0.5	2										
20	Bromoform	601	0.5	2										
21	Carbon Tetrachloride	601	0.5	2										
22	Chlorobenzene	601	0.5	2										
23	Chlorodibromomethane	601	0.5	2										
24	Chloroethane	601	0.5	2										
25	2-Chloroethylvinyl Ether	601	1	1										
26	Chloroform	601	0.5	2										

² The suggested method is the U.S. EPA Method unless otherwise specified (SM = Standard Methods). The Discharger may use another U.S. EPA-approved or recognized method if that method has a level of quantification below the applicable water quality objective. Where no method is suggested, the Discharger has the discretion to use any standard method.

³ Minimum levels are from the *State Implementation Policy*. They are the concentration of the lowest calibration standard for that technique based on a survey of contract laboratories. Laboratory techniques are defined as follows: GC = Gas Chromatography; GCMS = Gas Chromatography/Mass Spectrometry; LC = High Pressure Liquid Chromatography; Color = Colorimetric; FAA = Flame Atomic Absorption; GFAA = Graphite Furnace Atomic Absorption; ICP = Inductively Coupled Plasma; ICPMS = Inductively Coupled Plasma/Mass Spectrometry; SPGFAA = Stabilized Platform Graphite Furnace Atomic Absorption (i.e., U.S. EPA 200.9); Hydride = Gaseous Hydride Atomic Absorption; CVAA = Cold Vapor Atomic Absorption; DCP = Direct Current Plasma.

⁴ Analysis for total chromium may be substituted for analysis of chromium (III) and chromium (VI) if the concentration measured is below the lowest hexavalent chromium criterion (11 µg/l).

⁵ The Discharger shall use ultra-clean sampling (U.S. EPA Method 1669) and ultra-clean analytical methods (U.S. EPA Method 1631) for mercury monitoring. The minimum level for mercury is 2 ng/l (or 0.002 µg/l).

⁶ MUN = Municipal and Domestic Supply. This designation, if applicable, is in the Findings of the permit.

⁷ Determination of Asbestos Structures over 10 [micrometers] in Length in Drinking Water Using MCE Filters, U.S. EPA 600/R-94-134, June 1994.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

CTR No.	Pollutant/Parameter	Analytical Method ²	Minimum Levels ³ (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
75	1,2-Dichlorobenzene	601	0.5	2										
76	1,3-Dichlorobenzene	601	0.5	2										
77	1,4-Dichlorobenzene	601	0.5	2										
27	Dichlorobromomethane	601	0.5	2										
28	1,1-Dichloroethane	601	0.5	1										
29	1,2-Dichloroethane	601	0.5	2										
30	1,1-Dichloroethylene or 1,1-Dichloroethene	601	0.5	2										
31	1,2-Dichloropropane	601	0.5	1										
32	1,3-Dichloropropylene or 1,3-Dichloropropene	601	0.5	2										
34	Methyl Bromide or Bromomethane	601	1.0	2										
35	Methyl Chloride or Chloromethane	601	0.5	2										
36	Methylene Chloride or Dichloromethane	601	0.5	2										
37	1,1,2,2-Tetrachloroethane	601	0.5	1										
38	Tetrachloroethylene	601	0.5	2										
40	1,2-Trans-Dichloroethylene	601	0.5	1										
41	1,1,1-Trichloroethane	601	0.5	2										
42	1,1,2-Trichloroethane	601	0.5	2										
43	Trichloroethene	601	0.5	2										
44	Vinyl Chloride	601	0.5	2										
45	2-Chlorophenol	604	2	5										
46	2,4-Dichlorophenol	604	1	5										
47	2,4-Dimethylphenol	604	1	2										
48	2-Methyl-4,6-Dinitrophenol or Dinitro-2-methylphenol	604	10	5										
49	2,4-Dinitrophenol	604	5	5										
50	2-Nitrophenol	604		10										
51	4-Nitrophenol	604	5	10										
52	3-Methyl-4-Chlorophenol	604	5	1										
53	Pentachlorophenol	604	1	5										
54	Phenol	604	1	1		50								
55	2,4,6-Trichlorophenol	604	10	10										
56	Acenaphthene	610 HPLC	1	1	0.5									
57	Acenaphthylene	610 HPLC		10	0.2									
58	Anthracene	610 HPLC		10	2									
60	Benzo(a)Anthracene or 1,2 Benzanthracene	610 HPLC	10	5										
61	Benzo(a)Pyrene	610 HPLC		10	2									
62	Benzo(b)Fluoranthene or 3,4 Benzo(b)fluoranthene	610 HPLC		10	10									
63	Benzo(ghi)Perylene	610 HPLC		5	0.1									
64	Benzo(k)Fluoranthene	610 HPLC		10	2									
74	Dibenzo(a,h)Anthracene	610 HPLC		10	0.1									
86	Fluoranthene	610 HPLC	10	1	0.05									
87	Fluorene	610 HPLC		10	0.1									
92	Indeno(1,2,3-cd) Pyrene	610 HPLC		10	0.05									
100	Pyrene	610 HPLC		10	0.05									
68	Bis(2-Ethylhexyl)Phthalate	606 or 625	10	5										
70	Butylbenzyl Phthalate	606 or 625	10	10										
79	Diethyl Phthalate	606 or 625	10	2										

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

CTR No.	Pollutant/Parameter	Analytical Method ²	Minimum Levels ¹ (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
80	Dimethyl Phthalate	606 or 625	10	2										
81	Di-n-Butyl Phthalate	606 or 625		10										
84	Di-n-Octyl Phthalate	606 or 625		10										
59	Benzidine	625		5										
65	Bis(2-Chloroethoxy)Methane	625		5										
66	Bis(2-Chloroethyl)Ether	625	10	1										
67	Bis(2-Chloroisopropyl)Ether	625	10	2										
69	4-Bromophenyl Phenyl Ether	625	10	5										
71	2-Chloronaphthalene	625		10										
72	4-Chlorophenyl Phenyl Ether	625		5										
73	Chrysene	625		10	5									
78	3,3'-Dichlorobenzidine	625		5										
82	2,4-Dinitrotoluene	625	10	5										
83	2,6-Dinitrotoluene	625		5										
85	1,2-Diphenylhydrazine (note) ⁸	625		1										
88	Hexachlorobenzene	625	5	1										
89	Hexachlorobutadiene	625	5	1										
90	Hexachlorocyclopentadiene	625	5	5										
91	Hexachloroethane	625	5	1										
93	Isophorone	625	10	1										
94	Naphthalene	625	10	1	0.2									
95	Nitrobenzene	625	10	1										
96	N-Nitrosodimethylamine	625	10	5										
97	N-Nitrosodi-n-Propylamine	625	10	5										
98	N-Nitrosodiphenylamine	625	10	1										
99	Phenanthrene	625		5	0.05									
101	1,2,4-Trichlorobenzene	625	1	5										
102	Aldrin	608	0.005											
103	α-BHC	608	0.01											
104	β-BHC	608	0.005											
105	γ-BHC (Lindane)	608	0.02											
106	δ-BHC	608	0.005											
107	Chlordane	608	0.1											
108	4,4'-DDT	608	0.01											
109	4,4'-DDE	608	0.05											
110	4,4'-DDD	608	0.05											
111	Dieldrin	608	0.01											
112	Endosulfan (alpha)	608	0.02											
113	Endosulfan (beta)	608	0.01											
114	Endosulfan Sulfate	608	0.05											
115	Endrin	608	0.01											
116	Endrin Aldehyde	608	0.01											
117	Heptachlor	608	0.01											
118	Heptachlor Epoxide	608	0.01											
119-125	PCBs: Aroclors 1016, 1221, 1232, 1242, 1248, 1254, 1260	608	0.5											
126	Toxaphene	608	0.5											

⁸ Measurement for 1,2-Diphenylhydrazine may use azobenzene as a screen: if azobenzene is measured at >1 ug/l, then the Discharger shall analyze for 1,2-Diphenylhydrazine.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

ATTACHMENT H – PRETREATMENT REQUIREMENTS

CALIFORNIA REGIONAL WATER QUALITY CONTROL
BOARD
SAN FRANCISCO BAY REGION

ATTACHMENT H PRETREATMENT PROGRAM PROVISIONS For NPDES POTW WASTEWATER DISCHARGE PERMITS

March 2011
(Corrected May 2011)

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

TABLE OF CONTENTS	Page
I. Pretreatment Program Provisions.....	H-3
II. APPENDIX H-1.....	H-5
REQUIREMENTS FOR PRETREATMENT ANNUAL REPORTS	
A. Cover Sheet.....	H-5
B. Introduction.....	H-5
C. Definitions.....	H-6
D. Discussion of Upset, Interference and Pass Through.....	H-6
E. Influent, Effluent and Biosolids Monitoring Results.....	H-6
F. Inspection, Sampling and Enforcement Programs.....	H-6
G. Updated List of Regulated SIUs.....	H-7
H. SIU (categorical and non-categorical) Compliance Activities.....	H-8
I. Baseline Monitoring Report Update.....	H-9
J. Pretreatment Program Changes.....	H-10
K. Pretreatment Program Budget.....	H-10
L. Public Participation Summary.....	H-10
M. Biosolids Storage and Disposal Practice.....	H-11
N. Other Pollutant Reduction Activities.....	H-11
O. Other Subjects.....	H-11
P. Permit Compliance System (PCS) Data Entry Form.....	H-11
III. APPENDIX H-2.....	H-12
REQUIREMENTS FOR JANUARY-JUNE PRETREATMENT SEMIANNUAL REPORT	
A. Influent, Effluent and Biosolids Monitoring.....	H-12
B. Industrial User Compliance Status.....	H-12
C. Discharger's Compliance with Pretreatment Program Requirements.....	H-13
IV. APPENDIX H-3.....	H-14
SIGNATURE REQUIREMENTS FOR PRETREATMENT ANNUAL AND SEMIANNUAL REPORTS	
V. APPENDIX H-4.....	H-15
REQUIREMENTS FOR INFLUENT, EFFLUENT AND BIOSOLIDS MONITORING	
A. Reduction of Monitoring Frequency.....	H-15
B. Influent and Effluent Monitoring.....	H-15
C. Biosolids Monitoring.....	H-16

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

Attachment H: Pretreatment Program Provisions

- A. The Discharger shall be responsible and liable for the performance of all Control Authority pretreatment requirements contained in 40 C.F.R. 403, including any regulatory revisions to Part 403. Where a Part 403 revision is promulgated after the effective date of the Discharger's permit and places mandatory actions upon the Discharger as Control Authority but does not specify a timetable for completion of the actions, the Discharger shall complete the required actions within six months from the issuance date of this permit or six months from the effective date of the Part 403 revisions, whichever comes later.

(If the Discharger cannot complete the required actions within the above six-month period due to the need to process local adoption of sewer use ordinance modifications or other substantial pretreatment program modifications, the Discharger shall notify the Executive Officer in writing at least 60 days prior to the six-month deadline. The written notification shall include a summary of completed required actions, an explanation for why the six month deadline cannot be met, and a proposed timeframe to complete the rest of the required actions as soon as practical but not later than within twelve months of the issuance date of this permit or twelve months of the effective date of the Part 403 revisions, whichever comes later. The Executive Officer will notify the Discharger in writing within 30 days of receiving the request if the extension is not approved.)

The United States Environmental Protection Agency (U.S. EPA), the State and/or other appropriate parties may initiate enforcement action against a nondomestic user for noncompliance with applicable standards and requirements as provided in the Clean Water Act (Act).

- B. The Discharger shall enforce the requirements promulgated under Sections 307(b), 307(c), 307(d) and 402(b) of the Act with timely, appropriate and effective enforcement actions. The Discharger shall cause nondomestic users subject to Federal Categorical Standards to achieve compliance no later than the date specified in those requirements or, in the case of a new nondomestic user, upon commencement of the discharge.
- C. The Discharger shall perform the pretreatment functions as required in 40 C.F.R. 403 and amendments or modifications thereto including, but not limited to:
1. Implement the necessary legal authorities to fully implement the pretreatment regulations as provided in 40 C.F.R. 403.8(f)(1);
 2. Implement the programmatic functions as provided in 40 C.F.R. 403.8(f)(2);
 3. Publish an annual list of nondomestic users in significant noncompliance as provided per 40 C.F.R. 403.8(f)(2)(viii);
 4. Provide for the requisite funding and personnel to implement the pretreatment program as provided in 40 C.F.R. 403.8(f)(3); and
 5. Enforce the national pretreatment standards for prohibited discharges and categorical standards as provided in 40 C.F.R. 403.5 and 403.6, respectively.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

- D.** The Discharger shall submit annually a report to U.S. EPA Region IX, the State Water Board and the Regional Water Board describing its pretreatment program activities over the previous calendar year. In the event that the Discharger is not in compliance with any conditions or requirements of the Pretreatment Program, the Discharger shall also include the reasons for noncompliance and a plan and schedule for achieving compliance. The report shall contain, but is not limited to, the information specified in Appendix H-1 entitled, “Requirements for Pretreatment Annual Reports.” The annual report is due each year on February 28.
- E.** The Discharger shall submit a pretreatment semiannual report to U.S. EPA Region IX, the State Water Board and the Regional Water Board describing the status of its significant industrial users (SIUs). The report shall contain, but is not limited to, information specified in Appendix H-2 entitled, “Requirements for Pretreatment Semiannual Reports.” The semiannual report is due July 31 for the period January through June. The information for the period July through December of each year shall be included in the Annual Report identified in Appendix H-1. The Executive Officer may exempt the Discharger from the semiannual reporting requirements on a case by case basis subject to State Water Board and U.S. EPA’s comment and approval.
- F.** The Discharger shall conduct the monitoring of its treatment plant’s influent, effluent, and sludge (biosolids) as described in Appendix H-4 entitled, “Requirements for Influent, Effluent and Sludge (Biosolids) Monitoring.” (The term “biosolids,” as used in this Attachment, shall have the same meaning as wastewater treatment plant “sludge” and will be used from this point forward.) The Discharger shall evaluate the results of the sampling and analysis during the preparation of the semiannual and annual reports to identify any trends. Signing the certification statement used to transmit the reports shall be deemed to certify the Discharger has completed this data evaluation. A tabulation of the data shall be included in the pretreatment annual report as specified in Appendix H-4. The Executive Officer may require more or less frequent monitoring on a case by case basis.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

APPENDIX H-1

REQUIREMENTS FOR PRETREATMENT ANNUAL REPORTS

The Pretreatment Annual Report is due each year on February 28 and shall contain activities conducted during the previous calendar year. The purpose of the Annual Report is to:

- Describe the status of the Discharger's pretreatment program; and
- Report on the effectiveness of the program, as determined by comparing the results of the preceding year's program implementation.

The report shall contain, at a minimum, the following information:

A. Cover Sheet

The cover sheet shall include:

1. The name(s) and National Pollutant Discharge Elimination System (NPDES) permit number(s) of the Discharger(s) that is part of the Pretreatment Program;
2. The name, address and telephone number of a pretreatment contact person;
3. The period covered in the report;
4. A statement of truthfulness; and
5. The dated signature of a principal executive officer, ranking elected official, or other duly authorized employee who is responsible for overall operation of the Publicly Owned Treatment Works (POTW) (40 C.F.R. 403.12(m)).

B. Introduction

This section shall include:

1. Any pertinent background information related to the Discharger and/or the nondomestic user base of the area;
2. List of applicable interagency agreements used to implement the Discharger's pretreatment program (e.g., Memoranda of Understanding (MOU) with satellite sanitary sewer collection systems); and
3. A status summary of the tasks required by a Pretreatment Compliance Inspection (PCI), Pretreatment Compliance Audit (PCA), Cleanup and Abatement Order (CAO), or other pretreatment-related enforcement actions required by the Regional Water Board or the U.S. EPA. A more detailed discussion can be referenced and included in the section entitled, "Program Changes," if needed.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

C. Definitions

This section shall include a list of key terms and their definitions that the Discharger uses to describe or characterize elements of its pretreatment program, or the Discharger may provide a reference to its website if the applicable definitions are available on-line.

D. Discussion of Upset, Interference and Pass Through

This section shall include a discussion of Upset, Interference or Pass Through incidents, if any, at the Discharger's treatment plant(s) that the Discharger knows of or suspects were caused by nondomestic user discharges. Each incident shall be described, at a minimum, consisting of the following information:

1. A description of what occurred;
2. A description of what was done to identify the source;
3. The name and address of the nondomestic user responsible;
4. The reason(s) why the incident occurred;
5. A description of the corrective actions taken; and
6. An examination of the local and federal discharge limits and requirements for the purposes of determining whether any additional limits or changes to existing requirements may be necessary to prevent other Upset, Interference or Pass Through incidents.

E. Influent, Effluent and Biosolids Monitoring Results

The Discharger shall evaluate the influent, effluent and biosolids monitoring results as specified in Appendix H-4 in preparation of this report. The Discharger shall retain the analytical laboratory reports with the Quality Assurance and Quality Control (QA/QC) data validation and make these reports available upon request.

This section shall include:

1. Description of the sampling procedures and an analysis of the results (see Appendix H-4 for specific requirements);
2. Tabular summary of the compounds detected (compounds measured above the detection limit for the analytical method used) for the monitoring data generated during the reporting year as specified in Appendix H-4;
3. Discussion of the investigation findings into any contributing sources of the compounds that exceed NPDES limits; and
4. Graphical representation of the influent and effluent metal monitoring data for the past five years with a discussion of any trends.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

F. Inspection, Sampling and Enforcement Programs

This section shall include at a minimum the following information:

1. Inspections: Summary of the inspection program (e.g., criteria for determining the frequency of inspections and inspection procedures);
2. Sampling Events: Summary of the sampling program (e.g., criteria for determining the frequency of sampling and chain of custody procedures); and
3. Enforcement: Summary of Enforcement Response Plan (ERP) implementation including dates for adoption, last revision and submission to the Regional Water Board.

G. Updated List of Regulated SIUs

This section shall contain a list of all of the federal categories that apply to SIUs regulated by the Discharger. The specific categories shall be listed including the applicable 40 C.F.R. subpart and section, and pretreatment standards (both maximum and average limits). Local limits developed by the Discharger shall be presented in a table including the applicability of the local limits to SIUs. If local limits do not apply uniformly to SIUs, specify the applicability in the tables listing the categorical industrial users (CIUs) and non-categorical SIUs. Tables developed in Sections 7A and 7B can be used to present or reference this information.

1. CIUs - Include a table that alphabetically lists the CIUs regulated by the Discharger as of the end of the reporting period. This list shall include:
 - a. Name;
 - b. Address;
 - c. Applicable federal category(ies);
 - d. Reference to the location where the applicable Federal Categorical Standards are presented in the report;
 - e. Identify all deletions and additions keyed to the list submitted in the previous annual report. All deletions shall be briefly explained (e.g., closure, name change, ownership change, reclassification, declassification); and
 - f. Information, calculations and data used to determine the limits for those CIUs for which a combined waste stream formula is applied.
2. Non-categorical SIUs - Include a table that alphabetically lists the SIUs not subject to any federal categorical standards that were regulated by the Discharger as of the end of the reporting period. This list shall include:
 - a. Name;

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

- b. Address;
- c. A brief description of the type of business;
- d. Identify all deletions and additions keyed to the list submitted in the previous annual report. All deletions shall be briefly explained (e.g., closure, name change, ownership change, reclassification, declassification); and
- e. Indicate the applicable discharge limits (e.g., different from local limits) to which the SIUs are subject and reference to the location where the applicable limits (e.g., local discharge limits) are presented in the report.

H. SIU (categorical and non-categorical) Compliance Activities

The information required in this section may be combined in the table developed in Section 7 above.

- 1. Inspection and Sampling Summary:** This section shall contain a summary of all the SIU inspections and sampling activities conducted by the Discharger and sampling activities conducted by the SIU over the reporting year to gather information and data regarding SIU compliance. The summary shall include:
 - a. The number of inspections and sampling events conducted for each SIU by the Discharger;
 - b. The number of sampling events conducted by the SIU. Identify SIUs that are operating under an approved Total Toxic Organic Management Plan;
 - c. The quarters in which the above activities were conducted; and
 - d. The compliance status of each SIU, delineated by quarter, and characterized using all applicable descriptions as given below:
 - (1) Consistent compliance;
 - (2) Inconsistent compliance;
 - (3) Significant noncompliance;
 - (4) On a compliance schedule to achieve compliance (include the date final compliance is required);
 - (5) Not in compliance and not on a compliance schedule; and
 - (6) Compliance status unknown, and why not.
- 2. Enforcement Summary:** This section shall contain a summary of SIU compliance and enforcement activities during the reporting year. The summary may be included in the summary

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

table developed in section 8A and shall include the names and addresses of all SIUs affected by the actions identified below. For each notice specified in enforcement action “i” through “iv,” indicate whether it was for an infraction of a federal or local standard/limit or requirement.

- a. Warning letters or notices of violations regarding SIUs’ apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements;
 - b. Administrative Orders regarding the SIUs’ apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements;
 - c. Civil actions regarding the SIUs’ apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements;
 - d. Criminal actions regarding the SIUs’ apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements;
 - e. Assessment of monetary penalties. Identify the amount of penalty in each case and reason for assessing the penalty;
 - f. Order to restrict/suspend discharge to the Discharger; and
 - g. Order to disconnect the discharge from entering the Discharger.
3. **July-December Semiannual Data:** For SIU violations/noncompliance during the semiannual reporting period from July 1 through December 31, provide the following information:
- a. Name and facility address of the SIU;
 - b. Indicate if the SIU is subject to Federal Categorical Standards; if so, specify the category including the subpart that applies;
 - c. For SIUs subject to Federal Categorical Standards, indicate if the violation is of a categorical or local standard;
 - d. Indicate the compliance status of the SIU for the two quarters of the reporting period; and
 - e. For violations/noncompliance identified in the reporting period, provide:
 - (1) The date(s) of violation(s);
 - (2) The parameters and corresponding concentrations exceeding the limits and the discharge limits for these parameters; and

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

- (3) A brief summary of the noncompliant event(s) and the steps that are being taken to achieve compliance.

I. Baseline Monitoring Report Update

This section shall provide a list of CIUs added to the pretreatment program since the last annual report. This list of new CIUs shall summarize the status of the respective Baseline Monitoring Reports (BMR). The BMR must contain the information specified in 40 C.F.R. 403.12(b). For each new CIU, the summary shall indicate when the BMR was due; when the CIU was notified by the Discharger of this requirement; when the CIU submitted the report; and/or when the report is due.

J. Pretreatment Program Changes

This section shall contain a description of any significant changes in the Pretreatment Program during the past year including, but not limited to:

1. Legal authority;
2. Local limits;
3. Monitoring/ inspection program and frequency;
4. Enforcement protocol;
5. Program's administrative structure;
6. Staffing level;
7. Resource requirements;
8. Funding mechanism;
9. If the manager of the Discharger's pretreatment program changed, a revised organizational chart shall be included; and
10. If any element(s) of the program is in the process of being modified, this intention shall also be indicated.

K. Pretreatment Program Budget

This section shall present the budget spent on the Pretreatment Program. The budget, either by the calendar or fiscal year, shall show the total expenses required to implement the pretreatment program. A brief discussion of the source(s) of funding shall be provided. In addition, the Discharger shall make available upon request specific details on its pretreatment program expense amounts such as for personnel, equipment, and chemical analyses.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

L. Public Participation Summary

This section shall include a copy of the public notice as required in 40 C.F.R. 403.8(f)(2)(viii). If a notice was not published, the reason shall be stated.

M. Biosolids Storage and Disposal Practice

This section shall describe how treated biosolids are stored and ultimately disposed. If a biosolids storage area is used, it shall be described in detail including its location, containment features and biosolids handling procedures.

N. Other Pollutant Reduction Activities

This section shall include a brief description of any programs the Discharger implements to reduce pollutants from nondomestic users that are not classified as SIUs. If the Discharger submits any of this program information in an Annual Pollution Prevention Report, reference to this other report shall satisfy this reporting requirement.

O. Other Subjects

Other information related to the Pretreatment Program that does not fit into any of the above categories should be included in this section.

P. Permit Compliance System (PCS) Data Entry Form

The annual report shall include the PCS Data Entry Form. This form shall summarize the enforcement actions taken against SIUs in the past year. This form shall include the following information:

1. Discharger's name,
2. NPDES Permit number,
3. Period covered by the report,
4. Number of SIUs in significant noncompliance (SNC) that are on a pretreatment compliance schedule,
5. Number of notices of violation and administrative Orders issued against SIUs,
6. Number of civil and criminal judicial actions against SIUs,
7. Number of SIUs that have been published as a result of being in SNC, and
8. Number of SIUs from which penalties have been collected.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

APPENDIX H-2

REQUIREMENTS FOR JANUARY-JUNE PRETREATMENT SEMIANNUAL REPORT

The pretreatment semiannual report is due on July 31 for pretreatment program activities conducted from January through June unless an exception has been granted by the Regional Water Board's Executive Officer (e.g., pretreatment programs without any SIUs may qualify for an exception to the pretreatment semiannual report). Pretreatment activities conducted from July through December of each year shall be included in the Pretreatment Annual Report as specified in Appendix H-1. The pretreatment semiannual report shall contain, at a minimum the following information:

A. Influent, Effluent and Biosolids Monitoring

The influent, effluent and biosolids monitoring results shall be evaluated in preparation of this report. The Discharger shall retain analytical laboratory reports with the QA/QC data validation and make these reports available upon request. The Discharger shall also make available upon request a description of its influent, effluent and biosolids sampling procedures. Violations of any parameter that exceed NPDES limits shall be identified and reported. The contributing source(s) of the parameters that exceed NPDES limits shall be investigated and discussed.

B. Significant Industrial User Compliance Status

This section shall contain a list of all SIUs that were not in consistent compliance with all pretreatment standards/limits or requirements for the reporting period. For the reported SIUs, the compliance status for the previous semiannual reporting period shall be included. Once the SIU has determined to be out of compliance, the SIU shall be included in subsequent reports until consistent compliance has been achieved. A brief description detailing the actions that the SIU undertook to come back into compliance shall be provided.

For each SIU on the list, the following information shall be provided:

1. Name and facility address of the SIU;
2. Indicate if the SIU is subject to Federal Categorical Standards; if so, specify the category including the subpart that applies;
3. For SIUs subject to Federal Categorical Standards, indicate if the violation is of a categorical or local standard;
4. Indicate the compliance status of the SIU for the two quarters of the reporting period; and
5. For violations/noncompliance identified in the reporting period, provide:
 - a. The date(s) of violation(s);
 - b. The parameters and corresponding concentrations exceeding the limits and the discharge limits for these parameters; and

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

- c. A brief summary of the noncompliant event(s) and the steps that are being taken to achieve compliance.

C. Discharger's Compliance with Pretreatment Program Requirements

This section shall contain a discussion of the Discharger's compliance status with the Pretreatment Program Requirements as indicated in the latest Pretreatment Compliance Audit (PCA) Report or Pretreatment Compliance Inspection (PCI) Report. It shall contain a summary of the following information:

1. Date of latest PCA or PCI report;
2. Date of the Discharger's response;
3. List of unresolved issues; and
4. Plan(s) and schedule for resolving the remaining issues.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

APPENDIX H-3

SIGNATURE REQUIREMENTS FOR PRETREATMENT ANNUAL AND SEMIANNUAL REPORTS

The pretreatment annual and semiannual reports shall be signed by a principal executive officer, ranking elected official, or other duly authorized employee who is responsible for the overall operation of the Discharger [POTW - 40 C.F.R. 403.12(m)]. Signed copies of the reports shall be submitted to the State Water Board and the Regional Water Board through the electronic self-monitoring report (eSMR) module of the California Integrated Water Quality System (CIWQS). Signed copies of the reports shall also be submitted electronically to U.S. EPA at R9Pretreatment@epa.gov or as instructed otherwise.

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

APPENDIX H-4

REQUIREMENTS FOR INFLUENT, EFFLUENT AND BIOSOLIDS MONITORING

The Discharger shall conduct sampling of its treatment plant's influent, effluent and biosolids at the frequency shown in **the pretreatment requirements table** of the Monitoring and Reporting Program (MRP, Attachment E). When sampling periods coincide, one set of test results, reported separately, may be used for those parameters that are required to be monitored by both the influent and effluent monitoring requirements of the MRP and the Pretreatment Program. The Pretreatment Program monitoring reports as required in Appendices H-1 and H-2 shall be transmitted to the Pretreatment Program Coordinator.

A. Reduction of Monitoring Frequency

The minimum frequency of Pretreatment Program influent, effluent, and biosolids monitoring shall be dependent on the number of SIUs identified in the Discharger's Pretreatment Program as indicated in Table H-1.

Table H-1: Minimum Frequency of Pretreatment Program Monitoring	
Number of SIUs	Minimum Frequency
< 5	Once every five years
> 5 and < 50	Once every year
> 50	Twice per year

If the Discharger's required monitoring frequency is greater than the minimum specified in Table H-1, the Discharger may request a reduced monitoring frequency for that constituent(s) as part of its application for permit reissuance if it meets the following criteria:

The monitoring data for the constituent(s) consistently show non-detect (ND) levels for the effluent monitoring and very low (i.e., near ND) levels for influent and biosolids monitoring for a minimum of eight previous years' worth of data.

The Discharger's request shall include tabular summaries of the data and a description of the trends in the industrial, commercial, and residential customers in the Discharger's service area that demonstrate control over the sources of the constituent(s). The Regional Water Board may grant a reduced monitoring frequency in the reissued permit after considering the information provided by the Discharger and any other relevant information.

B. Influent and Effluent Monitoring

The Discharger shall monitor for the parameters using the required sampling and test methods listed in **the pretreatment table** of the MRP. Any test method substitutions must have received prior written Executive Officer approval. Influent and effluent sampling locations shall be the same as those sites specified in the MRP.

City and County of San Francisco
 Oceanside Water Pollution Control Plant, Wastewater
 Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
 NPDES No. CA0037681

The influent and effluent samples should be taken at staggered times to account for treatment plant detention time. Appropriately staggered sampling is considered consistent with the requirement for collection of effluent samples coincident with influent samples in Section III.A.3.a(2) of Attachment D. All samples must be representative of daily operations. Sampling and analysis shall be performed in accordance with the techniques prescribed in 40 C.F.R. 136 and amendments thereto. For effluent monitoring, the reporting limits for the individual parameters shall be at or below the minimum levels (MLs) as stated in the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (2000) [also known as the State Implementation Policy (SIP)]; any revisions to the MLs shall be adhered to. If a parameter does not have a stated ML, then the Discharger shall conduct the analysis using the lowest commercially available and reasonably achievable detection levels.

The following report elements should be used to submit the influent and effluent monitoring results. A similarly structured format may be used but will be subject to Regional Water Board approval. The monitoring reports shall be submitted with the Pretreatment Annual Report identified in Appendix H-1.

1. Sampling Procedures, Sample Dechlorination, Sample Compositing, and Data Validation (applicable quality assurance/quality control) shall be performed in accordance with the techniques prescribed in 40 C.F.R. 136 and amendments thereto. The Discharger shall make available upon request its sampling procedures including methods of dechlorination, compositing, and data validation.
2. A tabulation of the test results for the detected parameters shall be provided.
3. Discussion of Results – The report shall include a complete discussion of the test results for the detected parameters. If any pollutants are detected in sufficient concentration to upset, interfere or pass through plant operations, the type of pollutant(s) and potential source(s) shall be noted, along with a plan of action to control, eliminate, and/or monitor the pollutant(s). Any apparent generation and/or destruction of pollutants attributable to chlorination/dechlorination sampling and analysis practices shall be noted.

C. Biosolids Monitoring

Biosolids should be sampled in a manner that will be representative of the biosolids generated from the influent and effluent monitoring events except as noted in (3. below. The same parameters required for influent and effluent analysis shall be included in the biosolids analysis. The biosolids analyzed shall be a composite sample of the biosolids for final disposal consisting of:

1. Biosolids lagoons – 20 grab samples collected at representative equidistant intervals (grid pattern) and composited as a single grab, or
2. Dried stockpile – 20 grab samples collected at various representative locations and depths and composited as a single grab, or

City and County of San Francisco
Oceanside Water Pollution Control Plant, Wastewater
Collection System, and Westside Recycled Water Project

Order No. R2-2019-0028
NPDES No. CA0037681

3. Dewatered biosolids - daily composite of 4 representative grab samples each day for 5 days taken at equal intervals during the daily operating shift taken from a) the dewatering units or b) each truckload, and shall be combined into a single 5- day composite.

The U.S. EPA manual, POTW Sludge Sampling and Analysis Guidance Document, August 1989, containing detailed sampling protocols specific to biosolids is recommended as a guidance for sampling procedures. The U.S. EPA manual Analytical Methods of the National Sewage Sludge Survey, September 1990, containing detailed analytical protocols specific to biosolids, is recommended as a guidance for analytical methods.

In determining if the biosolids are a hazardous waste, the Discharger shall adhere to Article 2, "Criteria for Identifying the Characteristics of Hazardous Waste," and Article 3, "Characteristics of Hazardous Waste," of Title 22, California Code of Regulations, sections 66261.10 to 66261.24 and all amendments thereto.

The following report elements should be used to submit the biosolids monitoring results. A similarly structured form may be used but will be subject to Regional Water Board approval. The results shall be submitted with the Pretreatment Annual Report identified in Appendix H-1.

- Sampling Procedures and Data Validation (applicable quality assurance/quality control) shall be performed in accordance with the techniques prescribed in 40 C.F.R. 136 and amendments thereto. The Discharger shall make available upon request its biosolids sampling procedures and data validation methods.
- Test Results – Tabulate the test results for the detected parameters and include the percent solids.
- Discussion of Results – Include a complete discussion of test results for the detected parameters. If the detected pollutant(s) is reasonably deemed to have an adverse effect on biosolids disposal, a plan of action to control, eliminate, and/or monitor the pollutant(s) and the known or potential source(s) shall be included. Any apparent generation and/or destruction of pollutants attributable to chlorination/dechlorination sampling and analysis practices shall be noted.

The Discharger shall also provide a summary table presenting any influent, effluent or biosolids monitoring data for non-priority pollutants that the Discharger believes may be causing or contributing to interference, pass through or adversely impacting biosolids quality.

Exhibit 2

IN RE CITY AND COUNTY OF SAN FRANCISCO

NPDES Appeal No. 20-01

ORDER DENYING REVIEW

Decided December 1, 2020

Syllabus

The City and County of San Francisco (“San Francisco”) petitioned the Environmental Appeals Board to review U.S. Environmental Protection Agency’s (“EPA’s”) Region 9 (“Region”) authorization to discharge under the National Pollutant Discharge Elimination System (“NPDES”) permitting program of the Clean Water Act. The Region jointly issued its authorization with the California Regional Water Quality Control Board for the San Francisco Bay Region (“California RWQCB”), allowing San Francisco to discharge from its existing combined sewer system (which includes its wastewater treatment facility and waste collection system) into the Pacific Ocean.

San Francisco contests three of the permit’s conditions: (1) a narrative prohibition against causing or contributing to a violation of any water quality standards (section V and attachment G.I.I.1); (2) a requirement to report on sewer overflows from the combined sewer system (section VI.C.5.a.ii.b); and (3) a requirement to update the long-term control plan (“LTCP”) (section VI.C.5.d). Additionally, San Francisco challenges the Region’s characterization of the joint authorization to discharge as two permits, rather than one.

Held: San Francisco has not demonstrated that review is warranted on any of the grounds presented. As such the Board denies the petition for review in all respects.

(1) The Board concludes that the respective permitting processes for the Region’s authorization and that of the California RWQCB were consolidated under 40 C.F.R. § 124.4(c)(2). As a result, San Francisco received dual authorizations for the continued operation of its facility, regardless whether those authorizations are characterized as one permit or two. San Francisco fails to establish clear error as to either the consolidated NPDES permitting process or the differing characterizations of the dual authorizations.

(2) San Francisco fails to carry its burden with respect to its arguments that the Region lacks a legal or factual basis to include a narrative prohibition against violating water quality standards in the receiving waters or that the prohibition deprives San Francisco of fair notice. Under the Clean Water Act, permit issuers are required to include

in every NPDES permit conditions that ensure that water quality standards will be met. Although 40 C.F.R. § 122.44(d) sets forth a process for deriving pollutant-specific effluent limits, the regulations do not require that all permit conditions necessary to meet water quality standards be expressed in terms of specific pollutant-by-pollutant limitations. Given the Region's responsibility to determine what conditions are appropriate to include in the permit, its legal obligation to ensure that water quality standards are met, the legal authority to include a narrative prohibition against violating water quality standards, and its determination that the water quality-based effluent limitations elsewhere in the permit may not necessarily meet that obligation, the Board concludes that the contested narrative prohibitions were not clearly erroneous. Additionally, San Francisco has not identified any language in the narrative prohibitions, or the water quality standards that apply, that is vague or unclear so as to deprive San Francisco of fair notice.

(3) The Board concludes that San Francisco's argument concerning the requirement to report on isolated sewer overflows (for example, backups into basements or onto streets through manholes) misapprehends the function of the permit condition at issue and fails to carry San Francisco's burden to show that the Region's inclusion of the reporting requirement constituted clear error. The requirement to report on isolated sewer overflows is not to "regulate" them, as argued by San Francisco. Rather, the frequency, cause, and location of isolated sewer overflows can be indicative of whether the permitted combined sewer system is operating appropriately. As such, the reporting requirement is an appropriate mechanism, grounded in the Combined Sewer Overflow Control Policy and the Clean Water Act more generally, to determine whether the permitted combined sewer system is operating in compliance with the permit, including the requirement to maximize storage without increasing upstream flooding into basements and streets, which can negatively impact human health and the environment.

(4) The Board concludes that San Francisco has not demonstrated that the Region's decision to include permit terms requiring San Francisco to update its LTCP is clearly erroneous. The Region's decision to require San Francisco to update its LTCP—to ensure that up-to-date information is used to assess whether, among other things, water quality standards are being met and to ensure that wet weather discharges are not causing unreasonable degradation of the marine environment—is entirely consistent with the aims of the Clean Water Act and its incorporation of the Combined Sewer Overflow Control Policy. Permitting authorities are required to issue permits that comply with the Clean Water Act, which in the case of combined sewer systems reasonably can include updates to long-term control plans, particularly where such plans are decades old. Additionally, the Board concludes that the Region's decision to require an LTCP update was well supported by the facts given that San Francisco's LTCP consists of a compilation of documents developed over the course of two decades (the most recent document being a 1990 revision of a 1988 document), making it difficult to discern the relationship between the documents. Information related to the existing sewer system, potential technology and water-quality based requirements that are intended to shape the system, and collection system improvement opportunities is clearly relevant to San Francisco's long-term plans

to control combined sewer overflows. Such information is also relevant to the Region's determination as to whether San Francisco's long-term plans will ensure compliance with the Clean Water Act, including the Combined Sewer Overflow Control Policy. The Board also concludes that the permit clearly describes, defines, and articulates the tasks required, giving San Francisco fair notice of what is required to comply with the Permit.

Before Environmental Appeals Judges Aaron P. Avila, Mary Kay Lynch, and Kathie A. Stein.

Opinion of the Board by Judge Avila:

I. INTRODUCTION

The U.S. Environmental Protection Agency ("EPA") Region 9 ("Region") and the California Regional Water Quality Control Board for the San Francisco Bay Region ("California RWQCB") jointly authorized the City and County of San Francisco ("San Francisco") to discharge from San Francisco's existing Oceanside combined sewer system (which includes its wastewater treatment facility and its wastewater collection system) ("Oceanside CSS") under the National Pollutant Discharge Elimination System ("NPDES") permitting program of the Clean Water Act.¹ The two permitting agencies processed their respective permit authorizations together because San Francisco's facility discharges into the Pacific Ocean, and those discharges are regulated by both EPA (for discharges more than three miles offshore) and the State (for discharges inside of three miles offshore).

¹ San Francisco owns and operates the Oceanside Water Pollution Control Plant and its waste collection system. Region 9, U.S. EPA, & Cal. Reg'l Water Quality Control Bd., S.F. Bay Region, *Oceanside Water Pollution Control Plant, Wastewater Collection System, and Westside Recycled Water Project, Fact Sheet for NPDES Permit No. CA0037681*, at F-3 (Dec. 10, 2019) (A.R. 17f) ("Fact Sheet") (appended to NPDES Permit No. CA0037681 as attach. F). This system was last permitted in 2009. See Region 9, U.S. EPA, & Cal. Reg'l Water Quality Control Bd., S.F. Bay Region, *NPDES Permit for City and County of San Francisco Oceanside Water Pollution Control Plant and Collection System, including the Westside Wet Weather Facilities, NPDES No. CA0037681, Order R2-2009-0062* (Aug. 12, 2009) (A.R. 81) ("2009 Permit"); see also Fact Sheet at F-4. During the term of the permit at issue here, San Francisco plans to construct, own, and operate the Westside Recycled Water Project. Fact Sheet at F-3. Collectively, the Oceanside Water Pollution Control Plant, its waste collection system, and the Westside Recycled Water Project (or any portion thereof) are referred to in this decision as the "Oceanside CSS."

In January 2020, San Francisco petitioned the Environmental Appeals Board (“Board”) to review the Region’s permit decision, contesting three of the permit’s conditions: (1) a narrative prohibition against causing or contributing to a violation of any water quality standards (section V and attachment G at G.I.I.1); (2) a requirement to report on sewer overflows from the combined sewer system (section VI.C.5.a.ii.b); and (3) a requirement to update the long-term control plan (section VI.C.5.d). *See* San Francisco Petition for Review of Oceanside Wastewater Treatment Plant’s NPDES Permit 2 (Jan. 13, 2020) (“Petition”). Additionally, in response to the Region’s notice regarding the stay of permit conditions pending appeal, San Francisco challenges the Region’s characterization of the joint authorization to discharge as two permits, rather than one. Final briefing for this appeal was completed in September 2020. Oral argument was held in October 2020. For the reasons stated below, the Board denies the Petition for Review in its entirety.

II. *PRINCIPLES GOVERNING BOARD REVIEW*

Section 124.19 of Title 40 of the Code of Federal Regulations governs Board review of an NPDES permit. In any appeal from a permit decision issued under part 124, the petitioner bears the burden of demonstrating that review is warranted. *See* 40 C.F.R. § 124.19(a)(4). “[A] petition for review must identify the contested permit condition or other specific challenge to the permit decision and clearly set forth, with legal and factual support, petitioner’s contentions for why the permit decision should be reviewed.” *Id.* § 124.19(a)(4)(i).

In considering whether to grant or deny a petition for review, the Board is guided by the preamble to the regulations authorizing appeal under part 124, in which the Agency stated that the Board’s power to grant review “should be only sparingly exercised,” and that “most permit conditions should be finally determined at the [permit issuer’s] level.” Consolidated Permit Regulations, 45 Fed. Reg. 33,290, 33,412 (May 19, 1980). The Board will ordinarily deny a petition for review and thus not remand the permit unless the underlying permit decision is based on a clearly erroneous finding of fact or conclusion of law. 40 C.F.R. § 124.19(a)(4)(i).

When evaluating a challenged permit decision for clear error, the Board examines the administrative record that serves as the basis for the permit decision to determine whether the permit issuer exercised “considered judgment.” *E.g.*, *In re Steel Dynamics, Inc.*, 9 E.A.D. 165, 191, 224-25 (EAB 2000); *In re Ash Grove Cement Co.*, 7 E.A.D. 387, 417-18 (EAB 1997). The permit issuer must articulate with reasonable clarity the reasons supporting its conclusion and the significance of the crucial facts it relied on when reaching its conclusion. *E.g.*, *Ash Grove*,

7 E.A.D. at 417. As a whole, the record must demonstrate that the permit issuer “duly considered the issues raised in the comments” and ultimately adopted an approach that “is rational in light of all information in the record.” *In re Gov’t of D.C. Mun. Sep. Storm Sewer Sys.*, 10 E.A.D. 323, 342 (EAB 2002); *accord In re City of Moscow*, 10 E.A.D. 135, 142 (EAB 2001); *In re NE Hub Partners, L.P.*, 7 E.A.D. 561, 568 (EAB 1998), *pet. for review denied sub nom. Penn Fuel Gas, Inc. v. EPA*, 185 F.3d 862 (3d Cir. 1999).

On matters that are fundamentally technical or scientific in nature, the Board typically defers to a permit issuer’s technical expertise and experience, again, as long as the permit issuer has adequately explained its rationale and supported its reasoning in the administrative record. *See In re Dominion Energy Brayton Point, L.L.C.*, 12 E.A.D. 490, 510, 560-62, 645-47, 668, 670-74 (EAB 2006); *see also, e.g., In re Russell City Energy Ctr., L.L.C.*, 15 E.A.D. 1, 12, 39-42, 66 (EAB 2010), *pet. for review denied sub nom. Chabot-Las Positas Cmty. Coll. Dist. v. EPA*, 482 F. App’x 219 (9th Cir. 2012); *NE Hub Partners*, 7 E.A.D. at 570, 571.

III. RELEVANT CLEAN WATER ACT PROVISIONS AND IMPLEMENTING REGULATIONS

In 1972, Congress enacted the Clean Water Act (“CWA”) “to restore and maintain the chemical, physical, and biological integrity of the Nation’s waters.” *See* CWA §§ 101(a), 33 U.S.C. §§ 1251(a). To achieve this objective, the CWA prohibits the discharge of pollutants into the waters of the United States, unless authorized by an NPDES permit or other specified CWA provision. *See* CWA §§ 301(a), 402, 502(7), 33 U.S.C. §§ 1311(a), 1342, 1362(7).

A. National Pollutant Discharge Elimination System Permits Generally

NPDES permits rely on two statutory mechanisms to protect water quality: (1) water quality standards, and (2) effluent limitations. *See generally* CWA §§ 301, 303, 304(b), 33 U.S.C. §§ 1311, 1313, 1314(b); 40 C.F.R. pts. 122, 125, 131. Water quality standards are promulgated by states and approved by EPA. *See* CWA § 303(a), (c), 33 U.S.C. § 1313(a), (c); 40 C.F.R. §§ 131.10-.12. Water quality standards include three components: (1) the “designated uses” of a waterbody, such as public drinking supply, recreation, or wildlife habitat; (2) “water quality criteria,” expressed in numeric or narrative form, specifying the amount of various pollutants that may be present in the waterbody without impairing the waterbody’s designated uses; and (3) an “antidegradation” provision that protects existing uses and high quality waters. 40 C.F.R. §§ 131.10-.12; *see also* CWA § 303(c)(2)(A), 33 U.S.C. § 1313(c)(2)(A). The CWA and its implementing regulations require permitting authorities to ensure that any permit

issued complies with the CWA and the water quality standards of all states affected by the discharge. *See* CWA §§ 301(b)(1)(C), 401(a)(1)-(2), 33 U.S.C. §§ 1311(b)(1)(C), 1341(a)(1)-(2); 40 C.F.R. §§ 122.4(d), .44(d)(1).

Generally speaking, effluent limits are either technology based (typically established by the permitting authority on an industry-specific basis) or water quality based (developed in the context of individual permit decisions). *See* CWA §§ 301(b), 302, 303(c), (d), 33 U.S.C. §§ 1311, 1312, 1313(c), (d); 40 C.F.R. §§ 122.44, 125.3(a). Water quality-based effluent limits (“WQBELs”) control pollutant discharges by restricting the types and amounts of particular pollutants a permitted entity may lawfully discharge. *See* 40 C.F.R. § 122.44(d).

NPDES permits can be issued either by EPA or by states with authorized programs. *See generally* CWA § 402, 33 U.S.C. § 1342. Where EPA has approved a state’s submitted program under CWA section 402(b), the state administers its approved NPDES permit program and EPA suspends its issuance of NPDES permits as to discharges into navigable waters *within the state’s own boundaries*. *See id.* § 1342(b), (c); 40 C.F.R. § 123.1(d)(1). EPA has approved the State of California’s program to implement the NPDES program through the State Water Resources Control Board and its nine Regional Water Quality Control Boards. *See* Approval of California’s Revisions to the State National Pollutant Discharge Elimination System Program, 54 Fed. Reg. 40,664, 40,664-65 (Oct. 3, 1989); Discharges of Pollutants to Navigable Waters: Approval of State Programs, 39 Fed. Reg. 26,061, 26,061 (July 16, 1974). Nearshore waters, i.e., waters in the Pacific Ocean within three miles from shore, are considered within the boundary of California (they are also referred to as the “territorial waters” of the state) and are therefore subject to California’s approved program. *See* Fact Sheet at F-6. Discharges into the Pacific Ocean that are beyond three miles from shore are not within the boundary of California and therefore are *not* subject to California’s approved program. Thus, as relevant here, the California RWQCB administers the NPDES program for San Francisco’s nearshore discharges, and EPA administers the NPDES program for San Francisco’s discharges that are beyond three miles from shore.² *See id.* at F-6, F-11.

² This distinction between the state-authorized and the EPA-authorized discharges does not alter the fact that *all* of the authorized discharges from the Oceanside CSS are into the Pacific Ocean, which is considered “navigable waters” and falls under the scope of NPDES regulation for purposes of the CWA. *See* CWA § 502(7), (8), 33 U.S.C. § 1362(7), (8). The parties use the term “state waters” to refer to the “navigable waters” that are

B. *Combined Sewer Overflows*

San Francisco's challenge to this permit involves provisions that relate to combined sewer overflows ("CSOs") within the San Francisco wastewater collection system. Combined sewer systems convey sanitary wastewater (domestic, commercial, and industrial wastewaters) and stormwater through a single pipe system to a wastewater treatment facility. *See* Combined Sewer Overflow (CSO) Control Policy § I.A, 59 Fed. Reg. 18,688, 18,689 (Apr. 19, 1994) (A.R. 96) ("CSO Control Policy"). A CSO is a discharge from a combined sewer system at a point prior to the treatment facility that occurs as a result of a wet weather event. *Id.* Dry weather CSOs are prohibited by the CWA. *Id.* § I.B, at 18,689. Combined sewer systems anticipate significant stormwater events and are designed to overflow directly from CSO outfalls to surface water bodies such as the Pacific Ocean. In addition, when the storage capacity of the entire system is exceeded, isolated sewer overflows ("ISOs"), or spills, can occur from various points of exit other than the permitted CSO outfalls (backups into basements or onto streets through manholes, for example). *See* Office of Water, U.S. EPA, *CSO Guidance for Permit Writers*, at 4-6 (1995) (A.R. 95c) ("CSO Guidance for Permit Writers"); Office of Water, U.S. EPA, *Combined Sewer Overflows Guidance for Nine Minimum Controls*, at 3-3 (1995) (A.R. 95a) ("NMC Guidance").

Discharge from a CSO event consists of mixtures of domestic sewage, industrial and commercial wastewaters, and stormwater runoff. CSO Control Policy § I.A, 59 Fed. Reg. at 18,689. As such, CSOs often contain high levels of suspended solids, pathogenic microorganisms, toxic pollutants, floatables, nutrients, oxygen-demanding organic compounds, oil and grease, and other pollutants. *Id.* CSOs can cause exceedances of water quality standards. Such exceedances may pose risks to human health, threaten aquatic life and its habitat, and impair the use and enjoyment of the nation's waterways. *Id.* Discharges from CSOs are not subject to the secondary treatment requirements applicable to wastewater treatment facilities; they are, however, point source discharges subject to the CWA, including its NPDES permit requirements. *Id.*

EPA issued the CSO Control Policy in 1994 to implement a "comprehensive national strategy" for CSO control to "meet appropriate health and environmental objectives." CSO Control Policy, 59 Fed. Reg. at 18,688. In 2000,

subject to California's approved NPDES program and "federal waters" to refer to the "navigable waters" that are not part of California's approved program and are instead under EPA's NPDES authority.

Congress subsequently codified the CSO Control Policy at section 402(q) of the CWA, 33 U.S.C. § 1342(q), thus making the provisions of the CSO Control Policy part of NPDES permitting law. The CSO Control Policy is intended to facilitate and coordinate the planning, selection, design, and implementation of CSO management practices and controls to meet the requirements of the CWA and to involve the public fully during the decisionmaking process. *Id.* § I.A, 59 Fed. Reg. at 18,689. The policy seeks to review and revise, as appropriate, the implementation of water quality standards when developing CSO control plans to reflect the site-specific wet weather impacts of CSOs. *Id.* The policy applies to all combined sewer systems that overflow as a result of stormwater flow, including those systems that were completed prior to issuance of the policy. *Id.* §§ I.B, .C, 59 Fed. Reg. at 18,689-90 (referencing NPDES permit requirements identified in section IV.B of the CSO Control Policy, which includes requirements for nine minimum controls and the long-term control plan, and providing that, “[for] any ongoing or substantially completed CSO control effort, the NPDES permit * * * should be revised to include all appropriate permit requirements” of the CSO Control Policy).

The CSO Control Policy requires municipalities operating combined sewer systems to “immediately” and “accurately” characterize their sewer systems and demonstrate the implementation of the nine minimum controls (“NMC”) as the minimum technology-based requirements to be imposed on combined sewer systems during wet weather. *Id.* § II.A., B, 59 Fed. Reg. at 18,691 (incorporating CWA § 301(b) requirement to impose best practicable control technology); *see* 40 C.F.R. § 125.3; Fact Sheet at F-29; CSO Guidance for Permit Writers at 3-1, 3-3. Municipalities must also develop and then implement a “Long-Term CSO Control Plan” (“LTCP”). CSO Control Policy § II.A, C, 59 Fed. Reg. at 18,691. The CSO Control Policy allows a phased approach for implementation of CSO controls. *See* CSO Guidance for Permit Writers at 3-1, 4-1. “Phase I permits” require permittees to implement the NMC and develop an LTCP. *Id.* at 3-1; *see also* CSO Control Policy § IV.B.1, 59 Fed. Reg. at 18,696. “Phase II permits” require permittees to implement the LTCP developed in Phase I. CSO Control Policy § IV.B.2, 59 Fed. Reg. at 18,696; CSO Guidance for Permit Writers at 4-1. A permit writer’s responsibilities continue after the issuance of a first Phase II permit; multiple Phase II permits may be required through numerous permit cycles, and a permit writer’s obligation to address CSO controls continues even after implementation of the LTCP in subsequent (or “post-Phase II”) permits to ensure proper operation and maintenance of the CSO controls and appropriate implementation of post-construction compliance monitoring. CSO Guidance for Permit Writers at 5-1 to 5-4.

In recognition that some municipalities were already in the process of managing their CSOs at the time the CSO Control Policy was issued, in certain circumstances permitting authorities could determine on a case-by-case basis that portions of the CSO Control Policy did not apply. CSO Control Policy § I.C., 59 Fed. Reg. at 18,690. The policy also provides that “such programs * * * should be reviewed and modified to be consistent with the sensitive area, financial capability, and post-construction monitoring provisions of [the] Policy.” *Id.*

IV. *PROCEDURAL POSTURE AND RELEVANT FACTS*

San Francisco’s Oceanside CSS includes 250 miles of pipe to collect and transport wastewater from approximately 250,000 residents across western San Francisco to its water pollution control plant for treatment. *See* Fact Sheet at F-4. During dry weather, the water pollution control plant provides secondary treatment, and the system’s maximum secondary treatment capacity is 43 million gallons per day.³ *Id.* at F-5. During wet weather, the system can provide primary treatment for an additional 22 million gallons per day (which is then combined with the secondary-treated effluent before being discharged for a total of 65 million gallons per day), and the system’s storage/transport structures and collection system piping have a combined storage capacity of about 73 million gallons. *Id.* When the volume of stormwater exceeds the system’s capacity, the system discharges the combined effluent through seven nearshore (within California’s boundary) combined sewer discharge structures (or “CSD Outfalls”)⁴ into the Pacific Ocean and through one deepwater ocean outfall that terminates approximately 3.9 nautical miles offshore (outside of California’s boundary and therefore beyond the State’s authority to regulate through its approved NPDES program). *Id.* at F-6. The combined sewer system was designed to achieve a long-term average of eight combined sewer discharges per year. *Id.* at F-7.⁵

³ As mentioned above, San Francisco seeks authorization to add a recycled water project to its system, as part of its current permit renewal. Fact Sheet at F-3.

⁴ The current configuration of the facility is different from prior descriptions of the facility, which described the system as having eight rather than seven CSD Outfalls. *See* Memorandum from Becky Mitschele, NPDES Permit Writer, NPDES Permits Section, to Admin. Record for NPDES Permit No. CA0037681, at 6 n.9 (Apr. 15, 2019) (A.R. 91) (“Memo to File”).

⁵ In 1976, the San Francisco facility existing at that time was required to reduce discharges from an average of 114 overflow events per year to an average of 1 overflow

San Francisco began developing a “Master Plan for Wastewater Management” in the 1970s, part of which included studies to balance system storage, reduce wet weather discharges, and develop control alternatives. *See* Pet. at 4-5; *San Francisco Master Plan for Waste Water Management*, at i, II-1 to II-9 (Sept. 1971) (A.R. 77). Construction began on the Oceanside CSS in the early 1980s and the system was substantially complete by 1993. *See* Pet. at 6. Thus, when the CSO Control Policy was developed in 1994, San Francisco was well into the process of reducing wet weather discharges from its combined sewer system. As a result, the Region and the California RWQCB determined that San Francisco did not need to comply with the initial planning and construction requirements of the CSO Control Policy when they issued its NPDES permit in 1997. Region 9, U.S. EPA & Cal. Reg’l Water Quality Control Bd., S.F. Bay Region, *NPDES Permit for City and County of San Francisco’s Oceanside Water Pollution Control Plant and the Westside Wet Weather Combined Sewer System*, NPDES No. CA0037681, Order 97-044, at 6 (1997) (“1997 Permit”) (A.R. 9, App. 7); *see also* CSO Policy § I.C.1, 59 Fed. Reg. at 18,690.

In subsequent permit renewals, the Region and the California RWQCB determined that San Francisco’s LTCP was consistent with the CSO Control Policy and, thus, did not require San Francisco to conduct the planning and construction tasks required by the CSO Control Policy. Region 9, U.S. EPA, & Cal. Reg’l Water Quality Control Bd., S.F. Bay Region, *NPDES Permit for San Francisco Oceanside Treatment Plant, Sw. Ocean Outfall, and Westside Wet Weather Facilities*, NPDES No. CA0037681, Order R2-2003-0073, at 10, 17 (Aug. 20, 2003) (“2003 Permit”) (A.R. 9, App. 5) (citing CSO Control Policy § I.C.1); Region 9, U.S. EPA, & Cal. Reg’l Water Quality Control Bd., S.F. Bay Region, *NPDES Permit for San Francisco Oceanside Water Pollution Control Plant & Collection System, including the Westside Wet Weather Facilities*, NPDES No. CA0037681, Order R2-2009-0062, at 10 (Aug. 12, 2009) (A.R. 81) (“2009 Permit”) (determining San Francisco’s implementation of its LTCP is “consistent with” CSO Control Policy). In 2011, San Francisco began a Sewer System Improvement Program (“SSIP”) as

per year and to conduct a study to better understand the costs and benefits associated with various overflow frequencies. Cal. State Water Resources Control Bd., Order No. WQ 79-16: In the Matter of the Request for an Exception to the 1978 Water Quality Control Plan for Ocean Waters of Cal., at 1 (1979) (A.R. 102) (“State Water Board Order No. WQ 79-16”) (referencing Cal. Regional Water Quality Control Board, S.F. Bay Region, Order No. 76-23). In 1979, the Regional Water Board amended Order No. 76-23 to allow an average of 8 overflows per year, which was adopted in State Water Board Order No. 79-16. *Id.* at 2, 18.

a twenty-year, citywide investment to enhance the reliability and performance of its wastewater system. Memorandum from Becky Mitschele, NPDES Permit Writer, NPDES Permits Section, to Admin. Record for NPDES Permit No. CA0037681, at 5 (Apr. 15, 2019) (A.R. 91) (“Memo to File”). The SSIP contains information about how the combined sewer system, the sewershed, and the system’s management approach have changed since 1997, including various studies that analyze collection system improvements and that identify collection system opportunities within the drainage basin. *See id.* at 5, 10-11.

In 2014, the Region shared an early draft NPDES permit with San Francisco and received comments from San Francisco in January 2015. San Francisco, Comments on Admin. Draft NPDES Permit (Jan. 8, 2015) (A.R. 24). The permit reissuance process was put on hold when the Region and the California RWQCB sought additional information. In 2016, the Region sent an information request after receiving reports of “raw sewage mixed with stormwater * * * overflowing from the City and County of San Francisco’s [CSS] into streets, sidewalks, residences and businesses.” Letter from Kathleen H. Johnson, Dir., Enforcement Div., Region 9 U.S. EPA, to Harlan Kelly, Gen. Manager, S.F. Pub. Utils. Comm’n, Request for Information under Clean Water Act Section 308(a) (Feb. 16, 2016) (A.R. 146a). In 2017, California RWQCB sent San Francisco a request for additional monitoring data to better understand the quality of the wet weather discharges. Letter from Bruce H. Wolfe, Exec. Officer, California RWQCB, S.F. Bay Region, to Brian Henderson, Acting Assistant Gen. Manager, Wastewater Enterprise, Clarification of Monitoring Requirements and Requirement for Information (Nov. 29, 2017) (A.R. 145).

In March 2018, San Francisco submitted a Long Term Control Plan Synthesis to the California RWQCB in the context of its Bayside permit requirements.⁶ S.F. Pub. Utils. Comm’n, *San Francisco Wastewater Long Term Control Plan Synthesis for the Bayside Permit (NPDES No. CA0037664) & the*

⁶ San Francisco’s “Bayside” combined sewer system discharges to the San Francisco Bay and includes the Southeast Water Pollution Control Plant, North Point Wet Weather Facility, Bayside Wet Weather Facilities, and related wastewater collection system. These discharges are authorized under a separate NPDES permit issued solely by the California RWQCB. *See* Cal. Reg’l Water Quality Control Bd., S.F. Bay Region, *San Francisco Southeast Water Pollution Control Plant, North Point Wet Weather Facility, Bayside Wet Weather Facilities, and Wastewater Collection System*, NPDES No. CA0037664, Order R2-2013-0029, attach B (Facility Map) at B-1, attach. F (Fact Sheet) at F-3 to F-4, (Aug. 19, 2013) (A.R. 79a) (“Bayside Permit”).

Oceanside Permit (NPDES No. CA0037681) (Mar. 30, 2018) (A.R. 88b) (“Synthesis”).⁷ The stated objective of the Synthesis is “to describe the historical planning efforts undertaken” by San Francisco “to minimize and control wet weather discharges from the combined sewer system.” *Id.* at 4. Among other things, the Synthesis identifies various documents that San Francisco maintains “comprise” the LTCP for its combined sewer system. *Id.*

In response to the submittal, California informed San Francisco that the Synthesis “[did] not adequately address the minimum required elements” of the Bayside Permit requirement to update its LTCP. Letter from Bill Johnson, Chief, NPDES Wastewater & Enforcement Div., Cal. RWQCB, S.F. Bay Region, to Amy Chastain, Regulatory Program Manager, S.F. Pub. Utils. Comm’n, regarding Comments on Synthesis, at 1 (Sept. 7, 2018) (A.R. 85). For example, California explained that appendix A of the Synthesis “summarizes documents that comprise [San Francisco’s] Long-Term Control Plan through March 1994, but this does not reflect current circumstances.” *Id.* San Francisco gave a written response to California’s comments, but San Francisco did not, and has not, submitted a revised Synthesis. Letter from Amy Chastain, Regulatory Manager, S.F. Pub. Utils. Comm’n, to Bill Johnson, Cal. RWQCB, regarding Comments on Synthesis & Update (Sept. 21, 2018) (A.R. 88a) (“S.F. Resp. to RWQCB Cmts. on Synthesis”); *see also* Oral Argument Transcript at 26-27 (Oct. 8, 2020) (“Oral Arg. Tr.”) (Counsel for San Francisco stating that he is unaware of an updated plan or synthesis document having been sent to either permitting authority or whether either permitting authority agreed with San Francisco’s September 21, 2018 letter addressing the deficiencies identified by the California RWQCB). The Region determined that, notwithstanding the prior CSO exemption, it was both appropriate and necessary to include a requirement in the Permit at issue here that San Francisco update its LTCP. *See* Fact Sheet at F-30 to F-31 (explaining bases for requirement to update LTCP); Region 9, U.S. EPA, & Cal. Reg’l Water Quality Control Bd., S.F. Bay Region, Response to Comments, at 16-17 (Aug. 30, 2019) (A.R. 10) (“Resp. to Cmts.”). The permitting authorities also added a reporting requirement to the permit for isolated sewer overflows and a narrative prohibition against causing or contributing to a violation of any water quality standards in the receiving

⁷ San Francisco submitted the *Synthesis* to the California RWQCB pursuant to section VI.C.5.c.v. of the Bayside Permit, which required it to “synthesize and update its Long-Term Control Plan into one document that reflects current circumstance.” Bayside Permit at 25. In the Fact Sheet for the Permit that is currently before the Board, the permitting authorities described the *Synthesis* as “summariz[ing] the various documents that comprise [San Francisco’s] historical planning process and LTCP.” Fact Sheet at F-30.

waters. Fact Sheet at F-26, F-30 to F-31; Region 9, U.S. EPA, & Cal. Reg'l Water Quality Control Bd., S.F. Bay Region, *Oceanside Water Pollution Control Plant, Wastewater Collection System, and Westside Recycled Water Project, NPDES Permit No. CA0037681*, §§ V, VI.C.5.a.ii.b at 9, 17 (issued Dec. 10, 2019) (A.R. 17) (signed by Region) ("Permit").

In April 2019, the Region and the California RWQCB issued a public notice and opportunity to comment on the draft permit within 30 days. Resp. to Cmts. at 26. In September 2019, the Region and the RWQCB held a hearing on the permit. Transcript of S.F. Bay Reg'l Water Quality Control Bd. Hearing (Sept. 11, 2019). In addition to San Francisco's voluminous comments on the permit, the Region and the California RWQCB also received comments from numerous members of the public asking the permitting authorities to stop allowing San Francisco to discharge sewage into people's homes and businesses. Resp. to Cmts. at 1-9. The permit was signed by the California RWQCB on September 12, 2019, and became effective as to discharges to state waters on November 1, 2019. Region 9, U.S. EPA, & Cal. Reg'l Water Quality Control Bd., S.F. Bay Region, *Oceanside Water Pollution Control Plant, Wastewater Collection System, and Westside Recycled Water Project, NPDES Permit No. CA0037681*, at 2 (Sept. 11, 2019) (A.R. 15). The Region signed the Oceanside Permit, NPDES No. CA0037681, on December 10, 2019, with an effective date of February 1, 2019. See Permit at 2-3. San Francisco petitioned the Board for review of the Region's permit decision in January 2020.⁸

V. ANALYSIS

San Francisco's petition challenges three permit provisions: (1) the generic water quality based effluent limitations at section V and attachment G.I.I.1; (2) the reporting of isolated sewer overflows at section VI.C.5.a.ii.b; and (3) the long-term control plan update at section VI.C.5.d. Pet. at 2. After San Francisco filed its Petition for Review, and pursuant to 40 C.F.R. § 124.16, the Region issued a Notice of Stay, identifying which provisions of the permit were stayed pending appeal. U.S. EPA Region 9 Notice of Stay of Contested Conditions for NPDES Permit No. CA0037681 (Feb. 7, 2020) ("Notice of Stay"). In that notice, the Region characterized the NPDES authorizations for the Oceanside CSS as two permits—a

⁸ After San Francisco filed its petition with the Board and the Region issued its notice of stayed permit conditions, substantial motions practice and supplemental briefing ensued.

state permit and a federal permit—rather than as a single, jointly issued permit.⁹ As a result, in its Supplement to the Petition, San Francisco seeks either a determination that the Permit is a single, jointly issued permit, or a remand of the Permit with directions to the Region to develop a record that supports the issuance of a standalone federal permit. San Francisco’s Supplement to Petition for Review 33 (Jun. 30, 2020) (“Supp. to Pet.”). The Board addresses San Francisco’s argument in its Supplement to the Petition first.

A. One Permit Versus Two

In issuing their separate authorizations to San Francisco to discharge from the City’s existing Oceanside CSS into the Pacific Ocean, the Region and the California RWQCB consolidated their respective permit processing, as is allowed by 40 C.F.R. § 124.4(c)(2), for efficiency and coordination purposes. Combining that process resulted in a consolidated fact sheet, draft permit, public comment period, response to comments document, and a final consolidated NPDES permit signed by each of two permitting authorities (one federal, one state) albeit on two different dates (three months apart). *See* Permit at 2-3 (including unnumbered EPA signature page); Fact Sheet at F-3, F-34 to F-35; Resp. to Cmts. at 1.

Under regulations governing permit processing, EPA and an approved state “may agree to consolidate draft permits whenever a facility or activity requires permits from both [permit issuers].” 40 C.F.R. § 124.4(c)(2). Although San Francisco argues that the California and EPA permit processes could not have been consolidated under section 124.4(c)(2) because the Region “fail[ed] to follow any of the procedures required for permit consolidation,” San Francisco also acknowledges that the regulations do not specify required procedures for consolidation. Supp. to Pet. at 25-26; *see also*, Order Denying San Francisco’s Motion to Stay 5 n.4 (May 11, 2020) (Docket No. 14) (“Order Denying Motion to Stay”). The regulations also do not require any particular documentation of the agreement or intent to consolidate. *See* Order Denying Motion to Stay at 5 n.4. We also note that a joint permit was issued to San Francisco for all three prior NPDES permits authorizing the operation of the Oceanside CSS. *See*, e.g., 1997 Permit, 2003 Permit, and 2009 Permit. San Francisco identifies no other regulatory process for combining the permit processes. As such, we conclude that the permitting

⁹ Additional history and background on this issue is available in the Order Denying San Francisco’s Motion to Stay (May 11, 2020) (Docket No. 14) (“Order Denying Motion to Stay”), and the related filings in the appeal docket for this case.

process for these two authorizations was consolidated under 40 C.F.R. § 124.4(c)(2).

After San Francisco appealed to the Board, the Region issued the Notice of Stay of the contested permit conditions, as it is required to do under 40 C.F.R. section 124.16. In that notice, the Region for the first time described the dual authorization as two permits—a state permit and a federal permit. San Francisco objects to this characterization.¹⁰

As we explained in our order denying San Francisco’s motion to stay the Permit pending appeal, consolidation of the permitting process (including the consequent issuance of one consolidated permit document) does not alter the fact that there are two permit issuers, each with its own legal authority. Order Denying Motion to Stay at 9-11. The purpose of consolidation is to make the permitting process more efficient but, once the permitting process is complete and the consolidated permit is issued, the authorizations are distinct for the purposes of appeal,¹¹ stay, and enforcement as a matter of law. *See id.* (explaining that the Permit itself, whether consolidated or not, does not alter the individual legal authority of either permitting authority to stay or enforce the permit). In other words, the permit authorizations in this case involve one document derived from one consolidated permitting process resulting in dual authorizations by EPA and

¹⁰ This issue was fully briefed after the Board granted San Francisco’s motion to supplement its petition on this issue. *See* Supp. to Pet.; U.S. EPA Region 9 Response to San Francisco’s Supplement to Petition for Review (Jul. 23, 2020) (Docket No. 23); San Francisco’s Reply in Support of Supplement to Petition for Review (Sept. 11, 2020) (Docket No. 30).

¹¹ Just as the Region’s authorization must be appealed through the Board using the administrative process outlined in 40 C.F.R. § 124.19 before proceeding to the federal judicial process, the California RWQCB authorization must be challenged through the State’s administrative and judicial processes. *See* Fact Sheet at F-35; 40 C.F.R. § 123.30; Letter from Michael Montgomery, Exec. Officer, Cal. RWQCB, S.F. Bay Region, to Michael Carlin, S.F. Pub. Utils. Comm’n, 2-3 (Oct. 29, 2019) (A.R. 134) (citing Cal. Water Code §§ 13320, 13321, 13330). In fact, San Francisco is separately challenging the Oceanside CSS Permit in the California state court system. Pet. at 2, n.1 (referring to *City and Cty. of San Francisco v. RWQCB*, Case RG19042575 (Alameda Superior Court)).

the California RWQCB for the continued operation of the facility, regardless whether the authorizations are characterized as one permit or two.¹²

In addition, the outcome of the issues raised in this appeal would be no different whether the NPDES authorizations for the Oceanside CSS are characterized as one permit versus two. The Region does not rely on its consolidation of the permitting process for its authority to include a narrative prohibition against causing or contributing to a violation of any water quality standards, to require reporting on isolated sewer overflows, or to require San Francisco to update its long-term control plan. To the extent that San Francisco preferred that the permitting processes not be combined and that each permitting authority proceed with its own permitting process and issue its own separate permit, San Francisco could have recommended (and may recommend in the future) that the process not be consolidated. *See* 40 C.F.R. § 124.4(c)(3).¹³

In sum, San Francisco fails to establish that either the consolidated NPDES permitting process, resulting in two authorizations (one by the Region and the other by the California RWQCB), or the differing characterizations of the dual authorizations as either one or two permits constitutes clear error.

¹² We are not unsympathetic to the complexity of this permitting process, particularly given the Region's notice of stay of the contested permit conditions. As we described in our order denying San Francisco's motion to stay, both permitting authorities have referred to the permit in this matter in both singular and plural terms. *See* Order Denying Motion to Stay at 11 n.10. Adding to the confusion in this matter is the fact that the California RWQCB signed the authorization three months before the Region, resulting in different effective dates but identical expiration dates. As we stated before, the apparent confusion in this case suggests that it may behoove all involved if each permitting authority provides greater clarity for permittees in future permitting decisions. *Id.*

¹³ The rule allowing for consolidation of the permitting process, 40 C.F.R. § 124.4, also allows the permittee to recommend whether or not the processing of their applications should be consolidated, *id.* § 124.4(c)(3). San Francisco did not contest the consolidation of the permit process either for this permit term or in prior permit issuances. The rule also provides for the deconsolidation of the permits if joint processing will result in unreasonable delay in the issuance of one or more permits. *Id.* § 124.4(a)(2). Presumably, this would be appropriate in situations where one authority is prepared to issue a permit, but the other has not reached the same conclusion. Again, this issue arose only after the Region characterized the permits in this matter as two permits, after the authorizations were issued and the appeal was docketed.

B. *Narrative Prohibition Against Violating Water Quality Standards*

Section V of the Permit, entitled “Receiving Water Limitations,” prohibits discharges from “caus[ing] or contribut[ing] to a violation of any applicable water quality standard * * * for receiving waters.”¹⁴ Permit § V, at 9. San Francisco argues that the Region’s inclusion of that prohibition is based on “clearly erroneous conclusions of law and findings of fact and [the provision fails] to provide fair notice” of what is required to comply. Pet. at 12.¹⁵

As a preliminary matter, we note two things. First, San Francisco characterizes the contested provision in section V of the Permit as a water quality-based effluent limitation or “WQBEL.” Pet. at 12-23. The Region also uses the term “WQBEL” to describe the provision in its response brief. U.S. EPA Region 9 Response to San Francisco’s Petition for Review 15-26 (Feb. 28, 2020) (Docket No. 6) (“Resp. Br.”). Notwithstanding the parties’ characterization, we refer to the contested provision as a *prohibition* against exceeding (or violating) water quality standards of the receiving waters. We do so to distinguish this limitation from other facility-specific water quality based effluent limits set forth

¹⁴ The prohibition against violating any applicable water quality standard also incorporates the exception set forth in State Water Board No. WQ 79-16 granting San Francisco an exemption from the California ocean quality control plan (which prohibits discharges of wastewater to the Ocean that do not conform to its standards) to allow an average of eight wet weather overflows per year. Permit § V, at 9; *see* State Water Board Order No. WQ 79-16 at 18; Cal. State Water Resources Control Bd., *Water Quality Control Plan – Ocean Waters of California*, at 4, 13-33 (2019) (A.R. 101) (“Ocean Plan”).

¹⁵ Section G.I.I.1 of attachment G to the Permit provides that “[n]either the treatment nor the discharge of pollutants shall create pollution, contamination, or nuisance as defined by California Water Code section 13050.” Permit attach. G at G-2. This provision is part of California’s Regional Standard Provisions and Monitoring and Reporting Requirements that have been incorporated into nearly all California NPDES permits since 1993. Resp. to Cmts. at 13. For example, an identical provision was included in San Francisco’s 2009 permit. *See* 2009 Permit attach. G (supp. to attach. D) at 3. San Francisco challenges both the narrative prohibition at G.I.I.1 in attachment G in addition to the narrative prohibition in section V of the permit. Pet. at 12-23. San Francisco presents identical arguments with respect to both provisions, characterizing them as imposing “generic, boilerplate [water quality-based effluent limitations].” *E.g.*, Pet. at 12. The Board’s decision with respect to these provisions does not differ and, for ease of discussion, we will address the language in section V specifically. However, our disposition of this issue applies to both the language in Section V and the language in Attachment G.I.I.1.

elsewhere in the Permit that are not contested in this appeal. This distinction between the receiving water limitation and other end-of-pipe water quality based effluent limits is also consistent with the permit record. *See* Permit §§ IV.B, V, VI.C.5, at 8, 9, 15; Fact Sheet at F-17 to F-18, F-26.¹⁶

Second, the City of Lowell, Massachusetts, challenged a nearly identical NPDES permit provision in an appeal before the Board and raised arguments similar to those that San Francisco makes here. *See In re City of Lowell*, 18 E.A.D. 115, 175-88 (EAB 2020) (determining that region did not clearly err in including provision that stated facility’s discharge “shall not cause a violation of the water quality standards of the receiving water”). In *Lowell*, the Board upheld the provision after determining that the petitioner failed to demonstrate that the region lacked legal authority, that the prohibition was unnecessary, or that the prohibition infringed upon fair notice requirements.

¹⁶ San Francisco argues that the Region provided no meaningful distinction between a “receiving water limitation” and a water quality-based effluent limitation. Pet. at 10, 15-16. To the contrary, in its response to comments document, the Region described a receiving water limitation as “directly derived from the applicable water quality standards,” Resp. to Cmts. at 11, and a water quality-based effluent limitation as a “restriction * * * on quantities, rates, and concentrations of chemical, physical, biological and other constituents [that] are discharged from point sources,” *id.* (quoting CWA § 502(11), 33 U.S.C. § 1362(11)). The Region explained that “[c]ompliance with receiving water limitations is determined with respect to the discharger’s effect on the receiving water, whereas compliance with effluent limitations is based on the quality of the effluent.” *Id.* In other words, water quality-based effluent limits (or WQBELs) might be thought of as specific “end-of-pipe” limits on what is being discharged, whereas the narrative receiving water limitations might be thought of as a check on the effect that the discharge has on the quality of the receiving water. *See* U.S. EPA, Combined Sewer Overflows: Guidance for Long-Term Control Plan, at 1-22, 1-23 (1995) (A.R. 95b) (distinguishing end-of-pipe measures of success from receiving water measures of success); *see also* U.S. EPA, CSO Post Construction Compliance Monitoring Guidance, at 45 (May 2012) (A.R. 94) (distinguishing monitoring for achieving end-of-pipe-goals from quality of receiving water). In sum, the Region’s response to San Francisco’s comments on this issue was more than enough to meet the requirements of 40 C.F.R. § 124.17(a)(2). *See In re Circle T Feedlot, Inc.*, 14 E.A.D. 653, 674-76 (EAB 2010) (discussing the permitting authority’s obligation to respond to comments under 40 C.F.R. § 124.17(a)(2)).

1. *The Narrative Prohibition is Not Contrary to Law*

We address first the Region’s legal authority to impose a narrative prohibition against violating water quality standards (that is, a prohibition based on the effect that a discharge will have on receiving waters), in addition to the Permit’s specific water quality based effluent limits (that is, limits based on the end-of-pipe quality of the effluent). *See* Pet. at 13-16 (arguing that both the narrative “receiving water limitation” and the specific WQBELs are designed to protect water quality standards, but the receiving water limitations were not properly developed according to the standards to permit process set forth for WQBELs). For the reasons set forth below, in *Lowell*, and in the response to comments document for this Permit, San Francisco fails to demonstrate that the Region’s inclusion of a narrative prohibition against violating water quality standards in the Permit is based on a clearly erroneous conclusion of law. *See City of Lowell*, 18 E.A.D. at 175-80; Resp. to Cmts. at 11-14.

Clean Water Act section 402 requires permit issuers to include—in every NPDES permit—conditions that ensure that the discharge will meet the requirements of Clean Water Act section 301, *including* those necessary to meet water quality standards. *See City of Lowell*, 18 E.A.D. at 175; CWA §§ 402, 301(b)(1)(C), 33 U.S.C. §§ 1342, 1311(b)(1)(C); Resp. to Cmts. at 12. NPDES regulations implementing the CWA also require that permits include “any” limitation necessary to achieve water quality standards. 40 C.F.R. § 122.44(d); *see* Resp. to Cmts. at 12. Although 40 C.F.R. § 122.44(d) sets forth a process for deriving pollutant-specific effluent limits when the permitting authority determines that a particular pollutant has the reasonable potential to cause or contribute to an exceedance of water quality standards, the regulations do not require all permit conditions necessary to meet water quality standards to be expressed in terms of specific pollutant-by-pollutant limitations. *See* 40 C.F.R. § 122.44(d); Resp. to Cmts. at 12.

Additionally, CSOs must meet the requirements of the CWA, including compliance with water quality standards and the protection of designated uses. CSO Control Policy, 59 Fed. Reg. at 18,688-89; *id.* § IV.B, 59 Fed. Reg. at 18,695-96; Resp. to Cmts. at 12. The CSO Control Policy specifically recognizes that Phase I permits need to require compliance “expressed in the form of a narrative limitation.” CSO Control Policy § IV.B, 59 Fed. Reg. at 18,696; *see* Resp. to Cmts. at 12. Similarly, the guidance document for CSO permit writers provides that permit writers should include in Phase II permits narrative permit language providing for the attainment of applicable water quality standards, in addition to

facility-specific performance standards.¹⁷ CSO Guidance for Permit Writers at 4-27; *see* Resp. to Cmts. at 12.

Provisions generally prohibiting discharges from violating water quality standards are frequently included in NPDES permits in addition to more specific “end of pipe” effluent limits. *See, e.g., City of Lowell*, 18 E.A.D. at 176; *see also, e.g., Ohio Valley Envtl. Coal. v. Fola Coal Co.*, 845 F.3d 133, 136, 141-142 & n.5 (4th Cir. 2017) (recognizing that EPA often includes such provisions in NPDES permits). As the Region explained in its response to comments document, provisions prohibiting discharges that result in violations of water quality standards incorporate enforceable assurances that water quality standards will be met. Resp. to Cmts. at 11-12. In effect, they serve as “backstops” in the event that more specific limits or provisions prove inadequate. *See* Transcript of S.F. Bay Reg’l Water Quality Control Bd. Hearing at 14:16-20 (Sept. 11, 2019) (A.R. 14); Oral Arg. Tr. at 70, 71-72, 74. Such provisions also provide a mechanism for addressing “water quality violations that a permittee causes due to unanticipated circumstances or changes to effluent quality.” *City of Lowell*, 18 E.A.D. at 176.

As we stated in *Lowell*, federal courts have recognized the authority of permit issuers to include narrative prohibitions against violations of water quality standards that are similar to the one at issue here. *City of Lowell*, 18 E.A.D. at 176-77 (citing *Nw. Envtl. Advocates v. City of Portland*, 56 F.3d 979, 989-90 (9th Cir. 1995); *PUD No. 1 of Jefferson Cty. v. Wash. Dep’t of Ecology*, 511 U.S. 700, 716-18 (1994)); Resp. to Cmts. at 13; *see also Fola Coal*, 845 F.3d at 139-143 (determining that permit condition prohibiting permittee from causing violation of applicable water quality standards was enforceable permit term, recognizing EPA’s consistent use of such permit conditions, and noting acceptance by courts of EPA’s view when interpreting similar provisions); *Nat. Res. Def. Council, Inc. v. Cty. of Los Angeles*, 725 F.3d 1194, 1199, 1201, 1205 (9th Cir. 2013) (addressing enforcement of permit that included provision prohibiting “discharges from [the facility] that cause or contribute to the violation of the Water Quality Standards or water quality objectives”), *cert. denied*, 572 U.S. 1100 (2014)). In upholding the enforcement of a similar narrative provision, the U.S. Court of Appeals for the Ninth Circuit in *Northwest Environmental Advocates v. City of Portland* explained that “the Supreme Court recognized that the numerical criteria components of state

¹⁷ The CSO guidance document for permit writers provides that “[i]n addition to” performance standards designed to meet water quality standards, “the permit writer should include narrative permit language providing for the attainment of applicable [water quality standards].” CSO Guidance for Permit Writers at 4-27 (emphasis added).

water quality standards cannot reasonably be expected to address all the water quality issues arising from every activity which can affect the State's hundreds' of individual water bodies," and "requiring the States to enforce only the numerical criteria component of their water quality standards 'would in essence require the states to study to a level of great specificity each individual surface water to ensure that the criteria * * * fully protect the water's designated uses.'" 56 F.3d at 989-990 (quoting *PUD No. 1 of Jefferson County*, 511 U.S. at 717-18).

San Francisco contends, as did the petitioner in *Lowell*, that the cases on which the Region relies in support of its authority to include a narrative prohibition are enforcement cases and, as such, are inapposite. Pet. at 15. In *Lowell* we explained that, notwithstanding the enforcement posture of these cases, the conclusions regarding a permitting authority's basis for including narrative prohibitions against violating water quality standards are instructive and strongly support the proposition that permitting authorities are authorized to include such provisions. See *City of Lowell*, 18 E.A.D. at 177-178 (analyzing *Nw. Envtl. Advocates*, 56 F.3d at 989-90, and *Fola Coal*, 845 F.3d at 145-47). San Francisco also suggests that the authorities cited by the Region are a reference to narrative WQBELs like the ones set forth in this Permit at section VI.C.5.c,¹⁸ rather than the narrative prohibition expressed in section V. Pet. at 16. We disagree. The enforcement cases cited involved the application of permit language almost identical to the language at issue here. See *Nw. Envtl. Advocates*, 56 F.3d at 985 ("no wastes shall be discharged and no activities shall be conducted [that] will violate Water Quality Standards"); *Fola Coal*, 845 F.3d at 136 ("discharges * * * are to be of such quality so as not to cause violation of applicable water quality standards").

San Francisco also cites *American Paper Institute v. EPA* for the proposition that water quality standards are not a limit that can be violated because water quality standards themselves "have no effect on pollution," rather they are "used as the basis for specific effluent limitations in NPDES Permits." Pet. at 15 (quoting *Am.*

¹⁸ Section VI.C.5.c of the Permit contains narrative WQBELs applicable to wet weather discharges from CSO outfalls and the deepwater ocean outfall. Fact Sheet at F-25. As such, it satisfies the CSO Control Policy's requirement to implement San Francisco's LTCP by incorporating it into the Permit to satisfy water quality-based requirements during wet weather. See Fact Sheet at F-30. The narrative controls include requirements such as "optimize system operations to minimize combined sewer discharges and maximize pollutant removal during wet weather," "use all facilities * * * to store or treat wet weather flows to the maximum extent practicable." Permit § VI.C.5.c., at 20.

Paper Inst. v. EPA, 996 F.2d 346, 350 (D.C. Cir. 1993)). *American Paper*, however, involved a challenge to an EPA rule requiring permit writers to use one of three methods to interpret state water quality standards when establishing pollutant-specific effluent limitations in permits. 996 F.2d. at 348, 350 (upholding the rule codified at 40 C.F.R. § 122.44(d)(1)(vi)). *American Paper* is thus inapposite to whether, in addition to pollutant-specific water quality-based effluent limitations, a permit writer may *also* include a narrative prohibition against violating water quality standards. The same is true for *Natural Resources Defense Council Inc. v. EPA*, which San Francisco cites for the proposition that water quality standards are a critical component for setting applicable limitations in individual permits. Pet. at 15 (citing *Nat. Res. Def. Council, Inc. v. EPA*, 16 F.3d 1395, 1399 (4th Cir. 1993)). Again, that proposition does not speak to whether a permit writer may include a narrative prohibition against violating water quality standards in addition to specific water quality-based effluent limitations. See *Nat. Res. Def. Council*, 16 F.3d at 1400, 1405, 1406 (noting that states can establish narrative criteria to supplement numerical criteria and rejecting a challenge to EPA’s approval of specific state water quality standards). In sum, neither the CWA nor the caselaw supports San Francisco’s argument that a broad narrative prohibition against violating or exceeding water quality standards, in addition to more specific water quality-based effluent limitations, is based on a clearly erroneous conclusion of law.

San Francisco also contends that the narrative prohibition is illegal because the Region failed to follow the standards-to-permit framework set forth in the permit writers manual, which serves as guidance in implementing CWA requirements and regulations. Pet. at 13-15 (citing Office of Wastewater Mgmt., U.S. EPA, *NPDES Permit Writers’ Manual* at 6-1 to 6-2, 6-12 to 6-23 (2010) (“Permit Writers’ Manual”)); see also Pet. at 21 (arguing that a discharger cannot “violate” a water quality standard because that standard must first be “translated” into a permit limit). In its reply, San Francisco specifically points to the provisions for determining pollutant-specific effluent limits in 40 C.F.R. § 122.44(d)(1). Reply Br. at 4-5. The framework in the permit writer’s manual to which San Francisco refers is designed to determine specific water quality-based effluent limitations and not the type of general narrative prohibition that is at issue here. Additionally, as stated above and described by the Region in its response to comments document, although 40 C.F.R. § 122.44(d) provides a process for establishing pollutant-specific effluent limits, the regulations do not require that all permit conditions necessary to meet water quality standards be expressed in terms of specific pollutant-by-pollutant numeric limitations. See 40 C.F.R. § 122.44(d); Resp. to Cmts. at 12. Nor do the regulations prohibit the permitting authority from determining that a narrative prohibition against violating water quality standards in

the receiving waters is appropriate. *See Nw. Envtl. Advocates*, 56 F.3d at 986 (rejecting argument that “only those water quality standards that are translated into effluent limitations” may be enforced). As such, the regulations and guidance setting forth the standards-to-permit process are inapposite to the narrative prohibition at issue here.

In sum, San Francisco has not met its burden to demonstrate that the Region lacked legal authority to impose the prohibition against violating water quality standards in the receiving waters.

2. *The Region’s Factual Basis for the Provision*

San Francisco also argues that the Region’s inclusion of the prohibition against violating water quality standards in the Permit is based on clearly erroneous findings of fact. Pet. at 17-19. The Region explained that it included the prohibition as a backstop “to ensure compliance with applicable water quality standards in accordance with the CWA and [its implementing regulations].” Fact Sheet at F-26; *see also* Resp. to Cmts. at 11; Oral Arg. Tr. at 70, 71-72. In its comments on the draft permit, San Francisco asserted that compliance with applicable WQBELs in the Permit’s long-term control plan provision (section VI.C.5.c.) will result in attainment of applicable water quality standards and thus the narrative general prohibition is unnecessary. *See* Letter from Greg Norby, Assistant Gen. Manager, Wastewater Enter., to Jessica Watkins, Cal. RWQCB, S.F. Bay Region, attach. B at 3-5 (May 20, 2019) (attaching comments) (A.R. 9) (“San Francisco Comments”); Pet. at 18, 19-20. In its response to comments, based on the design of the Oceanside CSS and other factors related to historical assumptions, exceptions, and current conditions, the Region explained that the effluent limits in section VI.C.5.c. and elsewhere in the Permit may not “necessarily achieve water quality standards,” and therefore the narrative prohibition against violating water quality standards in the receiving water is “necessary to ensure compliance with applicable water quality standards.” Resp. to Cmts. at 11, 15; *see also generally* Resp. to Cmts. at 14-16.

Contrary to San Francisco’s argument that the Region provided no support for the determination that WQBELs in section VI.C.5.c. may not, alone, achieve water quality standards, Pet. at 17, the record in fact supports the Region’s conclusion. As discussed in the Fact Sheet, in 1972, the California State Water Resources Control Board adopted water quality standards for the Pacific Ocean to protect beneficial uses. *See* Fact Sheet at F-10 to F-11 (describing Cal. State Water Res. Control Bd., *Water Quality Control Plan – Ocean Waters of Cal., Cal. Ocean Plan* (1972, rev. 2019) (A.R. 101) (“Ocean Plan”)). The Ocean Plan is applicable to discharges both within and outside of the territorial waters of the state “to assure no violation of [the water quality standards in] the Ocean Plan will occur in ocean

waters.” Ocean Plan at 67. Notwithstanding the water quality standards set forth in the Ocean Plan, in 1979, the California State Water Quality Control Board (“State Water Board”) granted San Francisco a limited exception to the requirements of the Ocean Plan, by allowing San Francisco to discharge an average of eight overflows per year from its outfalls during wet weather. Fact Sheet at F-11 to F-12. The Oceanside CSS was thus *designed and constructed* not to contain all stormwater runoff (contrary to the goal of the CWA to eliminate all CSOs), but instead to allow CSOs, namely a long-term average of eight combined sewer discharges annually. *See* Fact Sheet at F-7.¹⁹

Notwithstanding the exception granted to San Francisco, the State Water Board Order also provided that San Francisco was to comply with the Ocean Plan “to the greatest extent practical,” and also provided that EPA or the California RWQCB “may require construction of additional facilities or modification of existing Facility operations if it finds (1) changes in the location, intensity, or importance of affected beneficial uses, or (2) demonstrated unacceptable adverse impacts result from Facility operations as currently constructed.” Fact Sheet at F-12; *see also* Cal. State Water Resources Control Bd., Order No. WQ 79-16: In the Matter of the Request for an Exception to the 1978 Water Quality Control Plan for Ocean Waters of California 19 (1979) (A.R. 102) (“State Water Board Order No. WQ 79-16”). Additionally, although the exception was presupposed to be contingent upon protecting beneficial uses of ocean waters, the State Water Board also acknowledged that “to some degree,” the exception itself would *require* an exception to the regulatory mechanisms meant to protect beneficial uses. State Water Board Order No. WQ 79-16 at 7-8. Thus, the design and construction of the Oceanside CSS and the exception contained in State Water Board Order WQ 79-16 provide support to the Region’s determination that the facilities’ discharges may not achieve water quality standards.

The aim of the CWA, by virtue of the CSO Control Policy, is to bring combined sewer discharges into compliance with the CWA, “including compliance with water quality standards *and* protection of designated uses.” CSO Control Policy, 59 Fed. Reg. at 18,688 (emphasis added). As the Region explained, the

¹⁹ *See also* 2009 Permit, attach. F (Fact Sheet) at F-5 (“[the facility was] designed to achieve a long term average of eight discrete CSOD events per year.”); 2003 Permit at 10 (“The system was designed and built based upon historical rainfall data to not exceed the overflow frequencies specified in Order No. 79-16.”); 1997 Permit at 4 (“The long-term average of 8 overflows per year was established as the Westside design goal by the Board after an evaluation of costs and benefits.”).

CSO Control Policy contemplates that water quality standards might not be attained and requires the permittee to submit a revised control plan in the event that they are not. *Id.*; *see also* CSO Control Policy §§ I.C., IV.B.2.g, 59 Fed. Reg. at 18,690, 18,696. The Permit “requires post-construction compliance monitoring to verify compliance with water quality standards and protection of designated uses as well as [to] ascertain the effectiveness of CSO controls.” Resp. to Cmts. at 15 (citing CSO Control Policy, 59 Fed. Reg. at 18,688, 18,694). In other words, the CSO Control Policy also supports the Region’s determination to address the possibility that specific WQBELs may not be sufficient to ensure that water quality standards would be met. *Id.*

In further support of the need to protect beneficial uses of the receiving waters, the Region noted that the combined sewer discharges occur at Ocean Beach, China Beach, and Baker Beach, each of which is a popular recreational area used by the community and tourists throughout the year. *Id.* at 19-20. Between 2011 and 2014, approximately 100 million gallons of combined wastewater and stormwater were discharged from the combined sewer discharge outfalls. *Id.* at 20 (citing S.F. Pub. Utils. Comm’n, *Characterization of Westside Wet Weather Discharges and the Efficacy of Combined Sewer Discharge Controls*, at 1-3 to 1-4 (Jul. 30, 2014) (A.R. 63) (“2014 Report on Efficacy of CSD Controls”)). From 2008 to 2014, recreational surveys after combined sewer discharges document that 20% of users were in contact with receiving water, and data from that timeframe show that pollutant concentrations in combined sewer discharges exceeded water quality objectives.²⁰ *Id.* (citing 2014 Report on Efficacy of CSD Controls at 3-14 tbl.3-3 & app. A). Additionally, discharges that occur in the early Fall or Spring have the potential to impact more users since “recreational use increases when days are longer and the duration of storm events is typically shorter, which contributes to good surf conditions.” Resp. Br. at 22 (citing S.F. Pub. Utils. Comm’n, *Southwest Ocean Outfall Regional Monitoring Program, Sixteen-Year Summary Report 1997-2012*, at ii (Apr. 2014) (A.R. 62) (“Sixteen Year Summary Report”)).

²⁰ San Francisco incorrectly asserts that the Region erred in stating that 20% of users were in contact with receiving water after combined sewer discharges. *See* Pet. at 27-28 (citing Resp. to Cmts. at 20). The report on which the Region relies states that 80% of users observed during or shortly after a combined sewer discharge were engaged in “non-water contact recreation.” 2014 Report on Efficacy of CSD Controls at 3-14 (cited in Resp. to Cmts. at 20). The report also illustrates that 15% of total recreational users observed were identified as “full contact” and 5% as “partial contact,” which amounts to 20% of recreational users in contact with the receiving water, during or after combined sewer discharges. *Id.* at 3-14 tbl.3-3; *see also* Resp. Br. at 22 n.12.

Monitoring data for one year (July 2012 – July 2013) showed that “56 of the 468 samples collected at the ten shoreline receiving water monitoring locations exceeded a single-sample maximum water quality objective for at least one bacteria indicator (i.e., *E. coli*, total coliform or *Enterococcus*).” Resp. to Cmts. at 20 (citing Sixteen Year Summary Report at 3-7, 3-13). Of the elevated samples, 70% were associated with a combined sewer discharge event and resulted in the posting of warning or no swimming signs at beaches for seventeen days. *Id.* Given these facts, it was not unreasonable for the Region to conclude it was appropriate to “assess ways to reduce the volume, frequency, and magnitude of the combined sewer discharges” to these sensitive recreational areas to better protect beneficial uses.²¹ *See id.*

San Francisco argues that prior findings established that San Francisco’s specific WQBELs were protective of water quality standards and that the Region failed to justify departing from those findings when the Region concluded that the prohibition against violating water quality standards in the receiving water was needed. Pet. at 18 (citing San Francisco’s comments, which include citation to State Water Board Order No. WQ 79-16 as well as “decades of contrary Regional Board, State Board and EPA findings”); *see also* San Francisco Comments, attach. B at 5 (citing State Water Board Order No. WQ 79-16); Resp. to Cmts. at 15 (citing State Water Board Order No. WQ 79-16). The Region disagrees that State Water Board Order No. WQ 79-16 contained a determination that beneficial uses would be protected. Resp. to Cmts. at 15-16.

Although the order provides that exceptions to the Ocean Plan can be made *only* if the State Water Board determines that the exception will not compromise protection of ocean waters for beneficial uses, as we stated above, the State Water Board also recognized that “[t]o some degree,” allowing wet weather bypasses requires an exception to the regulatory mechanisms in the Ocean Plan that are meant to protect beneficial uses. State Water Board Order No. WQ 79-16 at 8. Additionally, the wet weather exception, granted in the State Water Board Order,

²¹ San Francisco asserts, “[t]he Region did not respond or explain how the operation of the [CSS] consistent with San Francisco-specific water quality-based effluent limitations would fail to protect beneficial uses.” Pet. at 11. The Region’s response to comments document provides a more than adequate explanation for why a narrative prohibition against violating water quality standards is needed in addition to San Francisco-specific WQBELs in order to protect beneficial uses. *See Circle T Feedlot*, 14 E.A.D. at 674-76 (discussing the permitting authority’s obligation to respond to comments under 40 C.F.R. § 124.17(a)(2)).

allowed an average of eight overflows per year, based on then-current circumstances and then-current average rainfall records. *Id.* at 10-13, 18. The State Water Board Order also specifically provided that, notwithstanding the wet weather exception granted in the order, “if the Regional Board finds that changes in location, intensity or importance of affected beneficial uses or demonstrated unacceptable adverse impacts * * * have occurred, it may require [changes to the structure or operation of the facilities].” *Id.* at 19. Based on the language of the order we agree with the Region that State Water Board Order No. WQ 79-16 does not provide a determination that operation of the Oceanside CSS would be protective of beneficial uses in perpetuity. Nor does it render the Region’s inclusion of the prohibition against violating water quality standards in the Permit clearly erroneous.

San Francisco also points to a more than ten-year old determination in the 2009 Oceanside permitting record that the design of the system “would not compromise beneficial uses” in arguing that the Region has departed from prior findings that compliance with the LTCP would equate to compliance with water quality standards. Pet. at 18 (citing, among other things, 2009 Permit attach. F (Fact Sheet) at F-34). Determinations as to whether a permittee is in compliance with the terms of a permit, however, are not made in the context of issuing a permit. *See* Resp. to Cmts. at 15. Additionally, as discussed above and in Part V.D., below, the Region reviewed current data and determined that it was not appropriate to include a statement indicating that solely complying with the requirements of the LTCP would result in compliance with water quality standards (which include protecting beneficial uses). Resp. to Cmts. at 14-15; *see* Memo to File at 6-8. In any event, San Francisco does not explain how a determination that water quality standards were met in the past prevents the Region from being able to determine a future requirement is appropriate, particularly when the system is decades old and was modified from its original design with additional changes planned.²² We therefore

²² For example, the service life of the sewers exceeds 100 years (making the rate of failure more imminent), average rainfall totals have changed from when the exception to the Ocean Plan was implemented, the sewer system has undergone upgrades and operational changes over the years, and this Permit authorizes San Francisco to construct, own, and operate the Westside Recycled Water Project. *See* Fact Sheet at F-3; Memo to File at 6-8; *see also* Part V.D, below (discussing the need for an update to the long-term control plan, including modifications to the San Francisco CSS since built and future changes planned).

conclude that the 2009 determination on which San Francisco relies, or other prior determinations cited, does not render the Region's decision clearly erroneous.

San Francisco then invokes its post-construction monitoring as evidence that the applicable water quality standards under previous permits have been met (thus, the narrative prohibition is not needed) and argues that the Region failed to consider that information. Pet. at 19. As explained above, and in the response to comments document, the Region based its decision to include the narrative prohibition not on the monitoring data alone, but on its determination that solely complying with the end-of-pipe provisions in the LTCP may not necessarily result in compliance with the water quality standards, including beneficial uses. Resp. to Cmts. at 15. That latter determination was based on the fact that the CSO Control Policy contemplates that water quality standards may not be met by complying with the LTCP alone, the exception to the Ocean Plan that allows San Francisco to discharge from the outfalls for an annual average of up to eight times per year, as well as its consideration of the post-monitoring information in the administrative record supporting the Region's decision here. See Resp. to Cmts. at 14-16, 19-20 (citing 2014 Report on Efficacy of CSD Controls at 1-4, 3-14, & tbl.3-3, and the Sixteen Year Summary Report at 3-7, 3-13); Resp. Br. at 21-22 (citing Memo to File at 6-8; Sixteen Year Summary Report at ii, 3-13; Ocean Plan at 9 tbl.3; California Integrated Water Quality Systems Project, Monitoring data from 2012-2019 for CSOs from the CSD structures for the Oceanside Permit (A.R. 67b)); see also 40 C.F.R. § 124.18 (requiring Region to base its permitting decision on contents of administrative record). San Francisco has not established that the Region's consideration of post-monitoring data in determining whether beneficial uses were being met was clearly erroneous.

Finally, San Francisco argues that the prohibition at issue is not necessary because the standard reopener provision required to be included in NPDES permits addresses any uncertainty or future unknowns. Pet. at 20. In so arguing, San Francisco relies on the description of the reopener clause in the Permit Writer's Manual as allowing the permitting authority to reopen and modify the Permit based on adverse impacts on water quality or beneficial uses. *Id.* (citing Permit Writers Manual at 9-19). San Francisco does not, however, explain or support how the requirement to include a reopener clause in the Permit prohibits the Region from also including a narrative prohibition against violating water quality standards in a reissued permit as well. Reopening and modifying a permit based on adverse impacts on water quality or beneficial uses that occur during a permit's term (the reopener provision) is different and serves a different purpose than a permit term that itself prohibits violating water quality standards in the first instance.

Given the Region's responsibility to determine what conditions are appropriate to include in the Permit, its legal obligation to ensure that water quality standards are met, the legal authority to include a narrative prohibition against violating water quality standards, and its determination that the WQBELs elsewhere in the Permit may not necessarily meet that obligation, we cannot conclude that the Region's decision here was based on clear error of fact.

3. *Fair Notice*

San Francisco's final argument on the prohibition against violating water quality standards is that the provision is so "vague" and "unclear" that the Permit condition fails to provide "fair notice" to San Francisco of its legal obligations. Pet. at 20. In *Lowell*, we explained that, to evaluate a claim of unfair notice, the Board examines the contested permit provisions to determine if they are "confusing," ambiguous," or "unclear." 18 E.A.D. at 175, 182 (citing *In re Puna Geothermal Venture*, 9 E.A.D. 243, 262-63 (EAB 2000) (evaluating similarly-worded prohibition against discharges that will "cause a violation of the water quality standards of the receiving water"))).

As in *Lowell*, nothing in the language of the narrative prohibition against violating water quality standards in the Permit is itself unclear. *See id.* at 182. Nor is it unclear which water quality standards apply under the permit. *See id.* To the extent that San Francisco is suggesting that the language in any particular water quality standard is vague or insufficiently clear, San Francisco has not identified any such water quality standard.

In addition, the San Francisco-specific limits in section VI.C.5.c of the Permit contain narrative language such as "to minimize combined sewer discharges and maximize pollutant removal" and "to the maximum extent practicable." Permit § VI.C.5.c, at 20. San Francisco's argument that the narrative prohibition fails to provide fair notice is belied by San Francisco's argument that the latter permit limits (in section VI.C.5.c) are sufficiently protective of water quality standards so as to render the narrative prohibition unnecessary. *See* Part V.B.1, above; Pet. at 19-20, 22 (citing Permit at 8, 18-20; Fact Sheet at F-25). If San Francisco maintains that the narrative limits in section VI.C.5.c. are sufficiently protective of water quality standards, *see* Pet. at 19-20, then San Francisco must also have sufficient notice of how to comply with them. *Accord City of Lowell*, 18 E.A.D. at 183-84. If those narrative limits are sufficiently clear and not vague, the same is true for the narrative prohibition that San Francisco challenges.

C. The Requirement to Report Isolated Sewer Overflows

San Francisco's next challenge to the Permit involves the requirement to report on sewer overflows from the combined sewer system. Pet. at 31-44 (challenging Permit section VI.C.5.a.ii(b)). Combined sewer systems anticipate significant stormwater events and are designed to overflow directly from CSO outfalls to surface water bodies such as the Pacific Ocean. See Fact Sheet at F-3 to F-4. In addition to the anticipated CSO events from outfalls, as described in Part III.B., above, when the storage capacity of the entire system is exceeded, isolated sewer overflows ("ISOs") can occur from various points of exit other than the permitted CSO outfalls (backups into basements or onto streets through manholes, for example). CSO Guidance for Permit Writers at 4-6; NMC Guidance at 3-3. As also discussed in Part III.B, above, overflows of wastewater can be a major source of water pollution that the CSO Control Policy is designed to address. The reporting provision at issue in this petition requires San Francisco to notify and report on all sewer overflows from the combined sewer system (including those from CSO outfalls and from isolated sewer overflows). Permit § VI.C.5.a.ii(b), at 17; Fact Sheet at F-30.²³

San Francisco contests this reporting requirement only as it applies to isolated sewer overflows and not as it applies to sewer overflows from outfalls. Pet. at 31. San Francisco essentially makes two arguments as to why it was clearly erroneous for the Region to include that reporting requirement: (1) that the Region cannot *regulate* ISOs that do not reach waters of the United States (because the Region has no Clean Water Act authority over such overflows), *id.* at 32-35, 38-44; and (2) that the Region cannot require reporting of ISOs where that reporting is premised on the need to determine whether there are capacity issues because the capacity of the system is not within the purview of EPA, *id.* at 35-38. Both of San Francisco's arguments misapprehend the function of the Permit condition at issue

²³ Section VI.C.5.a.ii(b) also sets forth various time frames within which overflows must be reported, based on the volume of the overflow. Permit at 17. For example, for sewer overflows with volumes of 1000 gallons or greater, San Francisco must submit draft reports within three business days of becoming aware of the overflow. *Id.* Additionally, for sewer overflows with volumes of 50,000 gallons or greater that reach surface waters, San Francisco must submit a technical report that explains the causes and circumstances, including the method and data used to calculate the volume, and the response actions completed and planned. *Id.*

and fail to carry San Francisco's burden to show that the Region's inclusion of the reporting requirements constituted clear error.

As to San Francisco's first argument, it is undisputed that the Region's authority to regulate here is derived from San Francisco's discharge through an outfall into the Pacific Ocean three miles offshore. *See* Part III.A, above. As an NPDES permitting authority, the Region must include permit terms that meet the requirements of the CWA, as well as the monitoring and reporting necessary to ensure compliance. The requirement to report on ISOs is not to "regulate" ISOs. Rather, the reporting requirements notify the permitting authorities of such occurrences because sewer overflows serve as an indicator of whether the CSO controls are working and the permitted system is operating as it should. *Resp. Br.* at 34; *Resp. to Cmts.* at 22-23. Even San Francisco acknowledges the usefulness of this reporting requirement, having stated during the permitting process that the frequency, cause, and location of sewer overflows from the combined sewer system may serve as "a metric to evaluate the effectiveness of operation and maintenance of the collection system to the extent that they are indicative of blockages that may reduce storage capacity." *See Resp. to Cmts. attach. 1* at 5, 11; *see also Pet.* at 39 n.7 (citing San Francisco Comments *attach. C*, at 1) (stating that San Francisco was "prepared to * * * develop a workable framework for the monitoring and reporting of [sewer overflows from the combined sewer system]"); *see also Resp. to Cmts.* at 22.

The Region's authority to require such reporting derives, in part, from the CSO Control Policy, which, as noted previously, was incorporated into CWA section 402(q). 33 U.S.C. § 1342(q). As described above, the CSO Control Policy establishes "Nine Minimum Controls" as the minimum technology-based requirements to be imposed on combined sewer systems. *See* CSO Control Policy § II.B, 59 Fed. Reg. at 18,691; 40 C.F.R. § 125.3; Fact Sheet at F-29. Among other things, those minimum controls require "[p]roper operation and regular maintenance programs" for the sewer system and "[m]aximization of flow to the [plant] for treatment." CSO Control Policy § II.B, 59 Fed. Reg. at 18,691. One of the Nine Minimum Controls requires dischargers to "[m]aximize use of the collection system for storage." *Id.* This latter requirement refers to "making relatively simple modifications to the [combined sewer system] to enable the system itself to store wet weather flows until downstream sewers and treatment facilities can handle them." NMC Guidance at 3-1.

The Region included the requirement to maximize storage in San Francisco's Permit at section VI.C.5.a.ii. Permit at 16-17; *see* Fact Sheet at F-29;

Resp. to Cmts. at 22-23 (citing the NMC Guidance).²⁴ EPA guidance on implementing that requirement provides that “[t]he first step in maximizing storage in a system is to identify possible locations where minor modifications can be made to the CSS to increase in-system storage.” NMC Guidance at 3-1. The guidance further provides that “more complex modifications [to the combined sewer system] (e.g., those requiring extensive construction)” are meant to be evaluated as part of the system’s long-term control plan. *Id.* The guidance recognizes that the “[r]isk of upstream (street, basement) flooding goes up with increased use of the collection system for [wet weather] storage,” and warns that modifications to maximize storage should be analyzed to ensure that the modifications will not cause other problems, such as street or basement flooding. *Id.* at 3-1, 3-3; *see also* CSO Guidance for Permit Writers at 4-6. Any modifications undertaken are to be documented for the permitting authority. NMC Guidance at 3-1.

The guidance document also provides that municipalities should record, summarize, and report information on incidents relating to the impacts of the combined sewer overflow system, including street and basement flooding. *Id.* at 10-4; *see also id.* at 10-2 to 10-4 (describing monitoring requirements to characterize CSO impacts and the efficacy of CSO controls, including overflow occurrences). The expectation is that the reporting will provide useful information on the general performance of the combined sewer system and the effect of control measures implemented, as well as assist in characterizing the nature and relative severity of receiving water impacts from combined sewer overflows. *Id.* at 10-4; *see also generally id.* at 10-2, 10-5 (stating that the data is expected to “provide a perspective on existing conditions and a basis for identifying progress that has been achieved”). Importantly, monitoring and reporting existing conditions allow the permitting authority to assess the performance of the minimum control measures, as the permitting authority is required to do. *See id.* at 10-5.

The Region’s authority for the reporting requirement is also rooted in the general permitting regulations implementing the permitting provisions of the CWA. For example, permittees are required to, at all times, operate and maintain facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of the permit. *See* 40 C.F.R. § 122.41(e). CWA sections 308 and 402 and their

²⁴ While the NMC Guidance by itself does not mandate the reporting requirements, it does provide guidance to the Agency for implementing the CSO Control Policy according to the CWA, which authorizes the reporting requirements. NMC Guidance at 1-4, 1-6; CWA §§ 308, 402, 33 U.S.C. §§ 1318, 1342.

implementing regulations authorize the permitting authority to collect information deemed necessary to ensure compliance with all applicable requirements of the CWA, including the CSO Control Policy. 33 U.S.C. §§ 1318, 1342; 40 C.F.R. § 122.43(a); *see also* Resp. to Cmts. at 27 (citing the reporting requirement as necessary to detect violations of CWA section 301 and to evaluate compliance with the nine minimum controls). Permitting authorities rely on permittees to furnish “any information” that the permitting authority may request “to determine compliance with the permit.” 40 C.F.R. § 122.41(h).²⁵

In issuing the draft permit, the Region explained that reporting on releases of untreated or partially treated wastewater is necessary, among other reasons, “to evaluate combined sewer system performance, and operations and maintenance practices,” and “to determine whether any diversions of untreated or partially treated wastewater result in a discharge to surface waters.” Fact Sheet at F-30. The Region also explained that the requirement implements public notification requirements of the CSO Control Policy and is necessary to determine possible impacts to public health. *Id.* at F-29 to F-30; *see also* Resp. to Cmts. attach. 1 at 12; CSO Control Policy § I.A, 59 Fed. Reg. at 18,689 (stating that among the objectives of the CSO Control Policy is the goal of “minimiz[ing] water quality, aquatic biota, and human health impacts”); *Id.* § II.B, 59 Fed. Reg. at 18,691 (identifying “[p]ublic notification to ensure that the public receives adequate notification of CSO occurrences and CSO impacts” as one of the Nine Minimum Controls).²⁶

²⁵ In its reply brief, San Francisco maintains that the Region identified only two bases for its authority to require reporting of isolated overflows—40 C.F.R. § 122.41(h) and the CSO Control Policy. Reply Br. at 15. From there, San Francisco argues that other bases for the Region’s authority (i.e., CWA §§ 308, 402) were “*post hoc*” and therefore the Region cannot rely on those provisions. *Id.* (asserting, without citation or legal support, that reliance on these statutory provisions was impermissible, presumably based on the *post hoc* rationalization doctrine). The Region’s reliance on those CWA provisions in its response brief was not impermissible inasmuch as the Permit was issued pursuant to CWA § 402, the CSO Control Policy was incorporated into CWA § 402(q), and 40 C.F.R. § 22.41 sets forth conditions applicable to all NPDES permits issued under the CWA, including the sections on which the Region relies. In any case, San Francisco has not been deprived of an opportunity to confront the Region’s rationale.

²⁶ The Permit also provides that the collection, treatment, storage, and disposal systems shall be operated in a manner that precludes public contact with wastewater. *See* Permit attach. G § G.I.I.2, at G-3.

In response to San Francisco’s arguments, the Region explained that complete reporting on sewer overflows—i.e., “whenever sewage or sewage mixed with stormwater exits the system, whether in streets, business[es], residences, or discharges to surface waters”—provides important information about the proper operation and maintenance of the CSS. Resp. Br. at 34 (citing Permit at 17). The Region explained in its response to comments document that monitoring and reporting sewer overflows from the combined sewer system provide the Region with a means to evaluate implementation of the Nine Minimum Controls and determine “whether San Francisco’s operations and maintenance activities are adequate,” “whether measures to maximize storage within the collection system are functioning properly,” “whether flows to the treatment works have been maximized without causing sewer backups,” “whether dry weather overflows are being controlled,” “whether actions to minimize floatables are not causing backups,” and “whether pollution prevention activities * * * are effective.” Resp. to Cmts. at 23 (citing NMC Guidance). As the Region explained, “understanding the causes of overflows is vital to determining whether and what corrective actions might be appropriate.” *Id.* at 22.²⁷ In other words, monitoring and reporting ISOs provide the Region with a means to evaluate and ensure permit compliance, which the Region is required to do under the CWA. *Id.*; *see also* CWA §§ 308, 402(a)(2), 33 U.S.C. §§ 1318, 1342(a)(2) (mandating permit issuer to require reporting necessary to establish compliance with CWA and applicable regulations); 40 C.F.R. § 122.43(a).

²⁷ San Francisco also argues that reporting on isolated sewer overflows that occur as a result of wet weather events is not appropriate because the system anticipates and is designed for such events and, thus, overflows due to wet weather events would not demonstrate improper operation or maintenance. Pet. at 35-36 (citing San Francisco Comments attach. C, at 1); *see also* Resp. to Cmts. at 24; Reply Br. at 15, 19-20. San Francisco also argues that 44 C.F.R. § 122.41(e), which requires permittees to properly operate and maintain the permitted facility, is inapplicable to overflows caused by extreme storm events where the system operates as designed. Reply Br. at 19. These arguments ignore the purpose of the CSO Control Policy, which as we have stated is to ensure that controls are implemented at combined sewer systems to ensure that overflows that occur as a result of wet weather events meet the objectives and requirements of the CWA. 59 Fed. Reg. at 18,688. The arguments are also inconsistent with San Francisco’s acknowledgment that overflows can be indicative of blockages that reduce storage capacity and can be a useful metric to evaluate the effectiveness and operation of the collection system. *See* Pet. at 39 n.7 (citing San Francisco’s Comments attach. C, at 1); *see also* Resp. to Cmts. at 22.

San Francisco's second argument—that the Region cannot base its reporting requirement on system capacity issues, because capacity is beyond the purview of the Region—again misapprehends the reporting requirement. *See* Reply Br. at 19 (arguing that “[e]valuation of system’s design capacity *is not* a component of ‘ensuring adequate operation and maintenance’ of a combined system” (citing Resp. Br. at 34); Pet. at 37 (arguing that, if Region “does not have authority to order a change in the design capacity of the system, it does not have a basis to require reporting of [ISOs] resulting from design capacity exceedances”). The Region is not requiring reporting of ISOs to assert authority over the capacity of the overall system. Rather, the Region is requiring reporting to determine the effect of the controls implemented and to confirm proper maintenance and operation of the system. The location, frequency, significance, and circumstances of sewer overflows may reflect an exceedance of the capacity of the system to contain sewage and stormwater, and that capacity issue may be due to conditions that are within the purview of the permitting authority, indicating that changes to permitted activities are necessary. For example, as discussed, the Permit (as contemplated by the CSO Policy and the Nine Minimum Controls) requires San Francisco to maximize the use of its system for storage capacity. But if in the course of “maximizing the storage capacity of the system,” San Francisco were to implement modifications that result in sewer overflows into basements or onto streets, that would be an indicator to which the Region should be alerted. NMC Guidance at 3-1, 3-3, 10-4. This is not so that the Region can require design changes or increased capacity, but so that the Region can evaluate the system’s operation pursuant to its permit, as is appropriate. *See* Resp. Br. at 34.

If the Region were to exclude either some or all ISOs from reporting requirements, the risk of under-reporting CSO capacity problems would increase, and the need for rehabilitation of the sewer system would be masked. *See* Resp. to Cmts. at 23. Additionally, the Region explained that “without such monitoring and reporting, determining whether a particular sewer overflow from the combined sewer system arises solely from capacity constraints would be difficult, if not impossible, particularly when dealing with a collection system as old and complex as San Francisco’s collection system.” *Id.* at 22. The Region further explained that the monitoring and reporting of storm events provides the permitting authority with information on the frequency and severity of such events, which is essential to evaluating the accuracy of models used to predict the frequency and severity of future events. *See id.* at 24. For example, as the Region explained, “[f]requent sewer overflows from the combined sewer system of sufficient volume to backup into homes and businesses may be evidence that capacity improvements are needed,” which could lead to the need for a revised long-term control plan or

changes in the steps taken to maximize the use of the combined sewer system for storage capacity.²⁸ *Id.*

Based on the record before us, the Region’s conclusion that the frequency, cause, and location of isolated sewer overflows can be indicative of whether the permitted combined sewer system is operating appropriately is not clearly erroneous. Even more, the frequency, cause, and location of ISOs can be indicative of whether storage is being maximized without causing inappropriate upstream impacts. The requirement to report isolated sewer overflows is not an attempt by the Region to “regulate” those overflows, nor is it an attempt to assert authority over waters not otherwise covered by the Clean Water Act. Rather, the requirement to report isolated overflows is an appropriate mechanism, grounded in the CSO Policy and the Clean Water Act more generally, to determine whether the permitted combined sewer system is operating in compliance with the permit, including the requirement to maximize storage without increasing upstream flooding into basements and streets, which can negatively impact human health and the environment. San Francisco fails to demonstrate that the Region clearly erred in requiring San Francisco to report isolated sewer overflows. Accordingly, the Board denies review on this issue.

D. The Requirement to Update the Long-Term Control Plan

San Francisco’s final challenge relates again to the CSO Control Policy that is incorporated into the CWA at section 402(q), 33 U.S.C. § 1342. The CSO Control Policy requires municipalities operating combined sewer systems to develop and implement a “Long-Term Control Plan” as part of the NPDES permitting process. CSO Control Policy § II.C, 59 Fed. Reg. at 18,691. When the CSO Control Policy was issued in 1994, San Francisco was already well into constructing its facilities. *Resp. to Cmts.* at 17. As such, the permitting authorities determined that San Francisco’s “program qualifies for the CSO Control Policy’s classification under Section I.C. as being substantially complete” and was “exempt” from the “planning and construction requirements” pursuant to section I.C of the Policy. 1997 Permit at 6 (Finding No. 11). Although San Francisco’s existing plan

²⁸ Notwithstanding the Region’s articulation of both its authority and need to require reporting of ISOs, San Francisco asserts that the Region failed to adequately respond to its comments on the issue. *Pet.* at 11. We disagree; the record reflects that the Region adequately responded. *See Resp. to Cmts.* at 22-24, 27; *Circle T Feedlot*, 14 E.A.D. at 674-76 (discussing the permitting authority’s obligation to respond to comments under 40 C.F.R. § 124.17(a)(2)).

was deemed to satisfy the requirements of the CSO Control Policy in subsequent permits, in this Permit, San Francisco is required to update its “Long-Term Control Plan” or “LTCP” by implementing specified tasks based on the CSO Control Policy. *See* Permit § VI.C.5.d, at 21-23 tbl.7.

To comply with the provision, San Francisco must complete a specific list of tasks that is based on the CSO Control Policy and then report to the California RWQCB and the Region as specified. *Id.* The tasks include: (1) submitting a “System Characterization Report” that includes “a comprehensive characterization of the combined sewer system developed through records review, monitoring, modeling, and other means as appropriate”; (2) involving the affected public in the decision-making process; (3) submitting a “Consideration of Sensitive Areas Report” that “evaluates, prioritizes, and proposes control alternatives needed to eliminate, relocate, or reduce the magnitude of or frequency of discharges to sensitive areas”;²⁹ (4) submitting a “Wet Weather Operations Report” that “proposes a set of operational parameters to be used as performance measures to ensure that wet weather operations maximize pollutant removal and minimize the frequency, volume, and duration of combined sewer discharges and sewer overflows from the combined sewer system”; and (5) developing a “Post-Construction Compliance Monitoring Program” that proposes modifications, as appropriate, to the monitoring plan for the next permit term. *Id.* Each task is then further defined and articulated in the Permit. *See id.* Notably, the tasks are focused on obtaining and providing accurate information to the permitting authorities, as well as to San Francisco itself, on the current system and operation; they are not construction or redesign requirements.

San Francisco objects to the LTCP provision (and the tasks that it requires), arguing that the requirements are “contrary to law,” and “not supported by relevant factual findings.” Pet. at 23. San Francisco also argues that the requirement to update its LTCP does not provide it with fair notice of what is necessary to comply with the provision. *Id.* at 30-31. We address each of these arguments, in turn, below.

1. *The Long-Term Control Plan Provision Is Not Contrary to Law*

San Francisco argues that the requirement to update the LTCP plan is contrary to law because the Region (and the California RWQCB) determined in the

²⁹ San Francisco discharges to sensitive areas at six out of its seven discharge points. Permit § VI.C.5.d, at 22 tbl.7.

1997 permit that San Francisco was not covered by the initial planning and construction requirements of the CSO Control Policy based on the status of the San Francisco's facility at the time the Policy was issued. *See* 1997 Permit at 6, 8 (Finding Nos. 11 & 15) (relying on CSO Control Policy § I.C.1, 59 Fed. Reg. at 18,690). As a result, San Francisco argues, many of the elements of developing an LTCP required by the CSO Control Policy do not apply to San Francisco's CSS as a matter of law. Pet. at 24.

The Region acknowledges that based on certain provisions in the CSO Control Policy, it previously allowed San Francisco to avoid the initial planning and construction requirements applicable to other CSOs based on the status of San Francisco's system at the time. Resp. Br. at 26; *see* Resp. to Cmts. at 17. The Region disagrees, however, that its determination in 1997 applies to San Francisco's CSS in perpetuity and prevents a permitting authority from requiring an update to a previously completed LTCP. Resp. to Cmts. at 17; *see also* Resp. Br. at 26. According to the Region, an update to the LTCP is necessary to meet San Francisco's obligations under the CWA, including the CSO Control Policy.³⁰ Resp. to Cmts. at 16-17 (citing the CWA, including the CSO Control Policy, as well as 40 C.F.R. § 122.44(d); State Water Board Order No. WQ 79-16; and Office of Water, U.S. EPA, *Combined Sewer Overflows: Guidance for Long-Term Control Plan* (Sept. 1995) (A.R. 95b) ("LTCP Guidance")).

As discussed above, CSOs often cause exceedances of water quality standards during wet weather events.³¹ *See* CSO Control Policy § I.A, 59 Fed. Reg.

³⁰ We find no merit to San Francisco's assertion that the Region failed to explain its departure from its prior determinations that San Francisco was excepted from certain requirements under section I.C. of the permit. *See* Pet. at 10-11; Resp. to Cmts. at 16-17. The Region's rationale for requiring an LTCP update, notwithstanding its prior determination, satisfied the Region's obligation under 40 C.F.R. § 124.17(a)(2) to "[b]riefly describe and respond to all significant comments." *See Circle T Feedlot*, 14 E.A.D. at 674-76.

³¹ As described in Part III.B, above, "CSOs consist of mixtures of domestic sewage, industrial and commercial wastewaters, and storm water runoff. CSOs often contain high levels of suspended solids, pathogenic microorganisms, toxic pollutants, floatables, nutrients, oxygen-demanding organic compounds, oil and grease, and other pollutants." CSO Control Policy § I.A, 59 Fed. Reg. at 18,689. As such, they not only cause exceedances of water quality standards, but they also "may pose risks to human health, threaten aquatic life and its habitat, and impair the use and enjoyment of the Nation's waterways." *Id.*

at 18,689. Recognizing this, and the water quality problems that ensue, EPA developed—and Congress later incorporated into law—the CSO Control Policy to bring combined sewer systems into compliance with the CWA. *Id.* at 18,688-89; CWA § 402(q), 33 U.S.C. 1342(q); *see also* Part III.B, above. As such the CWA, via the CSO Policy, requires permitting authorities to include in every NPDES permit all appropriate requirements in section IV.B of the policy, including the requirement to develop and implement an LTCP to ensure that CSSs that overflow as a result of wet weather events include controls that meet the objectives and requirements of the CWA. *See* CWA §§ 402(a), (q), 33 U.S.C. § 1342(a), (q) (establishing the NPDES permit program and requiring that no permit be issued unless the discharge will meet the requirements of the Clean Water Act, including water quality standards and the requirements of CSO Control Policy); CSO Control Policy §§ I.C, II.C, IV.A-B, 59 Fed. Reg. at 18,690, 18,691, 18,695-96; *see also* CWA § 301, 33 U.S.C. § 1311 (prohibiting the discharge of pollutants except in compliance with the CWA); CWA § 303, 33 U.S.C. § 1313 (establishing water quality standards and implementation plans).

As described in Part III.B, above, the CSO Control Policy sets out a phased approach for implementing the LTCP requirement. CSO Control Policy § IV, 59 Fed. Reg. at 18,695-96. Under this approach, a “Phase I” permit will require that the permittee “develop and submit” an LTCP and a “Phase II” permit will “insure that the selected CSO controls are implemented, operated and maintained as described in the long-term CSO control plan.” *Id.* § IV.B.1, .2, 59 Fed. Reg. at 18,696; *see also Lowell*, 18 EAD at 169. That said, when it issued the CSO Control Policy in 1994, EPA recognized that “extensive work [had already] been done by many Regions, States, and municipalities to abate CSOs.” CSO Control Policy § I.C, 59 Fed. Reg. at 18,690. As such, the Agency recognized that portions of the Policy may not apply, “as determined by the permitting authority on a case-by-case basis” under specified circumstances.³² *Id.* But even then, the CSO

³² In its brief and at oral argument, San Francisco asserted that it was exempt from certain requirements of the CSO Control Policy pursuant to section I.C.2, rather than I.C.1. Pet. at 24; Oral Arg. Tr. at 14. The first exception applies to permittees that had “completed or substantially completed construction of CSO control facilities” on the date the CSO Control Policy was published. CSO Control Policy § I.C.1, at 18,690. The second exception applies to permittees that had “substantially developed or [were] implementing a CSO control program” on the date the CSO Control Policy was published. CSO Control Policy § I.C.2, at 18,690. According to the 1997 Permit, San Francisco was excepted from “initial planning and construction” provisions pursuant to section I.C.1 of the CSO Control Policy. 1997 Permit at 6; *see also* 2003 Permit at 17. The exception would not change

Control Policy specifies that “[i]n the case of any ongoing or substantially completed CSO control effort, the NPDES permit or other enforceable mechanism, as appropriate, should be revised to include all appropriate permit requirements consistent with Section IV.B of [the CSO Control Policy].” *Id.* The CSO Control Policy also indicates that its phased approach should not be construed to mean that each function occurs separately, “[r]ather, the entire process * * * must be coordinated to control CSOs effectively.” *Id.* § I.F, at 18,690.

As the Region explained in its response to San Francisco’s comments on the draft permit, the CSO Control Policy also anticipates changed circumstances and the need to re-evaluate CSO control programs. Resp. to Cmts. at 16-17; Resp. Br. at 26-28. For example, the CSO Control Policy provides that, where monitoring demonstrates water quality standards are not being met, permittees “should be required to submit a revised CSO control plan that, once implemented, will attain [water quality standards].” CSO Control Policy § I.C.1, 59 Fed. Reg. at 18,690. The Policy also states that programs that are excused from planning requirements under section I.C.2, “should be reviewed and modified to be consistent with the sensitive area, financial capability, and post-construction monitoring provisions” of the CSO Control Policy. *Id.* § I.C.2, 59 Fed. Reg. at 18,690. With respect to sensitive areas where elimination or relocation of CSOs is determined to be economically or physically impossible, the Policy provides that permitting authorities “should require for each subsequent permit term a reassessment” of discharges to sensitive areas “based on new or improved techniques” or “changed circumstances that influence economic achievability.” *Id.* § II.C.3.c, 59 Fed. Reg. at 18,692. Additionally, permits issued for CSOs should include permit reopener clauses that allow for permitting authorities to reopen and modify a permit if CSO controls fail to meet water quality standards or to protect designated uses. *Id.* § IV.B.2(g), at 18,696. Nothing in the CSO Policy suggests that long-term control plans (whether developed before the CSO Control Policy was issued or developed consistent with the provisions of the CSO Control Policy) were meant to forever remain static after a facility was beyond “Phase II.” The Agency guidance designed for use by permitting authorities in developing LTCPs also contemplates re-evaluation and updates of LTCPs after Phase II. LTCP Guidance at 4-16 (explaining in a section entitled “Re-Evaluation and Update” that post-construction

based on further progress by a permittee because the exception is based on the date of publication of the CSO Control Policy. Notwithstanding San Francisco’s position with respect to which exception applies, the basis for the exception makes no difference to the outcome of this issue on appeal.

monitoring is intended to verify compliance with water quality standards and protection of designated uses as well as to ascertain the effectiveness of the CSO controls; adding that, if the implemented controls do not achieve these results, a municipality should evaluate the current system's operating practices, strategies, and control measures as necessary).

San Francisco acknowledges its obligation under the CSO Control Policy to “focus on” sensitive areas and to perform post-construction compliance monitoring according to its plan. Reply Br. at 11-12. But San Francisco argues that the permitting authority is required to demonstrate that water quality standards are not being met, or that beneficial uses are not being protected, before the permitting authority can require an LTCP update. Pet. at 29 (citing CSO Control Policy § II.C.3, 59 Fed. Reg. at 18,692). Contrary to San Francisco's argument, the CSO Control Policy and LTCPs are not singularly focused on achieving water quality standards; the CSO Control Policy makes clear that its objective is compliance with the CWA generally and not compliance with water quality standards *exclusively*. See, e.g., CSO Control Policy, 59 Fed. Reg. at 18,688 (explaining that major provisions of CSO Control Policy include “compliance with the CWA, *including* compliance with water quality standards and protection of designated uses” (emphasis added)). Additionally, in the provision requiring LTCPs to include the re-assessment of discharges to sensitive areas, the CSO Control Policy does not require a demonstration of water quality exceedances. See CSO Control Policy § II.C.3.c, 59 Fed. Reg. at 18,692 (providing that “[w]here elimination or relocation [of overflows] has been proven not to be physically possible and economically achievable, permitting authorities should require for each subsequent permit term, a reassessment based on new or improved techniques to eliminate or relocate or on changed circumstances that influence economic achievability”). In other words, the Permit's requirement to “propose[] control alternatives needed to eliminate, relocate, or reduce the magnitude or frequency of [overflow] discharges to sensitive areas” is consistent with the CSO Control Policy, irrespective of whether water quality standards or beneficial uses are being met. See *id.*; Permit § VI.C.5.d tbl.7 (No. 3) at 22. Thus, San Francisco's argument that CSO Control Policy section II.C.3 requires a demonstration of water quality exceedances is mistaken.

San Francisco cites to nothing in the CWA, its regulations, or the policies implementing those requirements that prohibits permitting authorities from requiring a municipality to update its long-term control plan post-Phase II. See Pet. at 23-26. Nor does San Francisco cite to anything that supports the notion that a determination that a permittee is excused from having to conduct initial planning or construction requirements under the CSO Control Policy remains in perpetuity.

See id. Rather, the CSO Control Policy states that “Agency decisions in any particular case will be made by applying the law and regulations on the basis of specific facts when permits are issued.” CSO Control Policy § I.A, 59 Fed. Reg. at 18,689.

Also, as discussed above, the CSO Control Policy anticipates that the satisfaction of certain requirements may be revisited, including that a facility may need to update its long-term control plan due to changed circumstances. *Id.* §§ II.C, II.C.3, IV.B, 59 Fed. Reg. at 18,690, 18,692, and 18,695-96. Additionally, while a demonstration that water quality standards are not being met (or beneficial uses are not being protected) may be needed for a permit to be reopened mid-term, the reopener provision does not speak to a permitting authority’s ability to re-evaluate the need to update an LTCP at the time of permit renewal. *See generally id.* § IV.B.2.g, at 18,696; CSO Guidance for Permit Writers at 4-38 (providing that permit writers should consider waiting for permit term to end, if it is late in the five-year permit cycle, to address changes in the context of normal permit reissuance process). Moreover, the Region’s stated objectives—including to ensure that up-to-date information is used to assess whether water quality standards are being met and to ensure that wet weather discharges are not causing unreasonable degradation of the marine environment—is entirely consistent with the aims of the CWA and the CWA’s incorporation of the CSO Control Policy. *See generally* CWA § 101(a), 33 U.S.C. § 1251(a) (providing that one objective of the CWA is to “restore and maintain the chemical, physical, and biological integrity of the Nation’s waters”); CSO Control Policy, 59 Fed. Reg. at 18,688 (“The CSO Policy represents a comprehensive national strategy to ensure that municipalities, permitting authorities, water quality standards authorities, and the public engage in a comprehensive and coordinated planning effort to achieve cost effective CSO controls that ultimately meet appropriate health and environmental objectives.”). Permitting authorities are required to issue permits that comply with the CWA, which includes ensuring that water quality standards will be met. To that end, permitting authorities may impose conditions in a permit for a combined sewer system that will achieve that objective, which under some circumstances reasonably can include updating a long-term control plan, particularly where such plan is decades old. In sum, San Francisco has failed to carry its burden to establish that the Region’s decision to include permit terms requiring San Francisco to update its LTCP rests on a clearly erroneous conclusion of law.

2. *The Region's Decision to Require San Francisco to Update its Long-Term Control Plan Is Factually Supported in the Record*

San Francisco next argues that the Region's decision to require an LTCP update is not supported in fact. Pet. at 23, 26. The Region's stated objectives for requiring the LTCP update include: (1) ensuring that water quality objectives during wet weather are met to the greatest extent practicable; (2) ensuring that receiving water designated uses are protected; (3) reducing risks to human health and the environment associated with discharges from combined sewer discharge points; (4) evaluating a range of control alternatives that further reduce discharges to sensitive areas; and (5) providing for adaptive management of the combined sewer system. Memo to File at 1-2; *see also* Fact Sheet at F-30 to F-31; Resp. to Cmts. at 18-19. Ultimately, the Region determined that an LTCP update is needed to ensure that San Francisco's LTCP is based on the most current information so that the Region can accurately "assess whether water quality standards are being met" and assure that "wet weather discharges are not causing unreasonable degradation of the marine environment." Fact Sheet at F-30 to F-31; *see also* Resp. to Cmts. at 17-19; Memo to File at 1-2, 5-8.

In addition to its objectives, the Region articulated multiple bases for requiring San Francisco to update its LTCP in the fact sheet issued with the draft permit as well as in subsequent documents. *See* Fact Sheet at F-30 to F-31; Memo to File at 5-8; Resp. to Cmts. at 16-17. The Region observed that San Francisco has provided many documents over the years relating to the planning and operations of its sewer system and that identifying the contents of San Francisco's current LTCP—that is, which documents the LTCP comprises and which documents are outdated or no longer applicable—is difficult. Resp. to Cmts. at 17. The Region describes San Francisco's LTCP as a compilation of documents "developed over the course of two decades, dating from 1971" rather than "a single document, as is the case with most combined sewer systems," making it difficult to discern the relationship between the documents. Memo to File at 5. In addition, beginning in 2011 (after the last permit was issued for the Oceanside CSS), San Francisco commenced a twenty-year effort to improve the city's wastewater system; the program (discussed earlier and referred to as the SSIP) identifies information related to the existing system and potential technology and water-quality based requirements that are intended to shape the sewer system (including long-term capital plans and projects to provide cost-effective controls that affect system performance and protect water quality). *Id.* (citing the SSIP and the studies conducted as part of that program). In support of the SSIP, San Francisco also issued a technical memorandum in 2015 identifying "collection system improvement opportunities." *See* S.F. Pub. Utils. Comm'n, *Westside Drainage*

Basin Urban Watershed Opportunities Technical Memorandum (Final Draft), at xi (Feb. 2015) (A.R. 69) (“2015 Westside Drainage Memorandum”); *see also* Memo to File at 10-11. Such information is clearly relevant to San Francisco’s LTCP. For example, its plan to control CSOs, as well as the Region’s determination as to whether San Francisco’s long-term plans will ensure compliance with the CWA, including the CSO Control Policy, are significant.

San Francisco points to the San Francisco Wastewater Long Term Control Plan Synthesis (“Synthesis”) which (as discussed above in Part IV) it submitted to the California RWQCB pursuant to a 2013 permit proceeding for a separate facility, as sufficient to summarize the various documents that constitute San Francisco’s historical planning process and LTCP. Pet. at 4 (citing Synthesis). According to the Region, however, this document does not adequately solve the problem as it incorporates earlier documents from the 1970s and 1980s (the most recent document in the Synthesis is a 1990 revision of a 1988 document). Resp. Br. at 29-30. Among other shortcomings, the Synthesis does not include the studies, findings, or plans associated with the SSIP.³³ Thus, as the Region concluded, the Synthesis does not provide a basis for the Region to analyze San Francisco’s current long-term control plan for wastewater and to assess whether that plan is adequate to ensure that San Francisco’s CSOs are meeting water quality standards, not causing unreasonable degradation to the marine environment, and achieving other objectives of the CSO Control Policy.³⁴ *See generally* CSO Control Policy § II.C,

³³ Notwithstanding the relevance to San Francisco’s LTCP, San Francisco maintains that the SSIP is not properly part of its LTCP because it did not exist at the time the LTCP was implemented. *See* S.F. Resp. to RWQCB Cmts. on Synthesis, attach. cmt. 1; Oral Arg. Tr. at 26. San Francisco’s position rests on its erroneous assumption that the LTCP remains static unless and until it is demonstrated that water quality standards are being exceeded.

³⁴ In its reply brief, San Francisco argues that the Region erroneously states that San Francisco has not addressed deficiencies that the California RWQCB identified in the Synthesis. Reply Br. at 12, n.6 (citing Resp. Br. at 30 n.16) (indicating that it had responded to the California RWQCB’s comments on the Synthesis). San Francisco’s response to comments on the Synthesis, however, does not establish that either the Region or the California RWQCB determined that the Synthesis is adequate for purposes of this Permit. It is the permitting authorities that must be satisfied that the LTCP is sufficient, and San Francisco’s view that the plan is sufficient does not necessarily make it so. In any event, San Francisco’s response to the California RWQCB does not appear to address the issues with the Synthesis identified by the Region above. *See* S.F. Resp. to RWQCB Cmts. on Synthesis, attach. cmt. 1 (stating that the compilation of documents in the Synthesis

59 Fed. Reg. at 18,691 (describing requirements for long-term control plans); *see also* Resp. Br. at 30 n.16 (noting that the California RWQCB also found the Synthesis to be inadequate, in part because it did not reflect current circumstances when it was submitted pursuant to the 2013 Bayside NPDES Permit); Fact Sheet at F-30 to F-31.

The Region also noted changed circumstances as a basis for the Permit's LTCP update requirement. The Region explained that the combined sewer system, the sewershed, and San Francisco's management approach have changed since construction was completed in 1997, and additional changes are underway and planned for the near future. Resp. to Cmts. at 17. For example, the facility discharges from seven CSD Outfalls rather than the eight originally planned. Resp. to Cmts. at 17 n.3; *see also* Memo to File at 6, n.9. Many of the planning documents developed since the issuance of the 2009 Permit—which contain information related to the programs and plans intended to shape the sewer system, including cost-effective controls that affect system performance and water quality protection—were developed by different departments within the San Francisco Public Utilities Commission and were not submitted to EPA as part of the LTCP. Memo to File at 5. These changes further complicate the fact that the Synthesis provided by San Francisco is an amalgam of historic LTCP documents, the most recent of which is a 1990 revision of a 1988 document, and therefore predates now-completed and ongoing changes to the system, the sewershed, and the management approach. The Region's goal is that an updated LTCP will coordinate and integrate the ongoing planning efforts and take into account changes that have occurred “since the original LTCP was first developed in the 1970's and implemented in 1997.”³⁵ *Id.* That goal is consistent with the strategy of the CSO Control Policy to require permittees to “accurately characterize” sewer systems and to submit “appropriate documentation.” CSO Control Policy § II, 59 Fed. Reg. at 18,691.

constitutes the LTCP as constructed through the 1990s and stating San Francisco Public Utilities Commission's conclusion that documents reflecting current conditions and current operating and monitoring of the existing system are not appropriately part of its LTCP).

³⁵ When asked at oral argument how San Francisco could determine the source, cause, or volume of an isolated sewer overflow, Counsel for San Francisco explained that it would rely on its characterization and modeling of the system. Oral Arg. Tr. at 38-40. That response underscores the Region's need to have an accurate and current characterization of the system.

Moreover, updating an LTCP is not unprecedented. As the Region noted, a number of other cities have updated their LTCPs for reasons that include the “need to achieve specific water quality standards, update control commitments, update system requirements based on capital improvements, includ[ing] additional green infrastructure controls, minimize impacts associated with combined sewer discharges, and clarify technology-based and water-quality based permit requirements.” Memo to File at 13-14 (providing links to information on updated LTCPs for thirteen cities between the years of 2005-2018); *see also* Resp. to Cmts. at 17 (noting that EPA has required LTCP updates for other combined sewer systems).

San Francisco maintains that the Region failed to establish that beneficial uses are not currently being protected. Pet. at 26; *see* Reply Br. at 12. The assumption underlying San Francisco’s argument is that a permitting authority can require a permittee to update its LTCP only if it is shown that beneficial uses of the receiving water are not being adequately protected. *See* Pet. at 26; *see* Reply Br. at 12. As discussed in Part V.D.1, above, however, San Francisco points to nothing in the CWA or its implementing regulations that requires such a demonstration prior to requiring an update of the LTCP in a permit.

San Francisco also argues that it “clearly identified the correct legal framework” for updating the LTCP in its comments on the draft permit. Pet. at 29 (citing San Francisco Comments, attach. B at 10). The “legal framework” to which San Francisco refers is the subsection of the CSO Control Policy that addresses the objectives for permittees in considering sensitive areas in the development and review of long-term CSO control plans. *Id.*; San Francisco Comments, attach. B at 10 (citing CSO Control Policy § II.C.3). The provision of the subsection cited that addresses reconsideration of sensitive areas describes how permitting authorities should require permittees to review and reassess discharges to sensitive areas in subsequent permit terms, considering new or improved techniques to eliminate or relocate discharges to sensitive areas, as well as changed circumstances that influence economic achievability. CSO Control Policy II.C.3.c, 59 Fed. Reg. at 18,692. The one-sentence provision on reassessing discharges to sensitive areas does not, however, set forth a legal framework for weighing whether and how the permitting agency should factually support the need to review and revise an LTCP that is decades old and not readily ascertainable from existing documents for a combined sewer system and sewershed that has undergone many changes since the LTCP was formulated, with additional changes underway and planned for the near future.

With respect to the specific terms of the LTCP update requirement, the Region relied on various elements of the CSO Control Policy section pertaining to the LTCP requirements for Phase II permits. *Compare* Fact Sheet at F-31 with CSO Control Policy §§ II.C., IV.B., 59 Fed. Reg. at 18,691-94, 18,695-96. Those elements are:

- “[N]arrative requirements to ensure that selected controls are implemented, operated, and maintained as described in the * * * LTCP” (*see* CSO Control Policy § IV.B.2.b);
- [A] requirement to monitor and collect sufficient information to demonstrate compliance with water quality standards and protect designated uses, as well as to determine the effectiveness of combined sewer system controls” (*see id.* § IV.B.2.d);
- “[A] requirement to reassess combined sewer discharges to sensitive areas in those cases where elimination or relocation was previously found to be not physically possible and economically achievable” (*see id.* § IV.B.2.e); and
- “Requirements for maximizing the treatment of wet weather flows at the treatment plant, as appropriate” (*see id.* § IV.B.2.f).

Fact Sheet at F-31. The Region points to the above elements of the CSO Control Policy in support of requiring San Francisco to include these elements in its updated LTCP. *Id.* at 30-31.³⁶

³⁶ San Francisco asserts that the Region failed to respond to its request to identify the legal authority for the tasks in table 7 of the Permit. Pet. at 10. In its response to comments document, however, the Region stated that it relied on the CSO Control Policy’s Phase II permit requirements for implementation of a long-term control plan, as well LTCP Guidance. Resp. to Cmts. at 16-17. Additionally, the requirements in table 7 of the Permit track the requirements in both the CSO Control Policy and the LTCP Guidance. *Compare* Permit at 21-23 tbl.7, with CSO Control Policy § II.C, 18,691-94; *see also generally* LTCP Guidance. The Region’s response to San Francisco on the rationale for the tasks described in table 7 satisfies the Region’s obligations under 40 C.F.R. § 124.17(a)(2). *See Circle T Feedlot*, 14 E.A.D. at 674-76 (discussing the permitting authority’s obligation to respond to comments under 40 C.F.R. § 124.17(a)(2)).

The Region also points to State Water Board Order No. WQ 79-16, which, among other things, requires San Francisco to design and construct and operate facilities to the greatest extent practical to conform to the standards set forth in chapters II and III of the 1978 Ocean Plan. *Id.* Ultimately, the Region determined that an updated LTCP that takes into account all the changes to the combined sewer system, the sewershed, and the management approach is necessary. Fact Sheet at F-31. Further, the Region determined that compiling the LTCP in one document that contains the basic elements set forth in the CSO Control Policy, is necessary so that the Region can ensure that San Francisco's LTCP is "based on the most current information" and so that the Region can, among other things, properly "assess whether water quality standards are being met" and whether "wet weather discharges are not causing unreasonable degradation of the marine environment." *Id.* (citing 40 C.F.R. § 125.122); *see also* Memo to File at 5-8.

San Francisco suggests that the requirement to update the LTCP mandates an unduly onerous "re-examination" of its facilities that will take years to complete. Pet. at 23. The tasks required in table 7 of the Permit, as described above, are clearly laid out.³⁷ Permit § VI.C.5.d, at 21-23. The task list also provides a timeline for completing these tasks that allows up to forty-eight months for many of the tasks. *Id.* Recognizing that San Francisco's CSO facilities are already substantially completed, the Region also allows San Francisco to "use previously completed studies to the extent that they accurately provide the required information." *Id.* § VI.C.5.d, at 21; *see also* Resp. to Cmts. at 17.³⁸ San Francisco does not identify

³⁷ In its reply brief, San Francisco also argues that the Region "mischaracterizes the nature of the obligations" in section VI.C.5.d of the Permit (requiring the LTCP update and describing what that entails). Reply Br. at 12. As San Francisco notes, however, the Permit terms speak for themselves. *Id.* As we state above, the tasks are clearly set forth in the Permit with timelines for completion and permission to use previously completed studies as appropriate. San Francisco has not established any basis for concluding the Region mischaracterized the tasks outlined in the Permit or that the tasks will be unduly onerous or take more time to complete than set forth in the Permit.

³⁸ Although San Francisco asserts that the Region's rationale in its response to comments was "post hoc," Pet. at 26, the response to comments document is an appropriate vehicle for the Region to provide its rationale for a final permitting decision. *See City of Taunton Dept. of Pub. Works*, 17 E.A.D. 105, 125, 186 (EAB 2016), *aff'd*, 895 F.3d 120 (1st Cir 2018), *cert. denied* 139 S. Ct. 1240 (Feb. 19, 2019). Indeed, that is precisely the purpose of the response to comments document. *See id.*; 40 C.F.R. § 124.17(a) (requiring the permitting authority to provide its rationale for any changes made from the draft and to briefly respond to all significant comments on the draft permit).

any specific enumerated task that it contends is unreasonable; nor does San Francisco carry its burden of demonstrating that the Region clearly erred in requiring in the Permit that these tasks be completed.

3. *The Permit Requirement to Update its Long-Term Control Plan Provides San Francisco With Fair Notice of What is Required*

Finally, San Francisco maintains that the LTCP update provision fails to provide San Francisco with “fair notice” of what San Francisco is required to do to comply. Pet. at 30-31. San Francisco suggests that because the LTCP Update provision does not provide any guidance on “*why* reduction is necessary or * * * *how much* reduction is necessary to protect beneficial uses,” and the Region has for decades concluded that the limits for prior discharges were protective of beneficial uses, San Francisco cannot know what is required of its facilities. *Id.* By focusing on what specific levels of pollutants are required to protect beneficial uses, San Francisco fails to engage the Region’s rationale for the provision—the LTCP needs to be updated so that the Region can adequately assess the CSS to determine whether beneficial uses are being adequately protected. Resp. Br. at 28. Instead, San Francisco is essentially arguing that the Region must rely on inadequate characterization, outdated management approaches, and old inadequate data to prove that beneficial uses are not being protected before it can require an update to the LTCP.

As stated in Part V.D.2, above, the Permit clearly describes, defines, and articulates the tasks that San Francisco is required to complete. Permit § VI.C.5.d tbl.7, at 21-23. While San Francisco describes the tasks as vague references to beneficial use requirements, they are, in fact, detailed and specific, while still allowing San Francisco the opportunity to propose how best to address any issues it identifies. *See generally id.* (setting forth the tasks required to update the LTCP, which include “identify[ing]” alternatives, “evaluat[ing]” feasibility and costs, and “consider[ing]” costs relative to benefits for water quality and other public benefits).³⁹ Pet. at 30-31. Current information on the system will allow the

³⁹ San Francisco argues that the Region failed to respond to its comment with respect to fair notice. Pet. at 11. In its comments on the draft permit, San Francisco asserted that the terms in table 7 of the Permit were “vague” and failed to provide “fair notice” of what is “specifically required.” Resp. to Cmts. at 16. We find the argument that the Region failed to respond to be without merit. *See* Resp. to Cmts. at 16-21 (responding to San Francisco’s comments regarding the LTCP update requirement); *see also Circle T*

permitting authorities to better assess whether water quality standards are being met, whether wet weather discharges are causing unreasonable degradation to the environment, and whether discharges to sensitive areas are being reduced to the maximum extent practicable. Fact Sheet at F-31; Resp. to Cmts. at 16-17, 18-19, 20; Memo to File at 1-2, 5-8.

In sum, San Francisco has failed to carry its burden to show that the Region clearly erred in requiring San Francisco to update its LTCP.

VI. *CONCLUSION*

For the reasons stated above, the Petition for Review is denied.

So ordered.

Feedlot, 14 E.A.D. at 674-76 (discussing the permitting authority's obligation to respond to comments under 40 C.F.R. § 124.17(a)(2)).

Exhibit 3



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION IX
75 Hawthorne Street
San Francisco, CA 94105-3901

**OFFICE OF THE
REGIONAL ADMINISTRATOR**

NOTICE OF FINAL PERMIT DECISION

NPDES Permit No. CA0037681

For the City and County of San Francisco Oceanside Water Pollution Control Plant, Wastewater Collection System, and Westside Recycled Water Project

In accordance with the requirements of the Code of Federal Regulations (C.F.R.), Title 40 § 124.19(m), the United States Environmental Protection Agency, Region 9 (EPA) is issuing a Notice of Final Permit Decision for NPDES Permit No. CA0037681 to the City and County of San Francisco for the Oceanside Water Pollution Control Plant, Wastewater Collection System, and Westside Recycled Water Project (San Francisco), reissued on December 10, 2019. The final NPDES Permit and copy of this notice are available on EPA's web page at: <https://www.epa.gov/npdes-permits/city-and-county-san-francisco-oceanside-water-pollution-control-plant-wastewater>.

San Francisco filed a petition for review (Petition) of the final Permit with EPA's Environmental Appeals Board (EAB) on January 13, 2020. In the Petition, San Francisco contested certain conditions of the Final Permit. The uncontested and severable portions of the Final Permit were placed into effect pursuant to a Notice of Uncontested and Severable Conditions, dated February 7, 2020. The contested conditions were stayed pending a decision by the EAB on the Petition and final agency action.

On December 1, 2020, the EAB issued an order denying the Petition in its entirety. *In re City and County of San Francisco*, NPDES Appeal No. 20-01, 18 EAB 322. Under 40 C.F.R. § 124.19(m)(2)(i), the Regional Administrator must issue a final permit decision when the Board issues notice to the parties that a petition for review has been denied. I am, accordingly, hereby issuing my final permit decision. The contested conditions shall become fully effective and enforceable in accordance with the terms of the Final Permit on February 1, 2021.¹

This decision constitutes final agency action under 40 C.F.R. § 124.19(m)(1). Under 40 C.F.R. § 23.2 this Notice becomes effective for purposes of judicial review under 33 U.S.C. § 1369(b) and 5 U.S.C. § 704 two weeks after the Notice is signed.

Dated: _____

**JOHN
BUSTERUD**
Digitally signed by
JOHN BUSTERUD
Date: 2020.12.22
10:28:43 -08'00'

John W. Busterud
Regional Administrator

¹ The permit expiration date remains unchanged and is October 31, 2024.